



ADDENDUM to the Contract for the
STATTER HARBOR IMPROVEMENTS PHASE III(d)
UPLAND IMPROVEMENTS
Contract No. DH25-023

ADDENDUM NO.: **TWO**

CURRENT DEADLINE FOR BIDS:
May 7, 2025

PREVIOUS ADDENDA: **ONE**

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: **April 29, 2025**

The following items of the contract are modified as herein indicated. This addendum has been issued and is posted online. Please refer to the: <https://juneau.org/finance/purchasing/bids-rfps>

CLARIFICATION:

Question No. 1: *"Apparently, all the suppliers have transitioned over to an ASTM A500 Grade B & C. The A53 is getting hard to find so the reason for the question. Attached is a sample materials test report on the ASTM A500 for your review. We want to know if we can quote the job with this alternate Specification."*

Response: See PROJECT MANUAL Item No. 1 below.

PROJECT MANUAL:

Item No. 1: SECTION 05120 – METAL FABRICATION, PART 2 – PRODUCTS, ARTICLE 2.1 – MATERIALS, **Remove** Paragraph C in its entirety and **replace with** "C. Pipe less than 12-inch diameter shall be ASTM A500, Grade B or C, hot-dip galvanized, unless otherwise noted."

Receipt of this addendum must be acknowledged, or your bid may be considered non-responsive. Acknowledge the addendum in the submitted bid.

By: Matthew Creswell Acting Port Director
Carl Uchtyl, PE,
Port Director