

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS JUNEAU, CITY AND BOROUGHS OF 155 SOUTH SEWARD JUNEAU, ALASKA 99801		PERMIT NUMBER AK0021407		DISCHARGE NUMBER 001 A	
FACILITY: AUK BAY TREATMENT FACILITY		MONITORING PERIOD YR 99 MO 01 DAY 01 to YR 99 MO 01 DAY 31		MAJOR (SUBR 01)	
LOCATION: JUNEAU, ALASKA		QUANTITY OR LOADING AVERAGE MAXIMUM UNITS		QUALITY OR CONCENTRATION MINIMUM AVERAGE MAXIMUM UNITS	
PARAMETER TEMPERATURE, WATER DEG, CENTIGRADE 00010 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT PERMIT REQUIREMENT	8.3 25 DAILY AVG DAILY MAX	12.9 50 DAILY MAX	9.4 11.2 REPORT DAILY AVG DAILY MAX DEG. C	0 57 DAILY GRAB
00010 1 0 0 EFFLUENT GROSS VALUE (20 DEG. C)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	8.3 25 DAILY AVG DAILY MAX	12.9 50 DAILY MAX	9.4 11.2 REPORT DAILY AVG DAILY MAX DEG. C	0 57 DAILY GRAB
00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT PERMIT REQUIREMENT	8.3 25 DAILY AVG DAILY MAX	12.9 50 DAILY MAX	9.4 11.2 REPORT DAILY AVG DAILY MAX DEG. C	0 57 DAILY GRAB
pH	SAMPLE MEASUREMENT PERMIT REQUIREMENT	6.5 6.0 MIN.	9.0 MAXIMUM	9.0 MAXIMUM	0 57 DAILY GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT PERMIT REQUIREMENT	9.0 15.3	15.3	9.0 MAXIMUM	0 57 DAILY GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT PERMIT REQUIREMENT	9.0 25 DAILY AVG DAILY MAX	15.3 50 DAILY MAX	15 26 REPORT DAILY AVG DAILY MAX SU	0 1/MO COMP
SOLIDS, SETTLEABLE 00545 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT PERMIT REQUIREMENT	9.0 25 DAILY AVG DAILY MAX	15.3 50 DAILY MAX	15 26 REPORT DAILY AVG DAILY MAX SU	0 1/MO COMP
COLIFORM, FECAL MF, M-FC BROTH, 44.5C 31616 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT PERMIT REQUIREMENT	0.070 0.15	2.00	0.15 2.00 REPORT DAILY AVG DAILY MAX MG/L	0 1/MO GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT PERMIT REQUIREMENT	0.070	0.070	2 49 REPORT DAILY AVG DAILY MAX ML/	0 1/MO GRAB
I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)		TELEPHONE 907 789 9919		DATE 99 02 08	

NAME/TITLE PRINCIPAL EXEC. OFFICER
Andrew W. Bronson
 ANDREW BRONSON- WASTEWATER UTILITIES SUPERINTENDENT

COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

Monitoring period from 01/03/99 through 01/30/99.

