

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

F - FINAL

PERMITTEE NAME/ADDRESS		JUNEAU, CITY AND BOURGHOUGH OF		AK0021407		001 A	
NAME:		155 SOUTH SEWARD		PERMIT NUMBER		DISCHARGE NUMBER	
ADDRESS:		JUNEAU, ALASKA 99801		MONITORING PERIOD		YEAR MO DAY	
FACILITY:		AUKE BAY TREATMENT FACILITY		YR MO DAY		99 02 01 to 99 02 28	
LOCATION:		JUNEAU, ALASKA		NO. OF ANALYSIS		0 5/7	
PARAMETER		SAMPLE		AVERAGE		MAXIMUM	
TEMPERATURE, WATER		MEASUREMENT		10.0		11.9	
DEG, CENTIGRADE		PERMIT		REPORT DAILY AVG		REPORT DAILY MAX	
00010 1 0 0		REQUIREMENT		23		33	
EFFLUENT GROSS VALUE		SAMPLE		30		60	
BOD, 5-DAY		MEASUREMENT		DAILY AVG		DAILY MAX	
(20 DEG, C)		PERMIT		0.68		7.00	
00310 1 0 0		REQUIREMENT		REPORT DAILY AVG		REPORT DAILY MAX	
EFFLUENT GROSS VALUE		SAMPLE		23		33	
pH		MEASUREMENT		30		60	
00400 1 0 0		PERMIT		DAILY AVG		DAILY MAX	
EFFLUENT GROSS VALUE		REQUIREMENT		6.7		7.4	
SOLIDS, TOTAL		SAMPLE		9.0		9.0	
SUSPENDED		MEASUREMENT		MIN.		MAXIMUM	
00530 1 0 0		PERMIT		23		61	
EFFLUENT GROSS VALUE		REQUIREMENT		30		60	
SOLIDS, SETTLEABLE		SAMPLE		DAILY AVG		DAILY MAX	
00545 1 0 0		MEASUREMENT		0.68		7.00	
EFFLUENT GROSS VALUE		PERMIT		REPORT DAILY AVG		REPORT DAILY MAX	
COLIFORM, FECAL MF,		REQUIREMENT		56		2200	
M-F-C BROTH, 44,5C		SAMPLE		30 DAY GEO		400	
31616 1 0 0		MEASUREMENT		DAILY AVG		7 DAY GEO	
EFFLUENT GROSS VALUE		PERMIT		200		400	
FLOW, IN CONDUIT OR		SAMPLE		30 DAY GEO		400	
THRU TREATMENT PLANT		MEASUREMENT		DAILY AVG		7 DAY GEO	
50050 1 0 0		PERMIT		0.062		0	
EFFLUENT GROSS VALUE		REQUIREMENT		MGD		DAILY	

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND, BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. (SEE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.))

NAME/TITLE PRINCIPAL EXEC. OFFICER: *Andrew W. Branson* TELEPHONE: 907 789 9919 DATE: 99 03 08

ANDREW BRONSON- WASTEWATER UTILITIES SUPERINTENDENT COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE) PG 1 OF 2

