

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS: JUNEAU, CITY AND BOROUGH OF  
 155 SOUTH SEWARD  
 JUNEAU, ALASKA 99801  
 FACILITY: AUKE BAY TREATMENT FACILITY  
 LOCATION: JUNEAU, ALASKA

AK0021407 / ERMIT NUMBER: 001 A  
 DISCHARGE NUMBER: 001 A  
 MONITORING PERIOD: MO 07 01 to DAY 01 31  
 YEAR 89 MO 07 DAY 31  
 MAJOR SUBSTRATE

PARAMETER	MEASUREMENT	QUANTITY OR LOADING AVERAGE	MAXIMUM	UNITS
TEMPERATURE, WATER	SAMPLE MEASUREMENT			
DEG. CENTIGRADE	PERMIT REQUIREMENT			
00010 1 0 0				
EFFLUENT GROSS VALUE		10.4	13.2	
BOD, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT			
00310 1 0 0	PERMIT REQUIREMENT	25	50	LBS/DAY
EFFLUENT GROSS VALUE				
pH	SAMPLE MEASUREMENT			
00400 1 0 0	PERMIT REQUIREMENT			
EFFLUENT GROSS VALUE				
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	8.2	11.0	
00530 1 0 0	PERMIT REQUIREMENT	25	50	LBS/DAY
EFFLUENT GROSS VALUE				
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT			
00545 1 0 0	PERMIT REQUIREMENT			
EFFLUENT GROSS VALUE				
COLIFORM, FECAL MF, M-FC BROTH, 44.5C	SAMPLE MEASUREMENT			
31616 1 0 0	PERMIT REQUIREMENT			
EFFLUENT GROSS VALUE				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.088		
50050 1 0 0	PERMIT REQUIREMENT			
EFFLUENT GROSS VALUE				MGD

QUALITY OR CONCENTRATION AVERAGE	MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
15.9	16.6		0	5/7	GRAB
REPORT DAILY AVG	REPORT DAILY MAX	DEG. C		DAILY GRAB	
14	18		0	1/MO	COMP
30	60	MG/L	COMP 24 - ONCE/MONTH		
DAILY AVG	DAILY MAX	L	0	5/7	GRAB
6.7	7.6			DAILY GRAB	
60	90	SU			
M N	MAXIMUM				
11	15		0	1/MO	COMP
30	60	MG/L	COMP 24 - ONCE/MONTH		
DAILY AVG	DAILY MAX	L	0	1/MO	GRAB
0.00	0.00			DAILY GRAB	
REPORT DAILY AVG	REPORT DAILY MAX	ML/L			
5	13		0	1/MO	GRAB
200	400	#/100		DAILY GRAB	
30 DAY GEO7 DAY GEO		ML	0	7/7	CONT.
				DAILY	

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)

NAME/TITLE: *Andrew W. Bronson* PRINCIPAL EXEC. OFFICER  
 TELEPHONE: 907 789 9919  
 DATE: 99 08 08  
 ANDREW BRONSON - WASTEWATER UTILITIES SUPERINTENDENT  
 COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE):  
 PG 1 OF 2

F - FINAL

