

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS
 JUNEAU, CITY AND BOROUGH OF
 155 SOUTH SEWARD
 JUNEAU, ALASKA 99801
 FACILITY:
 AUK BAY TREATMENT FACILITY
 LOCATION:
 JUNEAU, ALASKA

AK0021407
 PERMIT NUMBER
 MONITORING PERIOD
 YR MO DAY YEAR MO DAY
 99 10 01 99 10 31
 DISCHARGE NUMBER
 001 A

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	MAXIMUM			
TEMPERATURE, WATER DEG, CENTIGRADE			14.5	15.8	0	5/7	GRAB
00010 1 0 0 EFFLUENT GROSS VALUE			REPORT DAILY AVG	REPORT DAILY MAX		DAILY GRAB	
BOD, 5-DAY (20 DEG C)	5.9	7.1	9	11	0	1/MO	COMP
00310 1 0 0 EFFLUENT GROSS VALUE			30 DAILY AVG	60 DAILY MAX		COMP 24 - ONCE/MONTH	
pH			6.6	7.5	0	5/7	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE			6.0 MIN	9.0 MAXIMUM		DAILY GRAB	
SOLIDS, TOTAL SUSPENDED	6.3	8.4	10	13	0	1/MO	COMP
00530 1 0 0 EFFLUENT GROSS VALUE			30 DAILY AVG	60 DAILY MAX		COMP 24 - ONCE/MONTH	
SOLIDS, SETTLEABLE			0.00	0.00	0	1/MO	GRAB
00545 1 0 0 EFFLUENT GROSS VALUE			REPORT DAILY AVG	REPORT DAILY MAX		DAILY GRAB	
COLIFORM, FECAL MF, M-FC BROTH, 44.5C			42	160000	0	1/MO	GRAB
31616 1 0 0 EFFLUENT GROSS VALUE			200	400		DAILY GRAB	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.078		30 DAY GEO	7 DAY GEO	0	7/7	CONT.
50050 1 0 0 EFFLUENT GROSS VALUE						DAILY	

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$1,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)

NAME/TITLE PRINCIPAL EXEC. OFFICER
Andrew W. Brinson
 ANDREW BRONSON- WASTEWATER UTILITIES SUPERINTENDENT
 COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

TELEPHONE 907 789 9919 DATE 11 08

