

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

F. FINAL

PERMITTEE NAME/ADDRESS		PERMIT NUMBER		DISCHARGE NUMBER			
JUNEAU, CITY AND BOROUGH OF 155 SOUTH SEWARD JUNEAU, ALASKA 99801		AK0021407		001 A			
FACILITY:		MONITORING PERIOD		YEAR	MO	DAY	
AUKE BAY TREATMENT FACILITY		YR	MO	DAY	00	05	31
LOCATION:		MAJOR (SUBR 01)					
JUNEAU, ALASKA							
PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 0			13.3	14.8	0	5/7	GRAB
EFFLUENT GROSS VALUE			REPORT DAILY AVG	REPORT DAILY MAX			
BOD, 5-DAY (20 DEG. C) 00030 1 0 0	3.4	3.4	7	7	0	1/MO	COMP
EFFLUENT GROSS VALUE			REPORT DAILY AVG	REPORT DAILY MAX			
pH			6.2	7.0	0	5/7	GRAB
00400 1 0 0			6.0 MIN	9.0 MAXIMUM			DAILY GRAB
EFFLUENT GROSS VALUE							
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	3.6	3.6	7	7	0	1/MO	COMP
EFFLUENT GROSS VALUE			REPORT DAILY AVG	REPORT DAILY MAX			
SOLIDS, SETTLEABLE 00545 1 0 0			0.00	0.00	0	1/MO	GRAB
EFFLUENT GROSS VALUE			REPORT DAILY AVG	REPORT DAILY MAX			
COLIFORM, FECAL MF, M-FC BROTH, 44.5C 31616 1 0 0			2	2	0	1/MO	GRAB
EFFLUENT GROSS VALUE			REPORT DAILY AVG	REPORT DAILY MAX			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	0.062		200	100	0	7/7	CONT.
EFFLUENT GROSS VALUE			30 DAY SE	7 DAY GROSS			
							DAILY

  

NAME/TITLE PRINCIPAL EXEC. OFFICER		TELEPHONE		DATE	
ANDREW BRONSON - WASTEWATER UTILITIES SUPERINTENDENT		907	789	00	06
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)					
I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$ 10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)					
<i>Andrew W. Bronson</i> 9919 00					

