

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)**

PERMITTEE NAME/ADDRESS		AK0021407		001 A	
NAME:		PERMIT NUMBER		DISCHARGE NUMBER	
ADDRESS:		YR		YEAR	
155 SOUTH SEWARD		MO		MO	
JUNEAU, ALASKA 99801		DAY		DAY	
FACILITY:		00		00	
AUKE BAY TREATMENT FACILITY		08		08	
LOCATION:		01		30	
JUNEAU, ALASKA		to		MAJOR (SUBR 01)	

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
TEMPERATURE, WATER DEG, CENTIGRADE							
00010 1 0 0				15.7	16.4	0	5/7
EFFLUENT GROSS VALUE				REPORT DAILY AVG	REPORT DAILY MAX		DAILY GRAB
BOD, 5-DAY (20 DEG. C)	6.6	6.6		10	10	0	1/MO
00310 1 0 0							COMP 24 - ONCE/MONTH
EFFLUENT GROSS VALUE							
pH			6.2		6.8	0	5/7
00400 1 0 0							GRAB
EFFLUENT GROSS VALUE							DAILY GRAB
SOLIDS, TOTAL SUSPENDED	10.2	10.2		15	15	0	1/MO
00530 1 0 0							COMP
EFFLUENT GROSS VALUE							COMP 24 - ONCE/MONTH
SOLIDS, SETTLEABLE				0.00	0.00	0	1/MO
00545 1 0 0							GRAB
EFFLUENT GROSS VALUE							DAILY GRAB
COLIFORM, FECAL MF, M-FC BROTH, 44.5C							
31616 1 0 0				2	2	0	1/MO
EFFLUENT GROSS VALUE							GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.081						
50050 1 0 0							DAILY GRAB
EFFLUENT GROSS VALUE							
						0	7/7
							CONT.
							DAILY

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)

NAME/TITLE	PRINCIPAL EXEC. OFFICER	TELEPHONE	DATE
ANDREW BRONSON - WASTEWATER UTILITIES SUPERINTENDENT	Andrew W. Bronson	907 789 9919	00 10 08
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)			

