

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

F - FINAL

PERMITTEE NAME/ADDRESS		AK0021407		DISCHARGE NUMBER		001 A	
NAME:		JUNEAU, CITY AND BOROUGH OF		PERMIT NUMBER		MONITORING PERIOD	
ADDRESS:		155 SOUTH SEWARD		YR		DAY	
FACILITY:		JUNEAU, ALASKA 99801		MO		MO	
LOCATION:		AUKE BAY TREATMENT FACILITY		2000		2000	
		JUNEAU, ALASKA		12		12	
				01		31	
				to		to	
				MAJOR (SUBR DT)			

PARAMETER	QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM		MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG, CENTIGRADE	*****	*****		12.7	14.2	*****	0	5/7	GRAB
00010 1 0 0 EFFLUENT GROSS VALUE	*****	*****		REPORT DAILY AVG	REPORT DAILY MAX	*****		DAILY GRAB	
BOD, 5-DAY (20 DEG. C)	3.4	3.4		6.4	6.4	*****		1/MO	COMP
00310 1 0 0 EFFLUENT GROSS VALUE	25	50	LBS/DAY	30	60	*****		COMP 24 - ONCE/MONTH	
pH	*****	*****		*****	7.0	6.1		5/7	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****		*****	9.0	6.0		DAILY GRAB	
SOLIDS, TOTAL SUSPENDED	3.2	3.2		6.0	6.0	*****		1/MO	COMP
00530 1 0 0 EFFLUENT GROSS VALUE	25	50	LBS/DAY	30	60	*****		COMP 24 - ONCE/MONTH	
SOLIDS, SETTLEABLE	*****	*****		0.00	0.00	*****		1/MO	GRAB
00545 1 0 0 EFFLUENT GROSS VALUE	*****	*****		REPORT DAILY AVG	REPORT DAILY MAX	*****		DAILY GRAB	
COLIFORM, FECAL MF, M-FC BROTH, 44.5C	*****	*****		1	1	*****		1/MO	GRAB
31616 1 0 0 EFFLUENT GROSS VALUE	*****	*****		200	400	*****		DAILY GRAB	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.065	*****		30 DAY GEO	7 DAY GEO	*****		DAILY GRAB	
50050 1 0 0 EFFLUENT GROSS VALUE	*****	*****	MGD	*****	*****	*****		7/7	CONT.
	*****	*****		*****	*****	*****		DAILY	

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$ 10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)

NAME/TITLE	PRINCIPAL EXEC. OFFICER	ANDREW W. BRONSON
NAME/TITLE	WASTEWATER UTILITIES SUPERINTENDENT	ANDREW BRONSON
TELEPHONE	907 789 9919	2001 01 08
DATE		

COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

