



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

F - FINAL

PERMITTEE NAME/ADDRESS		PERMIT NUMBER		DISCHARGE NUMBER				
JUNEAU, CITY AND BOROUGH OF 155 SOUTH SEWARD JUNEAU, ALASKA 99801		AK0021407		001 A				
FACILITY:		MONITORING PERIOD		YEAR				
ALUKE BAY TREATMENT FACILITY JUNEAU, ALASKA		2001 01 01 to 2001 01 31		2001 01 31				
PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE				MAXIMUM
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****	*****	11.9	12.8	0	5/7	GRAB
00010 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX	0	DAILY GRAB	GRAB
BOD, 5-DAY (20 DEG. C)	3.7	3.7	*****	6.5	6.5	0	1/MO	COMP
000310 1 0 0 EFFLUENT GROSS VALUE	25 DAILY AVG	50 DAILY MAX	*****	30 DAILY AVG	60 DAILY MAX	COMP 24 - ONCE/MONTH		
pH	*****	*****	6.0	*****	7.0	0	5/7	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	6.0 MIN.	*****	9.0 MAXIMUM	DAILY GRAB		
SOLIDS, TOTAL SUSPENDED	4.5	4.5	*****	8.0	8.0	0	1/MO	COMP
00630 1 0 0 EFFLUENT GROSS VALUE	25 DAILY AVG	50 DAILY MAX	*****	30 DAILY AVG	80 DAILY MAX	COMP 24 - ONCE/MONTH		
SOLIDS, SETTLEABLE	*****	*****	*****	0.00	0.00	0	1/MO	GRAB
00545 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX	DAILY GRAB		
COLIFORM, FECAL MF, M-FC BROTH, 44-5C	*****	*****	*****	11	11	0	1/MO	GRAB
31616 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	200 30 DAY GEO	400 7 DAY GEO	DAILY GRAB		
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.068	*****	*****	*****	*****	0	7/7	CONT.
50050 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	DAILY		

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$ 10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)

NAME/TITLE PRINCIPAL EXEC. OFFICER	TELEPHONE	DATE
ANDREW BRONSON, WASTEWATER UTILITIES SUPERINTENDENT	907 789 9919	2001 02 08

COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

*Andrew W. Bronson*

PG 1 OF 2