

# NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) DISCHARGE MONITORING REPORT (DMR)

MINOR  
( SUBR 01)  
F - FINAL

PERMITTEE NAME/ADDRESS		AK0021407		001 A		DISCHARGE NUMBER		
NAME: JUNEAU, CITY AND BOROUGH OF		PERMIT NUMBER		MONITORING PERIOD				
ADDRESS: 155 SOUTH SEWARD		YR	MO	DAY	YR	MO	DAY	
FACILITY: AUIKE BAY TREATMENT FACILITY		2001	08	01	2001	08	31	
LOCATION: JUNEAU, ALASKA		FROM		TO		MAJOR (SUBR 01)		
PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE				
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****	*****	17.1	17.8	0	57	
00010 1 00 EFFLUENT GROSS VALUE	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX	0	DAILY	GRAB
BOD, 5-DAY (20 DEG. C)	13.5	22.2	*****	22	37	0	1/MO	
00310 1 00 EFFLUENT GROSS VALUE	25	50	*****	DAILY AVG	DAILY MAX	0	ONCE/MONTH	COMP 24
pH	*****	*****	6.1	*****	7.5	0	57	
00400 1 00 EFFLUENT GROSS VALUE	*****	*****	60 MIN	*****	90 MAXIMUM	0	DAILY	GRAB
SOLIDS, TOTAL SUSPENDED	2.7	5.4	*****	5	9	0	1/MO	
00830 1 00 EFFLUENT GROSS VALUE	25	50	*****	DAILY AVG	DAILY MAX	0	ONCE/MONTH	COMP 24
SOLIDS, SETTLEABLE	*****	*****	*****	0.00	0.00	0	1/MO	
00846 1 00 EFFLUENT GROSS VALUE	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX	0	DAILY	GRAB
COLIFORM, FECAL MF. M-FC BROTH, 44.5C	*****	*****	*****	13	13	0	1/MO	
31616 1 00 EFFLUENT GROSS VALUE	*****	*****	*****	30 DAY GEO	7 DAY GEO	0	ONCE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.072	*****	*****	*****	*****	0	777	CONT.
50050 1 00 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	0	DAILY	

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$ 10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)

NAME/TITLE PRINCIPAL EXEC. OFFICER Ernie Mueller Public Works Director	TELEPHONE 907 789	9919	2001	DATE 09	08
---	----------------------	------	------	------------	----

COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

PG 1 OF 2

