

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

F - FINAL

PERMITTEE NAME/ADDRESS		PERMIT NUMBER		DISCHARGE NUMBER				
JUNEAU, CITY AND BOROUGH OF		AK0021407		001 A				
ADDRESS:		MONITORING PERIOD		YEAR				
155 SOUTH SEWARD		YR		2002				
JUNEAU, ALASKA 99801		MO		01				
FACILITY:		DAY		MO				
AUKE BAY TREATMENT FACILITY		2002		01				
LOCATION:		to		DAY				
JUNEAU, ALASKA		MAJOR (SUBR 01)		31				
PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE				
TEMPERATURE, WATER DEG, CENTIGRADE	*****	*****	*****	11.5	13.0	0	5/7	GRAB
00010 100 EFFLUENT GROSS VALUE	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX		DAILY GRAB	
BOD, 5-DAY (20 DEG. C)	2.9	*****	*****	5.2	5.2	0	1/MO	COMP
00310 100 EFFLUENT GROSS VALUE	25	50	*****	30	60		COMP 24 - ONCE/MONTH	
pH	*****	*****	6.2	DAILY AVG	DAILY MAX	0	5/7	GRAB
00400 100 EFFLUENT GROSS VALUE	*****	*****	6.0	*****	9.0		DAILY GRAB	
SOLIDS, TOTAL SUSPENDED	2.5	2.6	*****	4.6	4.6	0	1/MO	COMP
00530 100 EFFLUENT GROSS VALUE	25	50	*****	DAILY AVG	DAILY MAX		COMP 24 - ONCE/MONTH	
SOLIDS, SETTLEABLE	*****	*****	*****	0.00	0.00	0	1/MO	GRAB
00545 100 EFFLUENT GROSS VALUE	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX		DAILY GRAB	
COLIFORM, FECAL MF, M-FC BROTH, 44.5C	*****	*****	*****	2	2	0	1/MO	GRAB
31616 100 EFFLUENT GROSS VALUE	*****	*****	*****	30 DAY GEO	7 DAY GEO		DAILY GRAB	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.067	*****	*****	*****	*****	0	7/7	CONT.
50050 100 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****		DAILY	

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$ 10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)

NAME/TITLE: PRINCIPAL EXEC. OFFICER
 ERNIE MUELLER PUBLIC WORKS DIRECTOR
 COMMENT AND EXPLANATION OF ANY VIOLATIONS (SEE REFERENCE ALL ATTACHMENTS HERE)

TELEPHONE: 907 789 9919 DATE: 2002 02

PG 1 OF 2

