

# NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) DISCHARGE MONITORING REPORT (DMR)

MINOR  
( SUBR 01)  
F - FINAL

PERMITTEE NAME/ADDRESS JUNEAU, CITY AND BOROUGH OF 155 SOUTH SEWARD JUNEAU, ALASKA 99801 FACILITY: AUKE BAY TREATMENT FACILITY LOCATION: JUNEAU, ALASKA		PERMIT NUMBER AK0021407		DISCHARGE NUMBER 001 A				
MONITORING PERIOD YR 2003 MO 03 DAY 01 FROM TO 2003 03 01 TO 2003 03 31		MAJOR (SUBR 01)						
PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE				MAXIMUM
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****	*****	10.6	12.3	0	57	( 04)
000110 0 EFFLUENT GROSS VALUE	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX	0	DAILY	DEG. C
BOD, 5-DAY (20 DEG. C)	5.8	5.8	*****	9.6	9.6	0	1/MO	( 19)
00310 1 0 0 EFFLUENT GROSS VALUE	25	50	*****	DAILY AVG	DAILY MAX	0	ONCE/MONTH	MGL
pH	*****	*****	6.0	*****	6.5	0	5/7	( 12)
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	6.0 MIN.	*****	9.0 MAXIMUM	0	DAILY	SU
SOLIDS, TOTAL SUSPENDED	6.7	6.7	*****	11.0	11.0	0	1/MO	( 19)
00530 1 0 0 EFFLUENT GROSS VALUE	25	50	*****	DAILY AVG	DAILY MAX	0	ONCE/MONTH	MGL
SOLIDS, SETTLEABLE	*****	*****	*****	0.00	0.00	0	1/MO	( 25)
00545 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX	0	DAILY	ML/L
COLIFORM, FECAL MF, M-FC BROTH, 44.5C	*****	*****	*****	2	2	0	1/MO	( 13)
31616 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	30 DAY GEO	7 DAY GEO	0	ONCE/MONTH	# / 100 ML
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.073	*****	*****	*****	*****	0	7/7	CONT.
50060 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	0	DAILY	*****

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)

NAME/TITLE PRINCIPAL EXEC. OFFICER SCOTT JEFFERS WW UTILITIES SUPERINTENDENT	TELEPHONE 907 586 6393	DATE 2003 04 08
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)		

