

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

F - FINAL

PERMITTEE NAME/ADDRESS		AK0021407		001 A			
NAME: JUNEAU CITY AND BOROUGH OF		PERMIT NUMBER		DISCHARGE NUMBER			
ADDRESS: 155 SOUTH SEWARD		MONITORING PERIOD					
JUNEAU, ALASKA 99801		YR	MO	DAY	YEAR	MO	DAY
FACILITY: AUKE BAY TREATMENT FACILITY		2003	05	01	2003	05	31
LOCATION: JUNEAU, ALASKA		MAJOR (SUBR 01)					

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****			*****	13.5	14.2	(04)	0	5/7	
00010 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX	DEG. C		DAILY	GRAB
EFFLUENT GROSS VALUE											
BOD, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT	3.9	3.9	(26)	*****	6	6	(19)	0	1/MO	
00310 1 0 0	PERMIT REQUIREMENT	25	50		*****	30	60			ONCE/MONTH	COMP 24
EFFLUENT GROSS VALUE		DAILY AVG	DAILY MAX	LBS/DAY		DAILY AVG	DAILY MAX	MG/L			
pH	SAMPLE MEASUREMENT	*****	*****		6.1	*****	6.9	(12)	0	5/7	
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	6.0 MIN.	*****	9.0 MAXIMUM	SU		DAILY	GRAB
EFFLUENT GROSS VALUE											
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	4.4	4.4	(26)	*****	8	8	(19)	0	1/MO	
00530 1 0 0	PERMIT REQUIREMENT	25	50		*****	30	60			ONCE/MONTH	COMP 24
EFFLUENT GROSS VALUE		DAILY AVG	DAILY MAX	LBS/DAY		DAILY AVG	DAILY MAX	MG/L			
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****		*****	0.00	0.00	(25)	0	1/MO	
00545 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX	ML/L		DAILY	GRAB
EFFLUENT GROSS VALUE											
COLIFORM, FECAL MF, M-FC BROTH, 44.5C	SAMPLE MEASUREMENT	*****	*****		*****	2	2	(13)	0	1/MO	
31616 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	*****	200	400			ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE						30 DAY GEO	7 DAY GEO	# / 100 ML			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.071	*****	(03)	*****	*****	*****		0	7/7	CONT.
50050 1 0 0	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****		DAILY	
EFFLUENT GROSS VALUE											

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$ 10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 5 MONTHS AND SIX YEARS.)

NAME/TITLE PRINCIPAL EXEC. OFFICER	TELEPHONE	DATE
SCOTT JEFFERS, WW UTILITY SUPERINTENDENT	907 586 0393	2003 06 9

COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)