

**AUKE BAY WASTEWATER TREATMENT FACILITY**  
Juneau, Alaska  
**FEBRUARY 2013**

DAY	INFLUENT										EFFLUENT										MISCELLANEOUS			
	DATE	INFLUENT MGD	WASTE SLUDGE MGD	TEMP °C	pH	D.O. mg/L	S.S. mg/L	B.O.D. mg/L	B.O.D. LBS	FOG mg/L	NH3	TEMP °C	pH	D.O. mg/L	S.S. mg/L	S.S. LBS	B.O.D. mg/L	B.O.D. LBS	FOG mg/L	NH3	FECAL COLIFORM /100 ml	Cl <sup>-</sup> RESIDUAL mg/L	Cl <sup>-</sup> USED GAL	Na2SO3 USED LBS
SUN	27	0.070	0.000	14.1	7.6	7.7						10.4	6.7	4.4								0.01	2.00	3.41
MON	28	0.066	0.000	8.4	7.5	8.6						9.2	6.7	4.4								0.02	5.00	4.34
TUE	29	0.060	0.000	8.4	7.6	8.1						11.3	6.9	5.1								0.14	6.50	4.85
WED	30	0.056	0.000	9.5	7.6	8.1		119		23		9.9	6.9	4.7								0.09	3.00	5.88
THU	31	0.063	0.005	10.4	7.6	8.1						10.2	6.8	5.2								0.02	2.00	4.03
FRI	1	0.092	0.003	10.0	7.4	8.7																		1.86
SAT	2	0.078	0.000																					5.00
SUN	3	0.068	0.000																					4.03
MON	4	0.065	0.003	9.8	7.6	7.3						11.1	6.8	4.3							2	0.01	7.50	4.85
TUE	5	0.073	0.003	9.5	7.1	7.1						10.7	6.9	4.8								0.01	3.00	4.03
WED	6	0.054	0.003	8.6	8.2	6.9						10.8	6.9	5.0								0.03	4.00	3.10
THU	7	0.073	0.003	9.4	7.5	8.0						11.5	6.9	4.6								0.02	1.00	5.27
FRI	8	0.063	0.005	9.8	7.6	8.2			29			11.0	6.9	5.2						8		0.02	3.00	3.41
SAT	9	0.078	0.000																					4.25
SUN	10	0.081	0.000																					3.00
MON	11	0.075	0.003	11.1	6.9	7.3						10.7	6.9	4.6										6.20
TUE	12	0.071	0.003	9.4	7.4	7.8						10.6	6.9	4.5										7.44
WED	13	0.058	0.003	10.3	7.4	7.6						10.8	6.8	5.2										6.20
THU	14	0.085	0.003	9.0	7.4	7.3						11.2	6.8	5.3										4.96
FRI	15	0.091	0.002	7.1	7.2	9.4						10.1	7.0	5.4										4.85
SAT	16	0.069	0.000																					6.20
SUN	17	0.066	0.000																					8.68
MON	18	0.073	0.003	8.3	7.6	7.5						10.7	6.9	4.5										3.50
TUE	19	0.074	0.003	9.7	7.5	8.3						10.6	6.9	4.5										6.82
WED	20	0.065	0.000	9.9	7.4	7.9						10.4	6.9	4.3										4.00
THU	21	0.064	0.003	10.2	7.5	7.5						10.8	6.8	4.2										7.13
FRI	22	0.066	0.002	9.5	7.6	8.2						10.8	6.9	4.3										6.20
SAT	23	0.065	0.000																					8.68
TOTAL		1.961	0.048																					92.25
MAXIMUM		0.092	0.005	14.1	8.2	9.4		119		23		11.5	7.0	5.4										8.68
MINIMUM		0.054	0.000	7.1	6.9	6.9		119		29		9.2	6.7	4.2										1.86
AVERAGE		0.070	0.002	9.7	7.4	7.9		119		29		10.7	6.9	4.7										5.15
NO OF ANALYSIS		28	28	28	20	20		1		1		20	20	20										27

% REMOVAL	
B.O.D.	98
S.S.	96

WEEK	BOD			TSS			CHLORINE			COLIFORM	
	mg/L	lbs	lbs	mg/L	lbs	lbs	mg/L	Gal	Gal	Geop. Mean	
1	6	3	4	8	8	4	0.0560	3.9			
2							0.0180	4.0		2	
3							0.0200	3.1			
4							0.0320	2.8			
MAX	6	3	4	8	8	4	0.0560	4		2	

\*GEOMETRIC MEAN WAS USED TO CALCULATE THE AVERAGE FECAL COLIFORM COLONIES

COMMENTS:

# Alaska Department of Environmental Conservation Monthly Discharge Monitoring Report (DMR)

CONTACT NAME: Denny Kay  
 MAILING ADDRESS: 2009 Radcliffe  
 Juneau, AK 99801

FACILITY: Auke Bay WWTF  
 LOCATION: 11825 GLACIER HWY  
 Juneau, AK 99801

PERMIT NUMBER: AKG572004

MONITORING PERIOD: 1/27/2013

TO 2/23/2013

OUTFALL / MONITORING POINT: MXZ1 Mixing Zone for Outfall 001

NO DISCHARGE:

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
Dissolved Oxygen 3 - Outside edge of MZ 00300	Sample meas.	*****	*****			*****					
	Permit reqmt.	*****	*****		6 daily minimum	*****	17 daily maximum	mg/l		Upon Request	Grab
pH 3 - Outside edge of MZ 00400	Sample meas.	*****	*****			*****					
	Permit reqmt.	*****	*****		6.5 daily minimum	*****	8.5 daily maximum	S.U.		Upon Request	Grab
Total Residual Chlorine 3 - Outside edge of MZ 50060	Sample meas.	*****	*****		*****						
	Permit reqmt.	*****	*****		*****	0.0075 monthly average	0.013 daily maximum	mg/l		2X Annually	Grab
Enterococci 4 - Shoreline in MZ 61211	Sample meas.	*****	*****		*****	*****					
	Permit reqmt.	*****	*****		*****	*****	Report daily maximum	cts/100 ml		See Permit Requirements	Grab
Fecal Coliform 3 - Outside edge of MZ 74055	Sample meas.	*****	*****		*****						
	Permit reqmt.	*****	*****		*****	14 monthly geometric mean	43 daily maximum	cts/100 ml		2X Annually	Grab
Fecal Coliform 4 - Shoreline in MZ 74055	Sample meas.	*****	*****		*****						
	Permit reqmt.	*****	*****		*****	200 monthly geometric mean	400 daily maximum	cts/100 ml		2X Annually	Grab

**COMMENTS:**

For Enterococci Bacteria monitoring requirements see Section 2.4 of the permit

Mail this report when completed to ADEC, Division of Water, 555 Cordova Street, Anchorage, AK 99501-2617  
 Attach an explanation of any violations. Reference all attachments below.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
<i>Nathan D. McCombs</i> WWT Supervisor	<i>Nathan D. McCombs</i>	586-0393	3-12-13
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA   NUMBER	Y   M   D

# Alaska Department of Environmental Conservation Monthly Discharge Monitoring Report (DMR)

CONTACT NAME: Nathan McCombs  
 MAILING ADDRESS: 2009 Radcliffe  
 Juneau, AK 99801

FACILITY: Auke Bay WWTF  
 LOCATION: 11825 GLACIER HWY  
 Juneau, AK 99801

PERMIT NUMBER: AKG572004

MONITORING PERIOD: 1/27/2013

TO 2/23/2013

OUTFALL / MONITORING POINT: 001A Discharge into Auke Bay

NO DISCHARGE:

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
Dissolved Oxygen 1 - Final Effluent 00300	Sample meas.	*****	*****		4.15	*****	*****				
	Permit reqmt.	*****	*****		2.0 daily minimum	*****	*****	mg/l		Monthly	Grab
Biochemical Oxygen Demand (BOD5) 1 - Final Effluent 00310	Sample meas.	3	3		*****	6	6				
	Permit reqmt.	40 monthly average	80 daily maximum	lbs/day	*****	30 monthly average	60 daily maximum	mg/l		Monthly	Grab-Composite
Biochemical Oxygen Demand (BOD5) G - Influent 00310	Sample meas.	*****	*****		*****	6	*****				
	Permit reqmt.	*****	*****		*****	Report monthly average	*****	mg/l		Monthly	Grab-Composite
Biochemical Oxygen Demand (BOD5) W - See Comments 00310	Sample meas.	3	*****		*****	6	*****				
	Permit reqmt.	60 weekly average	*****	lbs/day	*****	45 weekly average	*****	mg/l		Monthly	Grab-Composite
pH 1 - Final Effluent 00400	Sample meas.	*****	*****		6.7	*****	7.0				
	Permit reqmt.	*****	*****		6.0 daily minimum	*****	9.0 daily maximum	S.U.		3X Weekly	Grab
Total Suspended Solids 1 - Final Effluent 00530	Sample meas.	4	4		*****	8	8				
	Permit reqmt.	40 monthly average	80 daily maximum	lbs/day	*****	30 monthly average	60 daily maximum	mg/l		Monthly	Grab-Composite
Total Suspended Solids G - Influent 00530	Sample meas.	*****	*****		*****	189	*****				
	Permit reqmt.	*****	*****		*****	Report monthly average	*****	mg/l		Monthly	Grab-Composite
Total Suspended Solids W - See Comments 00530	Sample meas.	4	*****		*****	8	*****				
	Permit reqmt.	60 weekly average	*****	lbs/day	*****	45 weekly average	*****	mg/l		Monthly	Grab-Composite
Flow 1 - Final Effluent 50050	Sample meas.	0.070	0.092		*****	*****	*****				
	Permit reqmt.	Report monthly average	0.16 daily maximum	MGD	*****	*****	*****			5X Weekly	Measured
Total Residual Chlorine 1 - Final Effluent 50060	Sample meas.	*****	*****		*****	0.03	0.14				
	Permit reqmt.	*****	*****		*****	0.5 monthly average	1.0 daily maximum	mg/l		3X Weekly	Grab
Enterococci 1 - Final Effluent 61211	Sample meas.	*****	*****		*****	*****					
	Permit reqmt.	*****	*****		*****	Report daily maximum	*****	cts/100 ml		See Permit Requirements	Grab
Fecal Coliform 1 - Final Effluent 74055	Sample meas.	*****	*****		*****	2	2				
	Permit reqmt.	*****	*****		*****	200 monthly geometric mean	800 daily maximum	cts/100 ml		Monthly	Grab
BOD5 Minimum % Removal K - Percent Removal 81010	Sample meas.	*****	*****		98	*****	*****				
	Permit reqmt.	*****	*****		85 minimum percent removal	*****	*****	%		Monthly	Calculation
Total Suspended Solids Minimum % Removal K - Percent Removal 81011	Sample meas.	*****	*****		96	*****	*****				
	Permit reqmt.	*****	*****		85 minimum percent removal	*****	*****	%		Monthly	Calculation

**COMMENTS:**

W = Average Weekly Effluent Limits;  
 For Enterococci Bacteria monitoring requirements see Section 2.4 of the permit

Mail this report when completed to ADEC, Division of Water, 555 Cordova Street, Anchorage, AK 99501-2617  
 Attach an explanation of any violations. Reference all attachments below.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
Nathan D. McCombs WWT Supervisor	<i>Nathan D. McCombs</i>	586-0393	3/2/13
TYPED OR PRINTED	OFFICER OR AUTHORIZED AGENT	AREA   NUMBER	Y   M   D