

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NO DISCHARGE

XX

PERMITTEE NAME/ADDRESS		JUNEAU, CITY AND BOROUGHO OF		AK-002321-3		REC 1		
NAME:		155 SOUTH SEWARD STREET		PERMIT NUMBER		DISCHARGE NUMBER		
ADDRESS:		JUNEAU, AK 99801		MONITORING PERIOD (calendar month)				
FACILITY:		JUNEAU-DOUGLAS TREATMENT PLANT		YR	MO	DAY	MO	
LOCATION:		JUNEAU, AK 99801		2000	12	01	2000	
				to				31
				MAJOR (SUBR.01)				

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
TEMPERATURE, WATER	*****	*****	*****	N/A	0	1/QTR	GRAB
DEG. CENTIGRADE	*****	*****	*****	REPORT		QTRLY	GRAB
00010 1 0 0	*****	*****	N/A	N/A	0	1/QTR	GRAB
EFFLUENT GROSS VALUE	*****	*****	REPORT	REPORT		QTRLY	GRAB
pH	*****	*****	*****	N/A	0	1/QTR	GRAB
00400 1 0 0	*****	*****	*****	REPORT		QTRLY	GRAB
EFFLUENT GROSS VALUE	*****	*****	*****	N/A	0	1/QTR	GRAB
SALINITY	*****	*****	*****	REPORT		QTRLY	GRAB
00480 1 0 0	*****	*****	*****	REPORT		QTRLY	GRAB
EFFLUENT GROSS VALUE	*****	*****	*****	N/A	0	1/QTR	GRAB
NITROGEN, AMMONIA	*****	*****	*****	REPORT		QTRLY	GRAB
TOTAL (AS N)	*****	*****	*****	REPORT		QTRLY	GRAB
00610 1 0 0	*****	*****	*****	REPORT		QTRLY	GRAB
EFFLUENT GROSS VALUE	*****	*****	*****	REPORT		QTRLY	GRAB
FECAL COLIFORM, MPN, EC MED, 44.5C	*****	*****	*****	REPORT		QTRLY	GRAB
31615 1 0 0	*****	*****	*****	REPORT		QTRLY	GRAB
SEE COMMENT BELOW	*****	*****	*****	REPORT		QTRLY	GRAB

NAME/TITLE PRINCIPAL EXEC. OFFICER	TELEPHONE	YEAR	MONTH	DAY
ANDREW BRONSON, Wastewater Util. Sup't.	(907) 789-9919	2001	01	09

COMMENT AND EXPLANATION OF ANY VIOLATIONS: None

AMBIENT SAMPLING FOR FECAL COLIFORM (SEASON 1 = MARCH - AUGUST AND SEASON 2 = SEPTEMBER - FEBRUARY) SHALL BE CONDUCTED JUST OUTSIDE THE MIXING ZONE.

Reporting the period: Dec. 03 through Dec. 30, 2000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NO DISCHARGE

PERMITTEE NAME/ADDRESS		AK-002321-3		001 A	
NAME:		PERMIT NUMBER		DISCHARGE NUMBER	
ADDRESS:		MONITORING PERIOD (calendar: month)			
JUNEAU, CITY AND BOROUGHS OF		YR	MO	YEAR	MO
155 SOUTH SEWARD STREET		2000	12	2000	12
JUNEAU, AK 99801		DAY	01	DAY	31
FACILITY:		MAJOR (SUBR 01)			
JUNEAU-DOUGLAS TREATMENT PLANT					
LOCATION:					
JUNEAU, AK 99801					

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE			
TU STAT 1HR CHR DEND RASTER EXCENTRICUS	*****	*****	N/A	*****	0		24 HR COMP
TKF3N 1 0 0	*****	*****	REPORT	*****		TOXIC UNITS	COMP24
EFFLUENT GROSS VALUE	*****	*****	N/A	*****	0		24 HR COMP
TU STAT 48HR CHR MYTIL US GALLOPROVINCIALIS	*****	*****	REPORT	*****		TOXIC UNITS	COMP24
TKG3P 1 0 0	*****	*****	*****	*****	0		GRAB
EFFLUENT GROSS VALUE	*****	*****	9.8	12.9	0	(04)	GRAB
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****	REPORT	REPORT			GRAB
00010 1 0 0	*****	*****	30DA AVG	DAILY			GRAB
EFFLUENT GROSS VALUE	*****	*****	69	*****	0	(19)	24 HR COMP
BOD, 5-DAY (20 DEG. C)	*****	*****	REPORT	*****		mg/L	COMP24
00310 G 0 0	*****	*****	MO AVG	*****			COMP24
RAW SEW / INFLUENT	*****	*****	2	2	0	(19)	24 HR COMP
BOD, 5-DAY (20 DEG. C)	*****	*****	30	45		mg/L	COMP24
00310 1 0 0	*****	*****	MO AVG	WKLY AVG			GRAB
EFFLUENT GROSS VALUE	*****	*****	6.4	6.9	0	(12)	GRAB
pH	*****	*****	MINIMUM	MAXIMUM			GRAB
00400 1 0 0	*****	*****	*****	8.5		SU	GRAB
EFFLUENT GROSS VALUE	*****	*****	262	*****	0	(19)	24 HR COMP
SOLIDS, TOTAL SUSPENDED	*****	*****	REPORT	*****			COMP24
00530 G 0 0	*****	*****	MO AVG	*****			COMP24
RAW SEW / INFLUENT	*****	*****	REPORT	*****			COMP24

"I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS."

NAME/TITLE PRINCIPAL EXEC. OFFICER	TELEPHONE	YEAR	MONTH	DAY
ANDREW BRONSON, Wastewater Util. Sup't.	(907) 789-9919	2001	01	09

COMMENT AND EXPLANATION OF ANY VIOLATIONS: None

Reporting the period: Dec. 03 through Dec. 30, 2000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NO DISCHARGE

PERMITTEE NAME/ADDRESS		AK-002321-3		001 A	
NAME:		PERMIT NUMBER		DISCHARGE NUMBER	
ADDRESS:		MONITORING PERIOD (calendar month)			
FACILITY:		YEAR	MONTH	YEAR	MONTH
LOCATION:		2000	12	2000	12
		DAY		DAY	
		2001		31	
		MAJOR (SUBR 01)			

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	MIN.	AVERAGE			
SOLIDS, TOTAL SUSPENDED	75	136	*****	6	7	(19)	24 HR COMP
00530 1 0 0	690	1035	*****	30	45	mg/L	COMP24
EFFLUENT GROSS VALUE	*****	*****	*****	*****	N/A	(19)	GRAB
NITROGEN, AMMONIA TOTAL (AS N)	*****	*****	*****	*****	REPORT INST MAX		GRAB
00610 1 0 0	*****	*****	*****	N/A	N/A	(28)	GRAB
EFFLUENT GROSS VALUE	*****	*****	*****	1.4	3.8	ug/L	COMP24
ARSENIC, TOTAL RECOVERABLE	*****	*****	*****	N/A	N/A	(28)	COMP24
00978 1 0 0	*****	*****	*****	MO AVG	WKLY AVG	ug/L	COMP24
EFFLUENT GROSS VALUE	*****	*****	*****	N/A	N/A	(28)	COMP24
COPPER	*****	*****	*****	18.5	26.7		COMP24
TOTAL RECOVERABLE	*****	*****	*****	MO AVG	WKLY AVG	ug/L	COMP24
01119 1 0 0	*****	*****	*****	2	2	(13)	GRAB
EFFLUENT GROSS VALUE	*****	*****	*****	400	800	#/	GRAB
FECAL COLIFORM, MPN, EC MED, 44.5C	*****	*****	*****	30DA GEO	7 DA GEO	100mL	GRAB
31615 1 0 0	*****	*****	*****	*****	*****		RCORDR
EFFLUENT GROSS VALUE	1.373	*****	*****	*****	*****		RCORDR
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	REPORT	*****	*****	*****	*****		RCORDR
50050 1 0 0	MO AVG	*****	*****	NOTE	NOTE	(28)	
EFFLUENT GROSS VALUE	*****	*****	*****	MO AVG	WKLY AVG	ug/L	
CHLORINE, TOTAL RESIDUAL	*****	*****	*****	*****	*****		
50060 1 0 1	ADMIN	*****	*****	*****	*****		
EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****		

NAME/TITLE PRINCIPAL EXEC. OFFICER: Andrew W. Bronson

TELEPHONE: (907) 789-9919

YEAR: 2001 MONTH: 01 DAY: 09

COMMENT AND EXPLANATION OF ANY VIOLATIONS: None

Reporting the period: Dec. 03 through Dec. 30, 2000

NOTE = Chlorine no longer used to disinfect the plant effluent. PG 2 OF 3

