

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUB 01)
F - FINAL
EFFLUENT
... NO DISCHARGE
NOTE: Read Instructions before completing this form.

Form Approved.
OMB No. 2040-0004
Approval Expires 05-31-98

PERMITTEE NAME/ADDRESS (Include Facility name/Location if different)

NAME: JUNEAU, CITY AND BOROUGH OF
ADDRESS: MENDENHALL TREATMENT PLANT
155 SOUTH SEWARD,
JUNEAU ALASKA 99801
FACILITY: MENDENHALL VALLEY SERVICE AREA
LOCATION: JUNEAU, ALASKA 99801
ATT: ANDREW BRONSON, WWTP SUPT.

(2-16)
AK0022951
PERMIT NUMBER

(17-19)
001 A
DISCHARGE NUMBER

MONITORING PERIOD			
YR	MO	DAY	TO
2000	05	01	
			YEAR 2000
			MO 05
			DAY 31

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

PARAMETER (32-37)	(3 Card Only) (46-53)			QUANTITY OF LOADING (54-61)			QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-69)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG, CENTIGRADE	*****	*****	*****	13.9	14.8	(04)	*****	*****	*****	0	5/7	GRAB
00010 1.0 0 EFFLUENT GROSS VALUE	*****	*****	*****	REPORT MO AVG	REPORT WKLY AVG	DEG. C	*****	*****	*****	0	2/7	COMP
BOD, 5-DAY (20 DEG. C)	4589	*****	(26)	269	*****	(19)	*****	*****	*****	0	2/7	COMP
00310 G.0.0 RAW SEW/INFLEUNT	REPORT 30 DAY AVG	*****	LBS/DAY	REPORT MO AVG	*****	MG/L	*****	*****	*****	0	WEEKLY COMP 24	COMP
BOD, 5-DAY (20 DEG. C)	111	*****	(26)	6	*****	(19)	*****	*****	*****	0	2/7	COMP
00310 1.0 0 EFFLUENT GROSS VALUE	690 30 DAY AVG	1035 WKLY AVG	LBS/DAY	30 MO AVG	45 WKLY AVG	MG/L	*****	*****	*****	0	WEEKLY COMP 24	COMP
pH	*****	*****	*****	6.2	7.1	(12)	*****	*****	*****	0	5/7	GRAB
00400 1.0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	9.0 MAXIMUM	SU	*****	*****	*****	0	WEEK - GRAB DAYS	COMP
SOLIDS, TOTAL SUSPENDED	4344	*****	(26)	254	270	(19)	*****	*****	*****	0	1/7	COMP
00530 G.0.0 RAW SEW/INFLEUNT	REPORT 30 DAY AVG	*****	LBS/DAY	REPORT 30 DAY AVG	*****	MG/L	*****	*****	*****	0	WEEKLY COMP 24	COMP
SOLIDS, TOTAL SUSPENDED	178	216	(26)	10	13	(19)	*****	*****	*****	0	1/7	COMP
00530 1.0 0 EFFLUENT GROSS VALUE	690 30 DAY AVG	1035 WKLY AVG	LBS/DAY	30 30 DAY AVG	45 WKLY AVG	MG/L	*****	*****	*****	0	WEEKLY COMP 24	COMP
NITROGEN, AMMONIA TOTAL (AS N)	*****	*****	*****	*****	9.0	(19)	*****	*****	*****	0	1/ month	GRAB
00610 1.0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	REPORT MO MAX	MG/L	*****	*****	*****	0	ONCE/GRAB MONTH	GRAB
I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. & 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)												
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER										DATE		08
ANDREW BRONSON										789-9919		2000
Wastewater Utility Superintendent										AREA CODE		MO
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT										PHONE NUMBER		DAY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)										YEAR		DAY
*CONCERNING VIOLATION- PLEASE SEE ATTACHED.												

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED).
EPA Form 3320-1 (08-95) Pr. Previous editions may be used. 00434/981209 1904
PAGE 1 OF 2

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUB 01) Form Approved.
OMB No. 2040-0004
F - FINAL Approval Expires 05-31-98
EFFLUENT ***
*** NO DISCHARGE

PERMITTEE NAME/ADDRESS (Include Facility name/Location if different)

NAME: JUNEAU, CITY AND BOROUGH OF
ADDRESS: MENDENHALL TREATMENT PLANT
155 SOUTH SEWARD,
JUNEAU, ALASKA 99801
FACILITY: MENDENHALL VALLEY SERVICE AREA
LOCATION: JUNEAU, ALASKA 99801
ATT: ANDREW BRONSON, WWTP SUPT.

(2-16) AK0022951
PERMIT NUMBER

(17-19) 001 A
DISCHARGE NUMBER

MONITORING PERIOD			
YR	MO	DAY	TO
2000	05	01	2000 05 31

PARAMETER (82-37)	(3 Card Only) (46-53)			(24-25) (54-61)			FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	AVERAGE	MAXIMUM	UNITS		
COLIFORM, FECAL MF, M-FC BROTH, 44.5C 31616 1 0 0	*****	*****	*****	4	7	(13) #/	0	TWICE/GRAB WEEK
EFFLUENT GROSS VALUE	*****	*****	*****	200 MO GEO	400 WKLY GEO	100 ML		
FLOW IN CONDUIT OR THRU TREATMENT PLANT	2.0486	*****	(3)	*****	*****	*****	0	7/7 CONT
50050 1 0 0	REPORT MO AVG	*****	MGD	*****	*****	*****		CONTINUOUSLY RECORDED
CHLORINE TOTAL RESIDUAL	*****	*****	*****	0.0000	*****	(19)	0	5/7 CONT
50060 100	*****	*****	*****	0.002 MO AVG	*****	MGL		WEEK-GRAB DAYS
EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	(23)	0	1/ month ONCE/CAC/DT MONTH
BOD, 5-DAY PERCENT REMOVAL	*****	*****	*****	*****	*****	PERCENT	0	1/ month ONCE/CAC/DT MONTH
81010 K 0 0	*****	*****	*****	*****	*****	PERCENT	0	1/ month ONCE/CAC/DT MONTH
PERCENT REMOVAL	*****	*****	*****	*****	*****	PERCENT	0	GRAB
SOLIDS, SUSPENDED PERCENT REMOVAL	*****	*****	*****	*****	*****	PERCENT	0	ONCE/CAC/DT MONTH
81011 K 0 0	*****	*****	*****	*****	*****	PERCENT		
PERCENT REMOVAL	*****	*****	*****	*****	*****	PERCENT		

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. & 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

NAME/TITLE: PRINCIPAL EXECUTIVE OFFICER
SIGNATURE: Andrew W. Bronson
Wastewater Utility Superintendent
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT (REFERENCE ALL ATTACHMENTS HERE)

TELEPHONE: 789-9919
PHONE NUMBER

AREA CODE: (907)
PHONE NUMBER

YEAR: 2000
YEAR

MO: 06
MO

DAY: 08
DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS
*THE EFFLUENTS CL₂ RESIDUAL WAS BELOW OUR EFFLUENT ANALYZERS DETECTABLE LEVEL.
*THE RECORDED AVERAGE CL₂ RESIDUAL WAS CALCULATED FROM GRAB SAMPLES COLLECTED 2/DAY 5 DAYS/WEEK. A 0.0400 mg/L CALIBRATION STANDARD WAS USED.
*PA Form 3320-1 (08-95) Pr. Previous editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)