

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved.  
OMB No. 2040-0004  
Approval Expires 05-31-98

MAJOR  
(SUB 01)  
F - FINAL  
EFFLUENT

\*\*\* NO DISCHARGE  
NOTE: Read Instructions before completing this form.

(2-16) **AK0022951**  
PERMIT NUMBER

(17-19) **001 A**  
DISCHARGE NUMBER

NAME: JUNEAU, CITY AND BOROUGH OF  
ADDRESS: MENDENHALL TREATMENT PLANT  
155 SOUTH SEWARD,  
JUNEAU, ALASKA 99801  
FACILITY: MENDENHALL VALLEY SERVICE AREA  
LOCATION: JUNEAU, ALASKA 99801  
ATT: ANDREW BRONSON, WWTP SUPT.

MONITORING PERIOD  
YR 2000 MO 09 DAY 01 TO YR 2000 MO 09 DAY 30

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

PARAMETER (32-37)	(3 Card Only) (46-53)		QUANTITY OF LOADING (54-61)		QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE	MAXIMUM	UNITS	UNITS				
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	15.8	16.6	(04)					
BOD, 5-DAY (20 DEG. C) 00310 G 0 0 RAW SEWINFLOW	4610	*****	*****	REPORT MO AVG	REPORT WKLY AVG	DEG. C		WEEK - GRAB DAYS	GRAB		
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	134	156	*****	6	7	(19)		WEEKLY COMP 24	COMP		
pH	6.4	*****	6.0 MIN.	*****	7.2	(12)		WEEK - GRAB DAYS	GRAB		
SOLIDS, TOTAL SUSPENDED 00530 G 0 0 RAW SEWINFLOW	4501	*****	*****	208	300	(19)		WEEKLY COMP 24	COMP		
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	287	477	*****	13	22	(19)		WEEKLY COMP 24	COMP		
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	30 30 DAY AVG	45 WKLY AVG	MG/L		WEEKLY COMP 24	GRAB		
I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 13 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		Andrew W. Bronson		TELEPHONE		789-9919		DATE		10 08	
ANDREW BRONSON		Wastewater Utility Superintendent		AREA CODE		907		YEAR		2000	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		PHONE NUMBER		899-9919		MO		DAY	
COMMENT AND EXPLANATION OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)		PHONE NUMBER		899-9919		MO		DAY	
*CONCERNING VIOLATION- PLEASE SEE ATTACHED.				PHONE NUMBER		899-9919		MO		DAY	

