

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUB 01)
F - FINAL
EFLUENT
*** NO DISCHARGE
NOTE: Read instructions before completing this form.

PERMITTEE NAME/ADDRESS (Include Facility name/Location if different)

NAME: JUNEAU, CITY AND BOROUGH OF
ADDRESS: MENDENHALL TREATMENT PLANT
155 SOUTH SEWARD,
JUNEAU, ALASKA 99801
FACILITY: MENDENHALL VALLEY SERVICE AREA
LOCATION: JUNEAU, ALASKA 99801
ATT: ANDREW BRONSON, WWTP SUPT.

(2-16)
AK0022951
PERMIT NUMBER

(17-19)
001 A
DISCHARGE NUMBER

MONITORING PERIOD
YR 2001 MO 01 DAY 01 TO YR 2001 MO 01 DAY 31
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

PARAMETER (32-37)	(3 Card Only) (46-53)		QUANTITY OF LOADING (54-61)		QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE WATER	*****	*****	*****	*****	11.5	13.0	(04)		5/7	GRAB
00010 1.0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	REPORT MO.AVG	REPORT WKLY.AVG	DEG. C		WEEK - GRAB DAYS	GRAB
BOD, 5-DAY (20 DEG. C) RAW SEWINFLOW	3141	*****	(26)	*****	180	*****	(19)	0	2/7	COMP
00310 G 0.0	REPORT 30 DAY AVG	*****	LBS/DAY	*****	REPORT MO.AVG	*****	MGL		WEEKLY COMP 24	COMP
BOD, 5-DAY (20 DEG. C) EFFLUENT GROSS VALUE	120.8	226.9	(26)	*****	6.9	13.0	(19)		2/7	COMP
00310 1.0	680	1035	LBS/DAY	*****	30 MO.AVG	45 WKLY.AVG	MGL		WEEKLY COMP 24	COMP
pH	*****	*****	*****	*****	5.7	7.2	(12)	0	5/7	GRAB
00400 1.0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	6.0 MIN.	3.0 MAXIMUM	SU		WEEK - GRAB DAYS	COMP
SOLIDS, TOTAL SUSPENDED	2792	*****	(26)	*****	160	200	(19)	0	1/7	COMP
00530 G 0.0	REPORT 30 DAY AVG	*****	LBS/DAY	*****	REPORT 30 DAY AVG	45 WKLY.AVG	MGL		WEEKLY COMP 24	COMP
RAW SEWINFLOW	118.7	296.7	(26)	*****	6.8	17.0	(19)	0	1/7	COMP
SOLIDS, TOTAL SUSPENDED	680	1035	LBS/DAY	*****	30 MO.AVG	45 WKLY.AVG	MGL		WEEKLY COMP 24	COMP
00530 1.0	*****	*****	*****	*****	*****	11.0	(19)		1/ month	GRAB
NITROGEN, AMMONIA TOTAL (AS N)	*****	*****	*****	*****	*****	*****	MGL		ONCE/GRAB MONTH	GRAB
00810 1.0	*****	*****	*****	*****	*****	*****	MGL			
EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	MGL			

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
ANDREW BRONSON
Wastewater Utility Superintendent
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT (REFERENCE ALL ATTACHMENTS HERE)
Andrew W. Bronson

TELEPHONE 907 789-9919
AREA CODE 789-9919
PHONE NUMBER 789-9919
DATE 2001 02 08
YEAR 2001
MO 02
DAY 08

COMMENT AND EXPLANATION OF ANY VIOLATIONS *CONCERNING VIOLATION - PLEASE SEE ATTACHED.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUB 01) Form Approved.
OMB No. 2040-0004
F - FINAL Approval Expires 05-31-88
EFFLUENT ***
NO DISCHARGE
NOTE: Read instructions before completing this form.

PERMITTEE NAME/ADDRESS (include Facility name/Location if different)

NAME: JUNEAU, CITY AND BOROUGH OF
ADDRESS: MENDENHALL TREATMENT PLANT
155 SOUTH SEWARD,
JUNEAU, ALASKA 99801
FACILITY: MENDENHALL VALLEY SERVICE AREA
LOCATION: JUNEAU, ALASKA 99801
ATT: ANDREW BRONSON, WWTP SUPT.

(2-16) AK0022951
PERMIT NUMBER

(17-19) 001 A
DISCHARGE NUMBER

MONITORING PERIOD		YEAR		MO		DAY	
YR	MO	DAY	YR	MO	DAY	YR	MO
2001	01	01	2001	01	31		

PARAMETER (32-37)	(3 Card Only) (46-53)		(54-61)		(22-23) (46-53)			(24-25) (24-25)		(26-27) (62-63)		(28-29) (64-68)		(30-31) (69-70)	
	AVERAGE	MAXIMUM	UNITS	QUANTITY OF LOADING	MINIMUM (38-45)	AVERAGE	MAXIMUM	UNITS	NO. EX.	FREQUENCY OF ANALYSIS	NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	NO. EX.	FREQUENCY OF ANALYSIS
COLIFORM, FECAL MF, M-FC BROTH, 44.5C	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
FLOW IN CONDUIT OR THRU TREATMENT PLANT	2.0926	*****	(9)	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
50050 100 EFFLUENT GROSS VALUE	REPORT MO AVG	*****	MGD	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
CHLORINE TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
50080 100 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
BOD, 5-DAY PERCENT REMOVAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
81010 K O O PERCENT REMOVAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
SOLIDS, SUSPENDED PERCENT REMOVAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
81011 K O O PERCENT REMOVAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 49 U.S.C. 1001 AND 33 U.S.C. & 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

NAME/TITLE: PRINCIPAL EXECUTIVE OFFICER
Andrew W. Bronson
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT (REFERENCE ALL ATTACHMENTS HERE)

Wastewater Utility Superintendent
TYPED OR PRINTED NAME AND EXPLANATION OF ANY VIOLATIONS

* THE EFFLUENTS CL₂ RESIDUAL WAS BELOW OUR EFFLUENT ANALYZERS DETECTABLE LEVEL.
* THE RECORDED AVERAGE CL₂ RESIDUAL WAS CALCULATED FROM GRAB SAMPLES COLLECTED 2/DAY 5 DAYS/ WEEK. A 0.0400 mg/L CALIBRATION STANDARD WAS USED.
EPA Form 3320-1 (08-95) Prev. Editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)