

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUB 01)
F - FINAL
EFFLUENT
*** NO DISCHARGE

Form Approved.
OMB No. 2040-0004
Approval Expires 05-31-98

NOTE: Read instructions before completing this form.

(2-16)

PERMITTEE NAME/ADDRESS (include Facility name/Location if different)

NAME: JUNEAU, CITY AND BOROUGH OF
ADDRESS: MENDENHALL TREATMENT PLANT
155 SOUTH SEWARD,
JUNEAU, ALASKA 99801
FACILITY: MENDENHALL VALLEY SERVICE AREA
LOCATION: JUNEAU, ALASKA 99801
ATT: ANDREW BRONSON, WWTP SUPT.

AK0022951
PERMIT NUMBER

(17-19)

DISCHARGE NUMBER
001 A

MONITORING PERIOD
YR. MO DAY YEAR
2001 02 01 2001
FROM TO

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

PARAMETER (32-37)	(3 Card Only) (46-53)		(54-61)		(54-61)		NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER 00010.1 0.0 EFFLUENT GROSS VALUE	*****	*****	*****	10.7	11.3	(04)	0	5/7	GRAB
BOD, 5-DAY (20 DEG. C) 00310.1 0.0 RAW SEW/INFLUENT	3059	*****	*****	182	*****	(19)	0	WEEK GRAB DAYS	COMP
BOD, 5-DAY (20 DEG. C) 00310.1 0.0 EFFLUENT GROSS VALUE	115.6	128.0	*****	6.9	7.6	(19)	0	WEEKLY COMP 24	COMP
pH	6.0	1035	6.4	30	45	(12)	0	WEEKLY COMP 24	GRAB
00400.1 0.0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	6.9	(19)	0	WEEK GRAB DAYS	COMP
SOLIDS, TOTAL SUSPENDED 00530.0 0.0 RAW SEW/INFLUENT	3228	*****	*****	192	*****	(19)	0	1/7	COMP
SOLIDS, TOTAL SUSPENDED 00530.1 0.0 EFFLUENT GROSS VALUE	145.7	168.4	*****	8.7	10.0	(19)	0	WEEKLY COMP 24	COMP
NITROGEN, AMMONIA TOTAL (AS N) 00610.1 0.0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	16.0	(19)	0	1/ month	GRAB

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 A.S.C. 1001 AND 33 U.S.C. § 1319.
(Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Andrew W. Bronson
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
(REFERENCE ALL ATTACHMENTS HERE)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
ANDREW BRONSON
Wastewater Utility Superintendent
TYPED OR PRINTED
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
(REFERENCE ALL ATTACHMENTS HERE)

TELEPHONE: 907 789-9919
AREA CODE: 907
PHONE NUMBER: 789-9919
YEAR: 2001
DATE: 03 08
DAY: DAY

*CONCERNING VIOLATION- PLEASE SEE ATTACHED.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved.
OMB No. 2040-0004
Approval Expires 05-31-98

MAJOR
(SUB 01)
F - FINAL
EFFLUENT
*** NO DISCHARGE

NOTE: Read instructions before completing this form.

PERMITTEE NAME/ADDRESS(Include Facility name/Location if different)

NAME: JUNEAU, CITY AND BOROUGH OF
ADDRESS: MENDEHALL TREATMENT PLANT
155 SOUTH SEWARD,
JUNEAU, ALASKA 99801
FACILITY: MENDEHALL VALLEY SERVICE AREA
LOCATION: JUNEAU, ALASKA 99801
ATT: ANDREW BRONSON, VMWP SUPT.

AK0022951
PERMIT NUMBER

001 A
DISCHARGE NUMBER

MONITORING PERIOD			
YR	MO	DAY	TO
2001	02	01	28
YEAR	MO	DAY	DAY
2001	02	01	28

PARAMETER (32-37)	(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MAXIMUM	AVERAGE	UNITS	MINIMUM	MAXIMUM	UNITS			
SAMPLE MEASUREMENT PERMIT REQUIREMENT COLIFORM, FECAL MF, M-FC BROTH, 44.5C 31616 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	15	6	(13)	0	2/7	GRAB
SAMPLE MEASUREMENT PERMIT REQUIREMENT FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	400 WKLY GEO	200 MO GEO	#/100ML	0	TWICE/GRAB WEEK	GRAB
SAMPLE MEASUREMENT PERMIT REQUIREMENT CHLORINE TOTAL 50060 100 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	*****	*****	*****	*****	0	7/7	CONT
SAMPLE MEASUREMENT PERMIT REQUIREMENT BOD, 5-DAY PERCENT REMOVAL 81010 K 0 0 PERCENT REMOVAL	*****	*****	*****	*****	*****	*****	*****	0.04 MO AVG.	(19)	0	CONTINUOUSLY RECORDED	CONT
SAMPLE MEASUREMENT PERMIT REQUIREMENT SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENT REMOVAL	*****	*****	*****	*****	*****	*****	*****	*****	(23)	0	CONTINUOUSLY RECORDED	COMP
SAMPLE MEASUREMENT PERMIT REQUIREMENT SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENT REMOVAL	*****	*****	*****	*****	*****	*****	*****	*****	PERCENT	0	ONCE/CACTD MONTH	GRAB
SAMPLE MEASUREMENT PERMIT REQUIREMENT SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENT REMOVAL	*****	*****	*****	*****	*****	*****	*****	*****	PERCENT	0	ONCE/CACTD MONTH	GRAB

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN. AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 A.S.C. 1001 AND 33 U.S.C. 1319g.
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
ANDREW BRONSON
Signature: Andrew W. Bronson

Wastewater Utility Superintendent
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
(REFERENCE ALL ATTACHMENTS HERE)

COMMENT AND EXPLANATION OF ANY VIOLATIONS
*THE EFFLUENTS CL2 RESIDUAL WAS BELOW OUR EFFLUENT ANALYZERS DETECTABLE LEVEL.
* THE RECORDED AVERAGE CL2 RESIDUAL WAS CALCULATED FROM GRAB SAMPLES COLLECTED 2/DAY 5 DAYS/WEEK. A 0.0400 mg/L CALIBRATION STANDARD WAS USED.

EPA Form 3320-1 (08-95) Previ Previous editions may be used. (REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)
00434/981209 1904
PAGE 2 OF 2