

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUB 01)
F - FINAL
EFFLUENT
*** NO DISCHARGE
NOTE: Read instructions before completing this form.

Form Approved
OMB No. 2040-0004
Approval Expires 05 31 98

PERMITTEE NAME/ADDRESS (include Facility name/Location if different)

NAME: JUNEAU, CITY AND BOROUGH OF
ADDRESS: MENDENHALL TREATMENT PLANT
155 SOUTH SEWARD,
JUNEAU, ALASKA 99801
FACILITY: MENDENHALL VALLEY SERVICE AREA
LOCATION: JUNEAU, ALASKA 99801
ATT: SCOTT JEFFERS, WW UTILITIES SUPT

AK0022951
PERMIT NUMBER

001 A
DISCHARGE NUMBER

MONITORING PERIOD							
FROM	YR	MO	DAY	TO	YEAR	MO	DAY
	2003	6	01		2003	6	30

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	15.9	17.0	(04)	5/7	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT MO AVG	REPORT DAILY MAX	DEG. °C	WEEK DAYS	GRAB
BOD, 5-DAY (20 DEG. C) 00310 G 0 0	SAMPLE MEASUREMENT	3593	3785	(26)	*****	245	297	(19)	1/7	
RAW SEW/INFLUENT	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MAX	LBS/DAY	*****	REPORT MO AVG	REPORT DAILY MAX	MGL	WEEKLY	COMP 24
BOD, 5-DAY (20 DEG. C) 00310 W 0 0	SAMPLE MEASUREMENT	142.0	*****	(26)	*****	9.7	*****	(19)	1/7	
SEE COMMENTS BELOW	PERMIT REQUIREMENT	1839	*****	LBS/DAY	*****	45	*****	MGL	WEEKLY	COMP 24
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	142.0	156.9	(26)	*****	9.7	11.0	(19)	1/7	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	1226	2452	LBS/DAY	*****	30	60	MGL	WEEKLY	COMP 24
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.5	*****	7.2	(12)	5/7	
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	6.5	*****	8.5	SU	WEEK DAYS	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	158.0	158.0	(19)	1/ month	
ALKALINITY AS CaCO3 00425 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT MO AVG	REPORT DAILY MAX	MGL	ONCE/ MONTH	COMP 24
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	2904.0	3180.0	(26)	*****	197.5	205.0	(19)	1/7	
SOLIDS, TOTAL SUSPENDED 00530 G 0 0	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MAX	LBS/DAY	*****	REPORT MO AVG	REPORT DAILY MAX	MGL	WEEKLY	COMP 24
RAW SEW/INFLUENT	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*****	*****	*****	*****

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT, SEE 18 U.S.C. 1001 AND 43 U.S.C. & 1919. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
SCOTT JEFFERS
WW UTILITY SUPERINTENDENT
TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
(REFERENCE ALL ATTACHMENTS HERE)

TELEPHONE
907 560-0393
AREA CODE PHONE NUMBER

DATE
2003 7 3
YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS
*CONCERNING VIOLATION- PLEASE SEE ATTACHED.