

AUKE BAY WASTEWATER TREATMENT FACILITY- JUNEAU, ALASKA
 Juneau, Alaska **OCTOBER 2016**

FLOWS		INFLUENT											EFFLUENT										MISCELLANEOUS			
DAY	DATE	INFLUENT MGD	WASTE SLUDGE MGD	TEMP °C	pH	D.O. mg/L	S.S. mg/L	S.S. LBS	B.O.D. mg/L	B.O.D. LBS	FOG mg/L	NH3	TEMP °C	pH	D.O. mg/L	S.S. mg/L	S.S. LBS	B.O.D. mg/L	B.O.D. LBS	FOG mg/L	Enterococci /100 ml	FECAL COLIFORM /100 ml	Cl ₂ RESIDUAL mg/L	Cl ₂ USED GAL	Na ₂ SO ₃ USED LBS	
SAT	1	0.05298	0.00200																						3.00	2.17
SUN	2	0.04949	0.00200																						3.00	2.17
MON	3	0.05251	0.00250	15.1	7.40	4.9							15.4	7.2	3.9								0.09	2.00	2.17	
TUE	4	0.05487	0.00300	14.9	7.89	5.6	152.0	69.6	180.0	82.4			15.5	7.23	4.4	5.6	2.6	6.0	2.7		20	1	0.30	3.00	1.86	
WED	5	0.05293	0.00250	16.0	7.73	5.5	213.0	94.0	280.0	123.6			15.9	7.16	4.6	4.4	1.9	5.3	2.3				0.38	3.00	2.17	
THU	6	0.04269	0.00250	14.8	7.89	4.1							15.4	7.15	4.1								0.28	2.00	1.86	
FRI	7	0.04543	0.02000	15.2	7.73	5.2							15.5	7.04	3.9								0.34	3.00	2.17	
SAT	8	0.04627	0.00150																					2.00	2.17	
SUN	9	0.05172	0.00150																					3.00	1.86	
MON	10	0.04510	0.00300	14.4	7.86	5.5							15.2	7.20	3.8								0.37	2.00	2.48	
TUE	11	0.04769	0.00300	15.5	8.00	5.9	107.0	42.6	140.0	55.7			15.0	7.17	4.2	4.0	1.6	5.1	2.0			1	0.39	3.00	2.79	
WED	12	0.04643	0.00300	14.8	8.20	6.2	160.0	62.0	220.0	85.2			15.4	7.16	4.7	6.4	2.5	6.0	2.3				0.50	2.00	2.48	
THU	13	0.04518	0.00250	14.5	7.80	5.4							15.6	7.23	3.8								0.18	3.00	2.48	
FRI	14	0.04319	0.00250	14.8	7.86	5.7							15.4	7.25	4.2								0.12	2.00	2.48	
SAT	15	0.04437	0.00150																					2.00	2.48	
SUN	16	0.05910	0.00150																					2.00	3.10	
MON	17	0.07216	0.00300	13.9	7.63	6.1							15.0	7.20	4.5								0.02	2.00	3.41	
TUE	18	0.06872	0.00300	14.7	7.71	5.9	122.0	69.9	150.0	86.0			14.9	7.07	4.9	4.0	2.3	5.2	3.0		85	15	0.02	2.00	3.41	
WED	19	0.06087	0.00200	12.9	7.69	5.7	180.0	91.4	210.0	106.6			14.7	7.11	4.4	4.4	2.2	6.6	3.4				0.22	2.00	3.72	
THU	20	0.05942	0.00300	14.1	8.33	6.7							15.0	7.15	5.5								0.01	2.00	3.72	
FRI	21	0.05000	0.00250	13.3	7.77	6.7							14.4	7.07	4.1								0.01	2.00	3.41	
SAT	22	0.05449	0.00200																					2.00	3.14	
SUN	23	0.05611	0.00200																					2.00	3.10	
MON	24	0.05199	0.00300	14.2	7.84	5.7							14.7	7.14	3.8								0.18	2.00	3.72	
TUE	25	0.05329	0.00250	13.2	7.55	5.8	186.0	82.7	250.0	111.1			14.4	7.09	3.9	7.6	3.4	6.4	2.8			2	0.13	2.00	2.48	
WED	26	0.05397	0.00300	13.3	7.87	6.0	250.0	112.5	310.0	139.5			14.6	7.06	4.1	5.2	2.3	7.3	3.3				0.01	2.00	3.10	
THU	27	0.04846	0.00200	14.0	7.93	6.2							14.4	7.04	4.0								0.08	2.00	3.10	
FRI	28	0.05753	0.00150	13.7	7.68	6.3							14.9	7.05	4.7								0.28	2.00	2.79	
SAT	29	0.04615	0.00200																					2.00	2.27	
SUN	30	0.04590	0.00250																					3.00	3.79	
MON	31	0.05093	0.00250	13.4	7.80	5.8							15.4	7.00	4.3								0.21	2.00	2.48	
TOTAL		1.60993	0.09100																					71.00		
MAXIMUM		0.07216	0.02000	16.0	8.33	6.7	250.0	112.5	310.0	139.5			15.9	7.25	5.5	7.6	3.4	7.3	3.4		85	15.0	0.5	3.0	3.8	
MINIMUM		0.04269	0.00150	12.9	7.40	4.1	107.0	42.6	140.0	55.7			14.4	7.00	3.8	4.0	1.6	5.1	2.0		20	1.0	0.0	2.0	1.9	
AVERAGE		0.05193	0.00294	14.3		5.7	171.3	78.1	217.5	98.8			15.1		4.3	5.2	2.4	6.0	2.7		41	2.3	0.2	2.3	2.7	
NO. OF ANALYSIS		31	31	21	21	21	8	8	8	8	8	0	21	21	21	8	8	8	8	8	0	2	4	21	31	31

Oct 1-31 used to calculate monthly data only.
 Oct 2-Oct 29 used to calculate the weekly averages only.

WEEK	WEEKLY AVERAGE						WEEKLY COLIFORM
	BOD		TSS		CHLORINE		
	mg/l	lbs	mg/l	lbs	mg/l	Gal	Geo. Mean
1	5.7	2.5	5.0	2.3	0.28	2.6	1
2	5.6	2.2	5.2	2.0	0.31	2.4	1
3	5.9	3.2	4.2	2.3	0.06	2.0	15
4	6.9	3.1	6.4	2.9	0.14	2.0	2
MAX	6.9	3.2	6.4	2.9	0.31	2.6	15

% REMOVAL	
B.O.D.	97.2
S.S.	97.0

Alaska Department of Environmental Conservation Monthly Discharge Monitoring Report (DMR)

CONTACT NAME: Catherine Carlson
 MAILING ADDRESS: 2009 Radcliffe
 Juneau, AK 99801

FACILITY: Auke Bay WWTF
 LOCATION: 11825 GLACIER HWY
 Juneau, AK 99801

PERMIT NUMBER: AKG572004

MONITORING PERIOD: **10/1/2016**

TO **10/31/2016**

OUTFALL / MONITORING POINT: MXZ1 Mixing Zone for Outfall 001


NO DISCHARGE:

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
Dissolved Oxygen 3 - Outside edge of MZ 00300	Sample meas.	*****	*****		10.2	*****	10.2		0		
	Permit reqmt.	*****	*****		6 daily minimum	*****	17 daily maximum	mg/l		Upon Request	Grab
pH 3 - Outside edge of MZ 00400	Sample meas.	*****	*****		7.7	*****	7.7		0		
	Permit reqmt.	*****	*****		6.5 daily minimum	*****	8.5 daily maximum	S.U.		Upon Request	Grab
Total Residual Chlorine 3 - Outside edge of MZ 50060	Sample meas.	*****	*****		*****	0	0		0		
	Permit reqmt.	*****	*****		*****	0.0075 monthly average	0.013 daily maximum	mg/l		2X Annually	Grab
Enterococci 4 - Shoreline in MZ 61211	Sample meas.	*****	*****		*****	*****	20		0		
	Permit reqmt.	*****	*****		*****	*****	Report daily maximum	cts/100 ml		See Permit Requirements	Grab
Fecal Coliform 3 - Outside edge of MZ 74055	Sample meas.	*****	*****		*****	44	44		0		
	Permit reqmt.	*****	*****		*****	14 monthly geometric mean	43 daily maximum	cts/100 ml		2X Annually	Grab
Fecal Coliform 4 - Shoreline in MZ 74055	Sample meas.	*****	*****		*****	8	8		0		
	Permit reqmt.	*****	*****		*****	200 monthly geometric mean	400 daily maximum	cts/100 ml		2X Annually	Grab

COMMENTS:

For Enterococci Bacteria monitoring requirements see Section 2.4 of the permit

Mail this report when completed to ADEC, Division of Water, 555 Cordova Street, Anchorage, AK 99501-2617
 Attach an explanation of any violations. Reference all attachments below.

NAME/TITLE PRINCIPLE EXECUTIVE OFFICE	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
CATHERINE CARLSON/Wastewater Treatment Plant Operator			907 586-0393	16/11/09
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA/NUMBER	YY/MM/DD	

Alaska Department of Environmental Conservation Monthly Discharge Monitoring Report (DMR)

CONTACT NAME: Catherine Carlson
 MAILING ADDRESS: 2009 Radcliffe
 Juneau, AK 99801

FACILITY: Auke Bay WWTF
 LOCATION: 11825 GLACIER HWY
 Juneau, AK 99801

PERMIT NUMBER: AKG572004

MONITORING PERIOD: 10/1/2016

TO 10/31/2016

OUTFALL / MONITORING POINT: 001A Discharge into Auke Bay


NO DISCHARGE:

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
Dissolved Oxygen 1 - Final Effluent 00300	Sample meas.	*****	*****		3.8	*****	*****		0		
	Permit reqmt.	*****	*****		2.0 daily minimum	*****	*****	mg/l		Monthly	Grab
Biochemical Oxygen Demand (BOD5) 1 - Final Effluent 00310	Sample meas.	3	3		*****	6	7		0		
	Permit reqmt.	40 monthly average	80 daily maximum	lbs/day	*****	30 monthly average	60 daily maximum	mg/l		Monthly	Grab-Composite
Biochemical Oxygen Demand (BOD5) G - Influent 00310	Sample meas.	*****	*****		*****	218	*****		0		
	Permit reqmt.	*****	*****		*****	Report monthly average	*****	mg/l		Monthly	Grab-Composite
Biochemical Oxygen Demand (BOD5) W - See Comments 00310	Sample meas.	3	*****		*****	7	*****		0		
	Permit reqmt.	60 weekly average	*****	lbs/day	*****	45 weekly average	*****	mg/l		Monthly	Grab-Composite
pH 1 - Final Effluent 00400	Sample meas.	*****	*****		7.0	*****	7.3		0		
	Permit reqmt.	*****	*****		6.0 daily minimum	*****	9.0 daily maximum	S.U.		3X Weekly	Grab
Total Suspended Solids 1 - Final Effluent 00530	Sample meas.	2	3		*****	5	8		0		
	Permit reqmt.	40 monthly average	80 daily maximum	lbs/day	*****	30 monthly average	60 daily maximum	mg/l		Monthly	Grab-Composite
Total Suspended Solids G - Influent 00530	Sample meas.	*****	*****		*****	171	*****		0		
	Permit reqmt.	*****	*****		*****	Report monthly average	*****	mg/l		Monthly	Grab-Composite
Total Suspended Solids W - See Comments 00530	Sample meas.	3	*****		*****	6	*****		0		
	Permit reqmt.	60 weekly average	*****	lbs/day	*****	45 weekly average	*****	mg/l		Monthly	Grab-Composite
Flow 1 - Final Effluent 50050	Sample meas.	0.05	0.07		*****	*****	*****		0		
	Permit reqmt.	Report monthly average	0.16 daily maximum	MGD	*****	*****	*****			5X Weekly	Measured
Total Residual Chlorine 1 - Final Effluent 50060	Sample meas.	*****	*****		*****	0.2	0.5		0		
	Permit reqmt.	*****	*****		*****	0.5 monthly average	1.0 daily maximum	mg/l		3X Weekly	Grab
Enterococci 1 - Final Effluent 61211	Sample meas.	*****	*****		*****	*****	85		0		
	Permit reqmt.	*****	*****		*****	*****	Report daily maximum	cts/100 ml		See Permit Requirements	Grab
Fecal Coliform 1 - Final Effluent 74055	Sample meas.	*****	*****		*****	2	15		0		
	Permit reqmt.	*****	*****		*****	200 monthly geometric mean	800 daily maximum	cts/100 ml		Monthly	Grab
BOD5 Minimum % Removal K - Percent Removal 81010	Sample meas.	*****	*****		97	*****	*****		0		
	Permit reqmt.	*****	*****		85 minimum percent removal	*****	*****	%		Monthly	Calculation
Total Suspended Solids Minimum % Removal K - Percent Removal 81011	Sample meas.	*****	*****		97	*****	*****		0		
	Permit reqmt.	*****	*****		85 minimum percent removal	*****	*****	%		Monthly	Calculation

COMMENTS:

W = Average Weekly Effluent Limits;
 For Enterococci Bacteria monitoring requirements see Section 2.4 of the permit

Mail this report when completed to ADEC, Division of Water, 555 Cordova Street, Anchorage, AK 99501-2617
 Attach an explanation of any violations. Reference all attachments below.

NAME/TITLE PRINCIPLE EXECUTIVE OFFICE	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
CATHERINE CARLSON/Wastewater Treatment Plant Operator			907 586-0393	16/11/09
TYPED OR PRINTED			AREA/NUMBER	YY/MM/DD