

Alaska Department of Environmental Conservation Monthly Discharge Monitoring Report (DMR)

CONTACT NAME: Catherine Carlson
 MAILING ADDRESS: 2009 Radcliffe
 Juneau, AK 99801

FACILITY: Auke Bay WWTF
 LOCATION: 11825 GLACIER HWY
 Juneau, AK 99801

PERMIT NUMBER: AKG572004
 OUTFALL / MONITORING POINT: 001A Discharge into Auke Bay

MONITORING PERIOD: 2/1/2017 TO 2/28/2017
 NO DISCHARGE:

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
Dissolved Oxygen	Sample meas.	*****	*****		3.9	*****	*****		0		
	Permit reqmt.	*****	*****		2.0 daily minimum	*****	*****	mg/l		Monthly	Grab
Biochemical Oxygen Demand (BOD5)	Sample meas.	1	2		*****	4	7		0		
	Permit reqmt.	40 monthly average	80 daily maximum	lbs/day	*****	30 monthly average	60 daily maximum	mg/l		Monthly	Grab-Composite
Biochemical Oxygen Demand (BOD5)	Sample meas.	*****	*****		*****	225	*****		0		
	Permit reqmt.	*****	*****		*****	Report monthly average	*****	mg/l		Monthly	Grab-Composite
Biochemical Oxygen Demand (BOD5)	Sample meas.	2	*****		*****	5	*****		0		
	Permit reqmt.	60 weekly average	*****	lbs/day	*****	45 weekly average	*****	mg/l		Monthly	Grab-Composite
pH	Sample meas.	*****	*****		7.1	*****	7.4		0		
	Permit reqmt.	*****	*****		6.0 daily minimum	*****	9.0 daily maximum	S.U.		3X Weekly	Grab
Total Suspended Solids	Sample meas.	0	1		*****	1	1		0		
	Permit reqmt.	40 monthly average	80 daily maximum	lbs/day	*****	30 monthly average	60 daily maximum	mg/l		Monthly	Grab-Composite
Total Suspended Solids	Sample meas.	*****	*****		*****	172	*****		0		
	Permit reqmt.	*****	*****		*****	Report monthly average	*****	mg/l		Monthly	Grab-Composite
Total Suspended Solids	Sample meas.	1	*****		*****	1	*****		0		
	Permit reqmt.	60 weekly average	*****	lbs/day	*****	45 weekly average	*****	mg/l		Monthly	Grab-Composite
Flow	Sample meas.	0.05	0.09		*****	*****	*****		0		
	Permit reqmt.	Report monthly average	0.16 daily maximum	MGD	*****	*****	*****			5X Weekly	Measured
Total Residual Chlorine	Sample meas.	*****	*****		*****	0.1	0.4		0		
	Permit reqmt.	*****	*****		*****	0.5 monthly average	1.0 daily maximum	mg/l		3X Weekly	Grab
Enterococci	Sample meas.	*****	*****		*****	*****	1		0		
	Permit reqmt.	*****	*****		*****	*****	Report daily maximum	cts/100 ml		See Permit Requirements	Grab
Fecal Coliform	Sample meas.	*****	*****		*****	1	2		0		
	Permit reqmt.	*****	*****		*****	200 monthly geometric mean	800 daily maximum	cts/100 ml		Monthly	Grab
BOD5 Minimum % Removal	Sample meas.	*****	*****		98	*****	*****		0		
	Permit reqmt.	*****	*****		85 minimum percent removal	*****	*****	%		Monthly	Calculation
Total Suspended Solids Minimum % Removal	Sample meas.	*****	*****		99	*****	*****		0		
	Permit reqmt.	*****	*****		85 minimum percent removal	*****	*****	%		Monthly	Calculation

COMMENTS:

W = Average Weekly Effluent Limits;
 For Enterococci Bacteria monitoring requirements see Section 2.4 of the permit

Mail this report when completed to ADEC, Division of Water, 555 Cordova Street, Anchorage, AK 99501-2617

Attach an explanation of any violations. Reference all attachments below.

NAME/TITLE	PRINCIPAL EXECUTIVE OFFICE	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
CATHERINE CARLSON/Wastewater Treatment Plant Operator				907 586-0393	17/03/08
TYPED OR PRINTED				AREA/NUMBER	YY/MM/DD