

**Alaska Department of Environmental Conservation Monthly Discharge Monitoring Report (DMR)**

CONTACT NAME: Catherine Carlson  
 MAILING ADDRESS: 2009 Radcliffe  
 Juneau, AK 99801

FACILITY: Auke Bay WWTF  
 LOCATION: 11825 GLACIER HWY  
 Juneau, AK 99801

PERMIT NUMBER: AKG572004  
 OUTFALL / MONITORING POINT: 001A Discharge into Auke Bay

MONITORING PERIOD: **1/1/2017** TO **1/31/2017**

NO DISCHARGE:

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
Dissolved Oxygen	Sample meas.	*****	*****		4.4	*****	*****				
	1 - Final Effluent 00300 Permit reqmt.	*****	*****		2.0 daily minimum	*****	*****	mg/l		Monthly	Grab
Biochemical Oxygen Demand (BOD5)	Sample meas.	3	4		*****	7	10				
	1 - Final Effluent 00310 Permit reqmt.	40 monthly average	80 daily maximum	lbs/day	*****	30 monthly average	60 daily maximum	mg/l		Monthly	Grab-Composite
Biochemical Oxygen Demand (BOD5)	Sample meas.	*****	*****		*****	270	*****				
	G - Influent 00310 Permit reqmt.	*****	*****		*****	Report monthly average	*****	mg/l		Monthly	Grab-Composite
Biochemical Oxygen Demand (BOD5)	Sample meas.	4	*****		*****	9	*****				
	W - See Comments 00310 Permit reqmt.	60 weekly average	*****	lbs/day	*****	45 weekly average	*****	mg/l		Monthly	Grab-Composite
pH	Sample meas.	*****	*****		7.0	*****	7.3				
	1 - Final Effluent 00400 Permit reqmt.	*****	*****		6.0 daily minimum	*****	9.0 daily maximum	S.U.		3X Weekly	Grab
Total Suspended Solids	Sample meas.	1	3		*****	3	8				
	1 - Final Effluent 00530 Permit reqmt.	40 monthly average	80 daily maximum	lbs/day	*****	30 monthly average	60 daily maximum	mg/l		Monthly	Grab-Composite
Total Suspended Solids	Sample meas.	*****	*****		*****	194	*****				
	G - Influent 00530 Permit reqmt.	*****	*****		*****	Report monthly average	*****	mg/l		Monthly	Grab-Composite
Total Suspended Solids	Sample meas.	2	*****		*****	5	*****				
	W - See Comments 00530 Permit reqmt.	60 weekly average	*****	lbs/day	*****	45 weekly average	*****	mg/l		Monthly	Grab-Composite
Flow	Sample meas.	0.05	0.06		*****	*****	*****				
	1 - Final Effluent 50050 Permit reqmt.	Report monthly average	0.16 daily maximum	MGD	*****	*****	*****			5X Weekly	Measured
Total Residual Chlorine	Sample meas.	*****	*****		*****	0.2	0.5				
	1 - Final Effluent 50060 Permit reqmt.	*****	*****		*****	0.5 monthly average	1.0 daily maximum	mg/l		3X Weekly	Grab
Enterococci	Sample meas.	*****	*****		*****	*****	10				
	1 - Final Effluent 61211 Permit reqmt.	*****	*****		*****	*****	Report daily maximum	cts/100 ml		See Permit Requirements	Grab
Fecal Coliform	Sample meas.	*****	*****		*****	3.2	11				
	1 - Final Effluent 74055 Permit reqmt.	*****	*****		*****	200 monthly geometric mean	800 daily maximum	cts/100 ml		Monthly	Grab
BOD5 Minimum % Removal	Sample meas.	*****	*****		97	*****	*****				
	K - Percent Removal 81010 Permit reqmt.	*****	*****		85 minimum percent removal	*****	*****	%		Monthly	Calculation
Total Suspended Solids Minimum % Removal	Sample meas.	*****	*****		99	*****	*****				
	K - Percent Removal 81011 Permit reqmt.	*****	*****		85 minimum percent removal	*****	*****	%		Monthly	Calculation

COMMENTS:  
 W = Average Weekly Effluent Limits;  
 For Enterococci Bacteria monitoring requirements see Section 2.4 of the permit

Mail this report when completed to ADEC, Division of Water, 555 Cordova Street, Anchorage, AK 99501-2617  
 Attach an explanation of any violations. Reference all attachments below.

NAME/TITLE PRINCIPLE EXECUTIVE OFFICE	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
CATHERINE CARLSON/Wastewater Treatment Plant Operator		907 586-0393	1/7/2017
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA/NUMBER	YY/MM/DD