





Code	Name	Value 1	Value 2	Units	Value 1	Value 2	Value 3	Units	of Ex.	Analysis	Type
50050	Flow, in conduit or thru treatment plant	Smpl. =0.05	=0.06	03 - MGD					0	05/WK - Five Per Week	MS - MEASRD
1 - Effluent Gross											
Season: 0		Req. Req Mon MO AVG	<=.16 DAILY MX	03 - MGD						05/WK - Five Per Week	MS - MEASRD
NODI: -		NODI									
50060	Chlorine, total residual	Smpl. =0	=0.2	19 - mg/L					0	03/07 - Three Per Week	GR - GRAB
1 - Effluent Gross											
Season: 0		Req. Req. MO AVG	<=.5 MO AVG	19 - mg/L			<=1 DAILY MX			03/07 - Three Per Week	GR - GRAB
NODI: -		NODI									
74055	Coliform, fecal general	Smpl. =3	=11	13 - #/100mL					0	01/30 - Monthly	GR - GRAB
1 - Effluent Gross											
Season: 0		Req. Req. MO GEOMN	<=200 MO GEOMN	13 - #/100mL			<=800 DAILY MX			01/30 - Monthly	GR - GRAB
NODI: -		NODI									
81010	BOD, 5-day, percent removal	Smpl. =93		23 - %					0	01/30 - Monthly	CA - CALCTD
K - Percent Removal											
Season: 0		Req. Req. MINIMUM	>=85 MINIMUM	23 - %						01/30 - Monthly	CA - CALCTD
NODI: -		NODI									
81011	Solids, suspended percent removal	Smpl. =93		23 - %					0	01/30 - Monthly	CA - CALCTD
K - Percent Removal											
Season: 0		Req. Req. MINIMUM	>=85 MINIMUM	23 - %						01/30 - Monthly	CA - CALCTD
NODI: -		NODI									

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

No attachments.

**Report Last Saved By**

**City and Borough of Juneau**

User: CBJWASTEWATER1  
Name: James Westcott  
E-Mail: jim.westcott@juneau.org  
Date/Time: 2019-05-09 12:06 (Time Zone: -08:00)

**Report Last Signed By**

User: CBJWASTEWATER1  
Name: James Westcott  
E-Mail: jim.westcott@juneau.org  
Date/Time: 2019-05-10 08:03 (Time Zone: -08:00)

---

©2008 NetDMR