


Permit

Permit ID: AKG572004
Permittee: City and Borough of Juneau
Facility: AUKE BAY WWTF
Permitted Feature: 001 - External Outfall
Report Dates & Status
Monitoring Period: From 06/01/19 to 06/30/19
Status: NetDMR Validated

Major: 
Permittee Address: 2009 Radcliffe Road
 Juneau , AK99801
Facility Location: 11825 GLACIER HWY
 JUNEAU , AK99801
Discharge: 001-A - Discharge into Auke Bay
DMR Due Date: 07/15/19

Considerations for Form Completion

W=Average Weekly Effluent Limits

Principal Executive Officer

First Name: Randall
Title: Supervisor

Last Name: brown
Telephone: 907-586-0393

No Data Indicator (NODI)

Form NODI: -

Parameter Code	Name	NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Units	Value 1	Value 2	Value 3			

Parameter Code	Name	NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Freq. of Analysis	Smpl. Type	
			Value 1	Value 2	Units	Value 1	Value 2	Value 3				Units
00300	Oxygen, dissolved [DO]	Smpl.			=4				19 - mg/L	0	01/30 - Monthly	GR - GRAB
1 - Effluent Gross												
Season: 0		Req.			>=2 DAILY MN				19 - mg/L		01/30 - Monthly	GR - GRAB
NODI: -												
00310	BOD, 5-day, 20 deg. C	Smpl.	=3	=5	26 - lb/d	=8	=13		19 - mg/L	0	01/30 - Monthly	CG - CMPGRB
1 - Effluent Gross												
Season: 0		Req.	<=40 MO AVG	<=80 DAILY MX	26 - lb/d	<=30 MO AVG	<=60 DAILY MX		19 - mg/L		01/30 - Monthly	CG - CMPGRB
NODI: -												
00310	BOD, 5-day, 20 deg. C	Smpl.				=225			19 - mg/L	0	01/30 - Monthly	CG - CMPGRB
G - Raw Sewage Influent												
Season: 0		Req.				Req Mon MO AVG			19 - mg/L		01/30 - Monthly	CG - CMPGRB
NODI: -												
00310	BOD, 5-day, 20 deg. C	Smpl.	=4		26 - lb/d	=11			19 - mg/L	0	01/30 - Monthly	CG - CMPGRB
W - See Comments												
Season: 0		Req.	<=60 WKLY AVG		26 - lb/d	<=45 WKLY AVG			19 - mg/L		01/30 - Monthly	CG - CMPGRB
NODI: -												
00400	pH	Smpl.			=6.7		=7.2		12 - SU	0	03/07 - Three Per Week	GR - GRAB
1 - Effluent Gross												
Season: 0		Req.			>=6 DAILY MN		<=9 DAILY MX		12 - SU		03/07 - Three Per Week	GR - GRAB
NODI: -												
00530	Solids, total suspended	Smpl.	=2	=2	26 - lb/d	=4	=6		19 - mg/L	0	01/30 - Monthly	CG - CMPGRB
1 - Effluent Gross												
Season: 0		Req.	<=40 MO AVG	<=80 DAILY MX	26 - lb/d	<=30 MO AVG	<=60 DAILY MX		19 - mg/L		01/30 - Monthly	CG - CMPGRB
NODI: -												
00530	Solids, total suspended	Smpl.				=168			19 - mg/L	0	01/30 - Monthly	CG - CMPGRB
G - Raw Sewage Influent												
Season: 0		Req.				Req Mon MO AVG			19 - mg/L		01/30 - Monthly	CG - CMPGRB
NODI: -												
00530	Solids, total suspended	Smpl.	=2		26 - lb/d	=5			19 - mg/L	0	01/30 - Monthly	CG - CMPGRB
W - See Comments												
Season: 0		Req.	<=60 WKLY AVG		26 - lb/d	<=45 WKLY AVG			19 - mg/L		01/30 - Monthly	CG - CMPGRB
NODI: -												
50050	Flow, in conduit or thru treatment plant	Smpl.	=0.05	=0.12	03 - MGD					0	05/WK - Five Per Week	MS - MEASRD

Parameter Code	Name	NODI	Quantity or Loading			Quality or Concentration			Units	# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Units	Value 1	Value 2	Value 3				
1 - Effluent Gross												
Season: 0		Req.	Req Mon MO AVG	<=.16 DAILY MX	03 - MGD					05/WK - Five Per Week	MS - MEASRD	
NODI: -		NODI										
50060	Chlorine, total residual	Smpl.				=0.03	=0.18	19 - mg/L	0	03/07 - Three Per Week	GR - GRAB	
1 - Effluent Gross												
Season: 0		Req.				<=.5 MO AVG	<=1 DAILY MX	19 - mg/L		03/07 - Three Per Week	GR - GRAB	
NODI: -		NODI										
61211	Enterococci	Smpl.				=0.05	=0.12	13 - #/100mL	0	09/99 - See Permit	GR - GRAB	
1 - Effluent Gross												
Season: 1		Req.				Req Mon MO AVG	Req Mon DAILY MX	13 - #/100mL		09/99 - See Permit	GR - GRAB	
NODI: -		NODI										
74055	Coliform, fecal general	Smpl.				=3	=7	13 - #/100mL	0	01/30 - Monthly	GR - GRAB	
1 - Effluent Gross												
Season: 0		Req.				<=200 MO GEOMN	<=800 DAILY MX	13 - #/100mL		01/30 - Monthly	GR - GRAB	
NODI: -		NODI										
81010	BOD, 5-day, percent removal	Smpl.			=96			23 - %	0	01/30 - Monthly	CA - CALCTD	
K - Percent Removal												
Season: 0		Req.				>=85 MINIMUM		23 - %		01/30 - Monthly	CA - CALCTD	
NODI: -		NODI										
81011	Solids, suspended percent removal	Smpl.			=98			23 - %	0	01/30 - Monthly	CA - CALCTD	
K - Percent Removal												
Season: 0		Req.				>=85 MINIMUM		23 - %		01/30 - Monthly	CA - CALCTD	
NODI: -		NODI										

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Enterrococci 120/100 ml

Attachments

No attachments.

Report Last Saved By**City and Borough of Juneau**

User: CBJWASTEWATER1
Name: James Westcott
E-Mail: jim.westcott@juneau.org
Date/Time: 2019-07-11 10:35 (Time Zone:-08:00)

Report Last Signed By

User: CBJWASTEWATER1
Name: James Westcott
E-Mail: jim.westcott@juneau.org
Date/Time: 2019-07-11 10:35 (Time Zone:-08:00)

©2008 NetDMR