## OUTER DRIVE & WEST JUNEAU WASTEWATER LIFT STATION IMPROVEMENTS

### **VOLUME II of II**

Contract No. BE23-194

File No. 2124



## **OUTER DRIVE AND WEST JUNEAU PUMP STATION REHABILITATION**

**CONTRACT BE23-194** 

JUNEAU, ALASKA

SHEET NO. TITLE									
GENERAL									
G-001	COVER								
G-002	GENERAL LEGEND, NOTES, & ABBREVIATIONS								
G-003	PUMP STATION PUMP CURVES & DATA								
V-101	/-101 SURVEY CONTROL								
V-102	V-102 RIGHT OF WAY								
V-103	CONSTRUCTION STAGING AREA								
CIVIL									
C-101	OD BYPASS PLAN								
C-102	WJ BYPASS PLAN								
C-103	OD SITE UTILITIES								
C-501	CIVIL DETAILS								
STRUCTURAL									
S-101	OD WET WELL IMPROVEMENTS								
S-102	WJ WET WELL IMPROVEMENTS								
S-501	GENERAL STRUCTURAL DETAILS								
S-502	WET WELL CONCRETE DETAILS								
S-503	WET WELL CONCRETE DETAILS								
PROCESS									
D-001	PROCESS LEGEND								
D-101	OUTER DRIVE PUMP STATION P&ID								
D-102	WEST JUNEAU PUMP STATION P&ID								
D-103	OD DEMOLITION								
D-104	WJ DEMOLITION								
D-105	OD PLAN & SECTION VIEWS								
D-106	WJ PLAN & SECTION VIEWS								
D-201	OD ELEVATION VIEWS								
D-202	WJ ELEVATION VIEWS								
D-301	OD ISOMETRIC VIEWS								
D-302	WJ ISOMETRIC VIEWS								
D-501	GENERAL DETAILS								
MECHANICAL									
M-001	MECH LEGEND, ABBREVIATIONS, AND SCHEDULES								
M-201	OD MECHANICAL DEMOLITION PLAN - GROUND LEVEL								
M-202	OD MECHANICAL DEMO PLAN - VALVE & PUMP LEVELS AND ELEVATION								
M-203	WJ MECHANICAL DEMOLITION PLAN - GROUND LEVEL								
M-204	WJ MECHANICAL DEMO PLAN - VALVE & PUMP LEVELS AND ELEVATION								
M-205	OD MECHANICAL NEW WORK PLAN - GROUND LEVEL								
M-206	OD MECH NEW WORK PLAN - VALVE & PUMP LEVELS AND ELEVATION								
M-207	WJ MECHANICAL NEW WORK PLAN - GROUND LEVEL								
M-208	WJ MECH NEW WORK PLAN - VALVE & PUMP LEVELS AND ELEVATION								
M-301	OD MECH SCHEMATIC & DETAILS								
M-302	WJ MECH SCHEMATIC & DETAILS								

ELECTRICAL	
E-001	ELEC LEGEND, ABBREVIATIONS AND SCHEDULES
E-101	OD AND WJ ELEC SITE PLAN
E-201	OD ELEC EXIST AND DEMO PLAN - GROUND LEVEL
E-202	OD ELEC EXIST AND DEMO PLAN - VALVE & PUMP LEVELS AND ELEV
E-203	WJ ELEC EXIST AND DEMO PLAN - GROUND LEVEL
E-204	WJ ELEC EXIST AND DEMO PLAN - VALVE & PUMP LEVELS AND ELEV
E-205	OD ELEC NEW WORK PLAN - GROUND LEVEL
E-206	OD ELEC NEW WORK PLAN - VALVE & PUMP LEVELS AND ELEVATION
E-207	WJ ELEC NEW WORK PLAN - GROUND LEVEL
E-208	WJ ELEC NEW WORK PLAN - VALVE & PUMP LEVELS AND ELEVATION
E-209	OD PHOTOS OF EXISTING EQUIPMENT
E-210	WJ PHOTOS OF EXISTING EQUIPMENT
E-301	OD AND WJ POWER ONE-LINE - EXIST AND DEMO
E-302	OD POWER ONE-LINE - NEW WORK
E-303	WJ POWER ONE-LINE – NEW WORK
E-304	OD ELEC SCHEDULES AND DETAILS
E-305	WJ ELEC SCHEDULES AND DETAILS
E-401	OD INSTRUMENT CONNECTION SCHEDULE
E-402	WJ INSTRUMENT CONNECTION SCHEDULE
E-403	ELECTRICAL SCHEMATICS
E-404	TYPICAL MOTOR STARTER ELEMENTARY DIAGRAMS
E-405	ELECTRICAL SCHEMATICS
E-501	OD AND WJ PANEL LAYOUT AND EQUIPMENT LIST
E-502	OD FUNCTIONAL NARRATIVES
E-503	WJ FUNCTIONAL NARRATIVES
E-504	OD PLC BLOCK DIAGRAM
E-505	WJ PLC BLOCK DIAGRAM
E-506	OD AND WJ PLC POWER DISTRIBUTION
E-507	OD PLC DISCRETE INPUTS
E-508	OD PLC DISCRETE INPUTS
E-509	OD PLC DISCRETE OUTPUTS
E-510	OD DRIVE PLC ANALOG INPUTS
E-511	OD DRIVE PLC ANALOG INPUTS
E-512	WJ PLC DISCRETE INPUTS
E-513	WJ PLC DISCRETE INPUTS
E-514	WJ PLC DISCRETE OUTPUTS
E-515	WJ PLC ANALOG INPUTS
E-516	WJ PLC ANALOG INPUTS
E-517	GENSET AND ATS INPUTS - OUTPUTS
E-518	VARIABLE FREQUENCY DRIVE (VFD) INPUTS - OUTPUTS
E-519	WJ MOTOR PROTECTION INPUTS - OUTPUTS
E-601	ELECTRICAL DETAILS
E-602	ELECTRICAL DETAILS













BORDER CITY PROJECT

FAIRBANKS • DELTA JCT.

**LOCATION MAP** 

WASILLA PALMER GLENNALLEN
ANCHORAGE EAGLE RIVER
AVALDEZ
KENALJS CORDOVA

G-001

### GENERAL NOTES

- 1. TOGETHER THE DRAWINGS AND CONSTRUCTION SPECIFICATIONS CONSTITUTE A COMPLETE AND INSEPARABLE SET OF CONSTRUCTION DOCUMENTS, INCLUDING ALL NECESSARY CONSTRUCTION AND MATERIALS SPECIFICATIONS TO ENSURE THE PROJECT AS CONSTRUCTED MEETS THE DESIGN INTENT. ANY CHANGES TO CONSTRUCTION METHODS OR MATERIALS SHALL BE APPROVED IN WRITING IN ADVANCE BY THE RESPONSIBLE REGISTERED PROFESSIONAL.
- 2. THIS IS A STANDARD SHEET OF SYMBOLOGY AND NOT ALL SYMBOLS MAY HAVE BEEN USED IN THIS PLANSET.
- 3. THE USE OF THE TERM "PUMP STATION" AND "LIFT STATION" THROUGHOUT THESE PLANS, SPECIFICATIONS, ESTIMATES, AND OTHER PERTINENT PROJECT DOCUMENTS ARE SYNONYMOUS AND REFER TO A "SANITARY SEWER LIFT STATION". THE TERM "PUMP STATION" SHALL NOT BE CONSTRUED TO MEAN POTABLE WATER PUMP STATION.
- 4. EXISTING GROUND CONTOURS ARE FOR REFERENCE ONLY. CONTRACTOR SHALL VERIFY SITE CONDITIONS.
- LOCATIONS OF UTILITIES ARE APPROXIMATE. THE CONTRACTOR SHALL FIELD VERIFY LOCATIONS PRIOR TO CONSTRUCTION. EXERCISE CAUTION DURING EXCAVATION TO EXPOSE UTILITIES WITHOUT DAMAGE. CONTRACTOR SHALL CALL ALASKA DIG LINE (811) FOR UTILITY LOCATES BEFORE DIGGING PER A.S. 42.30.410.
- 6. VERIFY HORIZONTAL AND VERTICAL LOCATIONS OF ALL UTILITIES ENCOUNTERED PRIOR TO CONSTRUCTION. REPORT DISCREPANCIES FROM PLANS IMMEDIATELY TO ENGINEER. RECORD LOCATIONS AND CHANGES TO UTILITIES IN SURVEY NOTES AND ON AS—BUILT DRAWINGS.
- 7. RESTORE ALL DISTURBED PROPERTY OUTSIDE OF WORK LIMITS TO ORIGINAL CONDITIONS.
- 3. THE PLAN DRAWINGS DO NOT SHOW ALL LANDSCAPING AND VEGETATION TO BE ENCOUNTERED DURING CONSTRUCTION. CONTRACTOR SHOULD HAVE A PLAN TO REMOVE AND REPLACE OR WORK AROUND ANY VEGETATION. LITTLE OR NO VEGETATION IS ANTICIPATED WITHIN THE WORK AREA.
- 9. ALL DESIGNATED ITEMS TO BE REMOVED OR DEMOLISHED SHALL BE DISPOSED OF AT AN OFF-SITE, PERMITTED LOCATION UNLESS OTHERWISE NOTED ON THE CONTRACT DOCUMENTS.
- 10. THE CONTRACTOR SHALL FOLLOW ALL CITY OF JUNEAU REGULATIONS FOR NOISE, HOURS OF OPERATIONS, AND DUST CONTROL.
- 11. THE CONTRACTOR SHALL BE RESPONSIBLE FOR EROSION AND SEDIMENT CONTROLS AS NECESSARY TO COMPLY WITH FEDERAL, STATE, AND MUNICIPAL LAWS THAT PROHIBIT UNPERMITTED DISCHARGE OF POLLUTANTS, INCLUDING SEDIMENTS, THAT ARE A RESULT OF EROSION AND OTHER CONSTRUCTION ACTIVITIES. THE CONTRACTOR SHALL CONDUCT ALL WORK SO SEDIMENT IS NOT TRANSPORTED ONTO THE ROADWAY, ADJACENT PROPERTY, OR GASTINEAU CHANNEL.
- 12. CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING THE NECESSARY DEWATERING PERMITS PRIOR TO EXCAVATION. CONTRACTOR IS RESPONSIBLE FOR THE QUALITY OF EFFLUENT FROM DEWATERING PROCESSES AND ANY CONSTRUCTION RUNOFF.
- 13. ALL COMPACTION SHALL BE IN ACCORDANCE WITH PROJECT SPECIFICATIONS.
- 14. PIPE DEFLECTION AND JOINT DEFLECTION SHALL NOT EXCEED ONE—HALF OF THE MANUFACTURER'S RECOMMENDED MAXIMUM DEFLECTION.
- 15. THE CONTRACTOR SHALL TAKE ALL PRECAUTIONARY MEANS TO PROTECT EXISTING EQUIPMENT AND THE BUILDING STRUCTURE.
- 16. WHERE CONDITIONS ARE ENCOUNTERED WHICH APPEAR DIFFERENT FROM THOSE INDICATED ON THE PLANS OR IN THE SPECIFICATIONS, THE CONTRACTOR SHALL NOTIFY THE ENGINEER PRIOR TO THE PERFORMANCE OF WORK.
- 17. CBJ ENGINEERING STANDARD DETAILS, 4TH EDITION, AUGUST 14, 2011 ARE MADE PART OF THESE CONTRACT DOCUMENTS WITH CURRENT MODIFICATIONS AS APPLICABLE. ALL WORK AND MATERIALS NOT INCLUDED IN THE PROJECT SPECIFICATIONS SHALL CONFORM TO THESE STANDARDS. IN CASE OF A CONFLICT BETWEEN REGULATORY OR STANDARD SPECIFICATIONS, THE MORE STRINGENT REQUIREMENT WILL PREVAIL. CBJ STANDARD DETAILS CAN BE FOUND AT: HTTPS: //JUNEAU.ORG/ENGINEERING-PUBLIC-WORKS/CBJ-ENGINEERING-STANDARDS
- 18. CONSTRUCTION SAFETY AND SANITATION FACILITIES SHALL BE PROVIDED AND MAINTAINED BY THE CONTRACTOR
- 19. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING AND ALL WORK IN THE AREA WITH THE PROJECT ENGINEER AND CBJ STAFF PRIOR TO BEGINNING WORK ON THE PROJECT.
- 20. THE CONTRACTOR SHALL COORDINATE WITH CBJ OPERATORS IN OPERATING ALL EXISTING VALVES AND PUMPS.
- 21. THE CONTRACTOR IS TO COMPLY WITH ALL PERMIT CONDITIONS AND RESTRICTIONS.
- 22. THE CONTRACTOR IS RESPONSIBLE FOR DUST CONTROL, USING WATER OR OTHER METHODS APPROVED BY THE REPRESENTATIVE.
- 23. THE CONTRACTOR IS RESPONSIBLE FOR MAINTAINING A SAFE SITE DURING BOTH WORKING AND NON-WORKING HOURS.
- 24. REFER TO THE PROJECT SPECIFICATION FOR FACILITY SHUTDOWN ALLOWANCES AND CONSTRUCTION CONSTRAINTS.
- 25. EQUIPMENT SHALL BE INSTALLED IN STRICT ACCORDANCE WITH THE MANUFACTURERS INSTALLATION AND STARTUP REQUIREMENTS. CONTRACTOR SHALL BE RESPONSIBLE FOR MODIFICATIONS REQUIRED, IF ANY, TO ACCOMMODATE ALTERNATE EQUIPMENT.


### **ABBREVIATIONS**


AC	ASBESTOS CEMENT	LF	LINEAR FEET
ACP	ASPHALT CONCRETE PAVEMENT	LT	LEFT
ADA	AMERICANS WITH DISABILITIES ACT	MAX	MAXIMUM
ARFS	AS REQUIRED FOR SAFETY	MCL	MATERIALS CERTIFICATION LIST
ASD	ABANDONED STORM DRAIN	ME	MATCH EXISTING
ASTM	AMERICAN SOCIETY OF TESTING	MH	MANHOLE
	MATERIALS	MIN	MINIMUM
ATM	ALASKA TRAFFIC MANUAL	MJ	MECHANICAL JOINT
AVAP	AS VERTICAL AS POSSIBLE	MUTCD	MANUAL ON UNIFORM TRAFFIC CONTROL
AWWA	AMERICAN WATER WORKS ASSOCIATION		DEVICES
BLVD	BOULEVARD	N	NORTH
BOP	BOTTOM OF PIPE	NFS	NON FROST SUSCEPTIBLE
3V	BUTTERFLY VALVE	NO	NUMBER
C&G	CURB & GUTTER	NSF	NATIONAL SANITATION FOUNDATION
CAP	CORRUGATED ALUMINUM PIPE	NTS	NOT TO SCALE
СВМН	CATCH BASIN MANHOLE	O&M	OPERATION & MAINTENANCE
CBJ	CITY AND BOROUGH OF JUNEAU	OC	ON CENTER
CI	CAST IRON	OD	OUTER DRIVE PUMP STATION
CIPP	CURED-IN-PLACE-PIPE	OGS	OIL GRIT SEPARATOR
CL	CLASS	ОН	OVERHEAD
CMP	CORRUGATED METAL PIPE	OSHA	OCCUPATIONAL SAFETY & HEALTH
00	CLEANOUT		ADMINISTRATION
CONC	CONCRETE	PCC	PORTLAND CEMENT CONCRETE
CPEP	CORRUGATED POLYETHYLENE PIPE	PE	PLAIN END
CPPP	CORRUGATED POLYPROPYLENE PIPE	PI	POINT OF INTERSECTION
CSP	CORRUGATED STEEL PIPE	PPI	PLASTIC PIPE INSTITUTE
CSSP	CORRUGATED STRUCTURAL STEEL PIPE	PS	PUMP STATION
	CORRUGATED STRUCTURAL STEEL PIPE	PSI	POUNDS PER SQUARE INCH
CSSPA	ARCH	PVC	POLYVINYL CHLORIDE
CTE	CONNECT TO EXISTING	R	RADIUS
CU	COPPER	R&R	REMOVE & REPLACE
CY	CUBIC YARD	ROW	RIGHT-OF-WAY
Ø	DIAMETER	RT	RIGHT
DIA	DIAMETER	S	SOUTH
DEC	DEPARTMENT OF ENVIRONMENTAL	SCH	SCHEDULE
	CONSERVATION	SD	STORM DRAIN
DIP	DUCTILE IRON PIPE	SDCB	STORM DRAIN CATCH BASIN
DR	DIMENSION RATIO	SDMH	STORM DRAIN MANHOLE
ĒΑ	EACH	SDR	STANDARD DIMENSION RATIO
EG	EXISTING GRADE	SDYD	STORM DRAIN YARD DRAIN
ELEV	ELEVATION	SS	SANITARY SEWER
EOP	END OF PROJECT	STA	STATION
Ξ	EXISTING	STD	STANDARD
FF	FINISH FLOOR	SW	SIDEWALK
F&I	FURNISH & INSTALL	SW T	
₹L	FLANGE		TELEPHONE
-M	FORCE MAIN	TB	TEST BORING
-T	FEET	TBC	TOP BACK OF CURB
G	GAS	TBD	TO BE DETERMINED
GB	GRADE BREAK	TYP	TYPICAL
GV	GATE VALVE	UG	UNDERGROUND
HDPE	HIGH DENSITY POLYETHYLENE	VB	VALVE BOX
		W	WEST
HYD	HYDRANT	WJ	WEST JUNEAU PUMP STATION
D	INSIDE DIAMETER	W/O	WITHOUT
NV	INVERT	wT	WEIGHT
JDWWTP	JUNEAU DOUGLAS WATER TREATMENT PLANT	WWTP	WASTEWATER TREATMENT PLANT
LB	POUNDS	YD	YARD DRAIN
LC	LEVELING COURSE		

JTER DRIVE & WEST JUNEAU PUMP STATION REHABILITATION JUNEAU, AK GENERAL LEGEND, NOTES, & ABBREVIATIONS

> ROJECT 1528.50233.0 ATE 01/17/2023

> > SHEET G-002





**OUTER DRIVE PERFORMANCE CURVES** 

				WET WELL FALLING				WET WELL RISING				
	WATER SURFACE ELEVATION	WATER DEPTH	NO.1 60 Hz	NO.1 42+ Hz	NO.2 60 Hz	NO.2 42 Hz	NO.3 45 Hz		NO.1 60 Hz	NO.1 42 Hz	NO.2 60 Hz	NO.3 60 Hz
HIGH ALARM	7.0	8.6										
HIGH HIGH	6.6	8.2										
LAG ON	6.0	7.6										
LEAD HIGH	5.6	7.2										
LEAD ON	4.6	6.2										
LEAD OFF	3.5	5.1										
LOW ALARM	3.2	4.8										

NOTE: SEQUENCE PROVIDED AS THE RECOMMENDED INITIAL PUMP SET POINTS. OPTIMIZATION, FIELD TUNING, SET POINT ADJUSTMENT, PID CONTROLLER TUNING FOR CONSTANT WELL LEVEL ARE AT CBJ OPERATOR AND INTEGRATOR DISCRETION.

-1.6

### OUTER DRIVE DESIGN CRITERIA:

PUMP STATION DESIGN CAPACITY (Q), FIRM = 3,500 GPMTOTAL DYNAMIC HEAD (TDH) AT DESIGN Q = 63 FT

DRY WEATHER PUMPS, RATED CAPACITY Q = 1,870 GPM TDH = 61 FT

WET WEATHER PUMP, RATED CAPACITY Q = 4,180 GPM

TDH = 105 FT HP = 175 HP

AVERAGE DAILY PUMPED VOLUME 1.0 MGD MAXIMUM DAILY PUMPED VOLUME 2.3 MGD MINIMUM FORCE MAIN VELOCITY

FORCE MAIN LENGTH 5,300 FEET DIAMETER 20 INCHES MINIMUM PUMP FLOW RATE 1,700 GPM

> 48 FEET 0.77%

30 INCHES

GRAVITY MAIN FROM UPSTREAM MANHOLE DIAMETER

### WEST JUNEAU PERFORMANCE CURVES

			,	WET FALL			T WE	
	WATER SURFACE ELEVATION	WATER DEPTH	NO.1 45 Hz	NO. 1 60 Hz	NO.2 60 Hz	NO.2 45 Hz	NO.1 60 Hz	NO.2 60 Hz
HIGH ALARM	4.00	6.87						
LAG ON	3.50	6.37						
LEAD ON	2.70	5.57						
LAG OFF	0.50	3.37						
LEAD OFF	0.50	3.37						
LOW ALARM	0.00	2.87						
WET WELL FLOOR	-2.87	-						

NOTE: SEQUENCE PROVIDED AS THE RECOMMENDED INITIAL PUMP SET POINTS. OPTIMIZATION, FIELD TUNING, SET POINT ADJUSTMENT, PID CONTROLLER TUNING FOR CONSTANT WELL LEVEL ARE AT CBJ OPERATOR AND INTEGRATOR DISCRETION.

WEST JUNEAU DESIGN CRITERIA:

PUMP STATION DESIGN CAPACITY (Q), FIRM = 1,675 GPMTOTAL DYNAMIC HEAD (TDH) AT DESIGN Q = 97 FT

PUMP RATED CAPACITY TDH = 94 FTHP = 85 HP

Q = 1,975 GPMTDH = 93 FT

AVERAGE DAILY PUMPED VOLUME MAXIMUM DAILY PUMPED VOLUME 1.0 MGD MINIMUM FORCE MAIN VELOCITY 2.0 FPS FORCE MAIN

LENGTH DIAMETER MINIMUM PUMP FLOW RATE

GRAVITY MAIN LENGTH FROM UPSTREAM MANHOLE DIAMETER

10 FEET 2.10% 18 INCHES

2,000 FEET

12 INCHES

700 GPM

WEST JUNEAU PUMP SEQUENCE

G - 003

AND

STATION PUMP CURVES DATA SHEET

**OUTER DRIVE PUMP SEQUENCE & CRITERIA** 

WET WELL FLOOR







### HORIZONTAL CONTROL

COORDINATES ARE ALASKA STATE PLANE ZONE 1, NAD83(2011) EXPRESSED IN U.S. SURVEY FEET. THE BASIS OF COORDINATES IS POINT 501, NATIONAL GEODETIC SURVEY TIDAL BENCHMARK "JNU TIDAL GPS" (PID: A14908), A BRASS DISK HAVING PUBLISHED NGS VALUES OF N 2,362,232.94 AND E 2,541,120.78. BEARING WERE DERIVED FROM STATIC GNSS OBSERVATIONS TAKEN DURING NOVEMBER 2021, HOLDING THE PUBLISHED NGS POSITION OF NGS STATION "JNU TIDAL GPS".

### VERTICAL CONTROL

ELEVATIONS ARE NAVD88 GEOID 12B ORTHOMETRIC HEIGHTS EXPRESSED IN U.S. SURVEY FEET. ELEVATIONS WERE DETERMINED HOLDING THE PUBLISHED ELLIPSOID HEIGHT FOR POINT 501, NATIONAL GEODETIC SURVEY TIDAL BENCHMARK "JNU TIDAL GPS" (PID: AI4908), A BRASS DISK SET IN CONCRETE. THE GPS DERIVED NAVD88 GEOID 12B ELEVATION OF 25.31 WAS HELD FOR THIS PROJECT.

	CONTROL MONUMENTS USED IN THIS SURVEY										
ID	NORTHING EASTING ELEVATION DESCRIPTION SURVEY POINT										
202	2362316.657	2542760.479	22.0470	BRASS CAP	202						
203	2362342.233	2542220.353	22.3570	ALCAP	203						
204	2361652.718	2538419.912	47.6370	MAGNAIL	204						
205	205 2361800.014 2538637.481 25.0080 ALCAP 205										
JNU TIDAL	2362232.94	2541120.777	25.3080	BRASS CAP	501						

**BID SET** 

REVISIONS

REV DATE DESCRIPTION

THE PROPERTY AND A THE PROPERTY AND A






STATION KEHABILITATION JUNEAU, AK

SURVEY CONTROL

OT 1528.50233.01 01/17/2023

V-101



1 V-102

OUTER DRIVE PUMP STATION SITE

1" = 20



WEST JUNEAU PUMP STATION SITE

### NOTES:

- 1. THERE IS NO RIGHT-OF-WAY TAKE OR TEMPORARY CONSTRUCTION EASEMENT OBTAINED BY THE CITY AND BOROUGH OF JUNEAU FOR THE FACILITATION OF THIS PROJECT.
- 2. PROPERTY LINES AND UTILITY EASEMENTS DISPLAYED ARE EXISTING. R/W LABELS INDICATE DOT&PF ROW.
- 3. THE WEST JUNEAU PUMP STATION SITE IS LOCATED WITHIN CBJ PROPERTY. DOT&PF PROPERTY SURROUNDS THE PROJECT SITE.
- 4. THE GRAVITY SEWER FACILITIES UPSTREAM OF OUTER DRIVE PUMP STATION EXIST WITHIN AKDOT&PF. USE OF THESE FACILITIES SHALL BE PERFORMED UNDER THE CONDITIONS OF THE MAJOR UTILITY PERMIT NO. 331103-71-020, DATED JUNE 2ND 1971.

**BID SET** 

SUNEAU, AN RIGHT OF WAY

ROJECT 1528.50233.0 ATE 01/17/2023

V-102

\SC-VU-SI-50233.dwg PLOT DATE 2023-1-17 15:03 SAVED DATE 2023-01-17 14:58 USER:

SC-VU-SI-SUZSS.AWG FLUI DAIE ZUZS-I-





### NOTES:

- 1. DO NOT BLOCK ACCESS TO AEL&P SUBSTATION AT ANY TIME. COORDINATE WITH THE UTILITY FOR ADDITIONAL STAGING AREA ONSITE.
- 2. NO STAGING AREA IS PROVIDED AT THE OUTER DRIVE SITE BESIDES THAT AVAILABLE WITHIN THE PROPERTY.



WEST JUNEAU PROPOSED STAGING AREA

**BID SET** 





V-103


### NOTES:


- CONTRACTOR SHALL FURNISH, INSTALL, OPERATE, AND MAINTAIN ALL TEMPORARY BYPASS PUMPS, PIPING, AND EQUIPMENT NECESSARY FOR THE CONSTRUCTION OF THE STRUCTURES DETAILED IN THESE DRAWINGS. THE CONTRACTOR SHALL ENSURE CONTINUOUS SERVICE TO THE UPSTREAM SEWER.
- 2. THE 30-INCH GRAVITY MAIN BETWEEN THE OD JUNCTION MANHOLE AND THE OUTER DRIVE PUMP STATION WET WELL MAY BE PLUGGED AND THE OD JUNCTION MANHOLE MAY BE USED AS AN INTERIM WET WELL. BYPASS LINES AND EQUIPMENT SHALL BE PROTECTED FROM TRAFFIC AND ALLOW TRAFFIC FLOW. CONTRACTOR IS RESPONSIBLE FOR TRAFFIC CONTROL PLAN AND LANE CLOSURE PERMITTING AND APPROVAL PRIOR TO BEGINNING ANY WORK WITHIN THE AKDOT&PF ROW OR THE EGAN DRIVE ROADWAY
- 3. BYPASS PUMPS SHALL BE CAPABLE OF HANDLING RAW, UNSCREENED SEWAGE CONTAINING GRAVEL, RAGS, AND OTHER FIBROUS MATERIALS. PUMPS SHALL BE SELF—PRIMING, NON—CLOG, AND CAPABLE OF PASSING 3-INCH SOLIDS, OR CHOPPER STYLE PUMPS.
- 4. A MINIMUM OF TWO (2) PUMPS SHALL BE INSTALLED AND OPERABLE AT THE OUTER DRIVE PUMP STATION AT ALL TIMES DURING BYPASS. FOR REDUNDANCY IN THE CASE OF PUMP FAILURE, AN ADDITIONAL PUMP IS RECOMMENDED TO BE AVAILABLE AND READY IN RESERVE FOR THE DURATION OF BYPASS PUMPING.
- 5. ROUTING AND MAINTENANCE OF BYPASS LINES IS AT CONTRACTOR DISCRETION. ROUTING SHALL BE ACHIEVED WITHOUT DISRUPTION OF WORK AND RISK OF INJURY OR DAMAGE TO THE LINES DURING CONSTRUCTION. ROUTING MUST BE WITHIN EASEMENTS, UNLESS OTHERWISE APPROVED BY THE ENGINEER. THE BYPASS PLAN SHOWN IN THE DRAWINGS HEREIN ARE PROVIDED TO ASSIST IN THE DEVELOPMENT OF CONTRACTOR WORK PLAN.
- 6. PIPING MAY BE NEW OR USED, BUT SHALL NOT LEAK DURING OPERATION, AND SHALL NOT BE ALUMINUM IRRIGATION PIPE OR SOLVENT CEMENT PVC. IF FLEXIBLE HOSING IS USED, HOSE SHALL HAVE A MINIMUM PRESSURE RATING OF 100 PSI.
- 7. THE CONTRACTOR SHALL REMOVE ALL TEMPORARY BYPASS EQUIPMENT AND RESTORE THE JUNCTION MANHOLE TO ITS ORIGINAL CONDITION UPON COMPLETION OF BYPASSING OPERATIONS. CONTRACTOR SHALL REPAIR ANY DAMAGE INCURRED DURING BYPASS OPERATIONS AND ESTABLISH FLOWING CONDITIONS IN THE
- 8. ALL RESIDUAL WASTEWATER LEFTOVER IN BYPASS PIPING SHALL BE DISPOSED OF IN A SANITARY SEWER MANHOLE AND SHALL NOT BE ALLOWED TO SPILL ONTO THE GROUND.
- 9. JUNCTION MANHOLE SHALL BE RETURNED TO PRIOR OR BETTER CONDITION. FLOW CHANNEL SHAPING OR OTHER MANHOLE MODIFICATIONS SHALL BE PERFORMED IN ACCORDANCE WITH CBJ STANDARD SPECIFICATIONS AND MANHOLE DETAIL.

### ESTIMATED BYPASS PUMPING SYSTEM PERFORMANCE TOTAL SYSTEM FLOW (GPM) HEAD (FT) 500 44 1000 47 2000 60 79 3000 3500 91 4500 122 5000 138 5500 161

### TABLE NOTES:


VALUES IN THIS TABLE WERE GENERATED UNDER THE ASSUMPTION THAT THE CONTRACTOR USES 30 LF OF 8-INCH BYPASS SUCTION LINE AND 80 LF OF 8-INCH BYPASS DISCHARGE LINE FOR BYPASS OPERATIONS.











EXISTING OD JUNCTION MANHOLE PLAN VIEW

**BID SET** 

PLAN

**BYPASS** 

О

C - 101

EXISTING FORCE MAIN BYPASS CONNECTION

-8" QUICK COUPLER, MALE ADAPTER WITH 8" M-NPT

END WITH 8" DUST CAP,

BARBED HOSE SHANK

FEMALE, AND COMPANION COUPLER, FEMALE, WITH 8"

DRAIN


- CONTRACTOR SHALL FURNISH, INSTALL, OPERATE, AND MAINTAIN ALL TEMPORARY BYPASS PUMPS, PIPING, AND EQUIPMENT NECESSARY FOR THE CONSTRUCTION OF THE STRUCTURES DETAILED IN THESE DRAWINGS. THE CONTRACTOR SHALL ENSURE CONTINUOUS SERVICE TO THE UPSTREAM SEWER
- 2. THE 18—INCH GRAVITY MAIN BETWEEN THE WJ JUNCTION MANHOLE AND THE WEST JUNEAU PUMP STATION WET WELL MAY BE PLUGGED AND THE WJ JUNCTION MANHOLE MAY BE USED AS AN INTERIM WET WELL.
- 3. BYPASS PUMPS SHALL BE CAPABLE OF HANDLING RAW, UNSCREENED SEWAGE CONTAINING GRAVEL, RAGS, AND OTHER FIBROUS MATERIALS. PUMPS SHALL BE SELF-PRIMING, NON-CLOG, AND CAPABLE OF PASSING 3-INCH SOLIDS, OR CHOPPER STYLE PUMPS.
- 4. A MINIMUM OF TWO (2) PUMPS SHALL BE INSTALLED AND OPERABLE AT THE OUTER DRIVE PUMP STATION AT ALL TIMES DURING BYPASS. FOR REDUNDANCY IN THE CASE OF PUMP FAILURE, AN ADDITIONAL PUMP IS RECOMMENDED TO BE AVAILABLE AND READY IN RESERVE FOR THE DURATION OF BYPASS PUMPING.
- 5. ROUTING AND MAINTENANCE OF BYPASS LINES IS AT CONTRACTOR DISCRETION. ROUTING SHALL BE ACHIEVED WITHOUT DISRUPTION OF WORK AND RISK OF INJURY OR DAMAGE TO THE LINES DURING CONSTRUCTION. ROUTING MUST BE WITHIN EASEMENTS, UNLESS OTHERWISE APPROVED BY THE ENGINEER. THE BYPASS PLAN SHOWN IN THE DRAWINGS HEREIN ARE PROVIDED TO ASSIST IN THE DEVELOPMENT OF CONTRACTOR WORK PLAN AND TO GIVE A GENERAL RECOMMENDED APPROACH.
- 6. PIPING MAY BE NEW OR USED, BUT SHALL NOT LEAK DURING OPERATION, AND SHALL NOT BE ALUMINUM IRRIGATION PIPE OR SOLVENT CEMENT PVC. IF FLEXIBLE HOSING IS USED, HOSE SHALL HAVE A MINIMUM PRESSURE RATING OF 100 PSI.
- THE CONTRACTOR SHALL REMOVE ALL TEMPORARY BYPASS EQUIPMENT AND RESTORE THE JUNCTION MANHOLE TO ITS ORIGINAL CONDITION UPON COMPLETION OF BYPASSING OPERATIONS. CONTRACTOR SHALL REPAIR ANY DAMAGE INCURRED DURING BYPASS OPERATIONS AND ESTABLISH FLOWING CONDITIONS IN THE
- 8. ALL RESIDUAL WASTEWATER LEFTOVER IN BYPASS PIPING SHALL BE DISPOSED OF IN A SANITARY SEWER MANHOLE AND SHALL NOT BE ALLOWED TO SPILL ONTO THE GROUND.
- 9. JUNCTION MANHOLE SHALL BE RETURNED TO PRIOR OR BETTER CONDITION. FLOW CHANNEL SHAPING OR OTHER MANHOLE MODIFICATIONS SHALL BE PERFORMED IN ACCORDANCE WITH CBJ STANDARD SPECIFICATIONS AND MANHOLE DETAIL.


ESTIMATED BYPASS PUMPING SYSTEM PERFORMANCE									
FLOW (GPM)	TOTAL SYSTEM HEAD (FT)								
0	70								
500	72								
1000	77								
1500	86								
2000	98								
2500	112								
3000	130								
3500	151								
4000	175								

### TABLE NOTES:

 VALUES IN THIS TABLE WERE GENERATED UNDER THE ASSUMPTION THAT THE CONTRACTOR USES 30 LF OF 8-INCH BYPASS SUCTION LINE AND 40 LF OF 8-INCH BYPASS SUCTION LINE AND 40 LF OF 8-INCH BYPASS SUCTION LINE FOR SUPPLY SUPPL DISCHARGE LINE FOR BYPASS OPERATIONS.

SPACE INTENTIONALLY LEFT BLANK






WJ JUNCTION MANHOLE

**BID SET** 

C - 102









PLAN

**BYPASS** 



- 1. ALL EXCAVATION AND TRENCHING FOR PIPE AND STRUCTURES SHALL BE DONE IN ACCORDANCE WITH CBJ STANDARD SPECIFICATIONS 02203.
- 2. CONTRACTOR SHALL CONSULT WITH A LICENSED PROFESSIONAL ENGINEER TRAINED AND COMPETENT IN THE DESIGN OF SHEETING, SHORING, AND BRACING FOR EXCAVATIONS IN PRESENCE OF GROUNDWATER.
- 3. LOCATION OF EXISTING, ABANDONED DIP FORCE MAIN IS APPROXIMATE, LOCATE AND PROTECT IN PLACE DURING ANY EXCAVATION ACTIVITIES.
- 4. CONTRACTOR TO COORDINATE WITH ALASKA ELECTRIC LIGHT & POWER (AEL&P), GCI, AND ACS FOR MAINTENANCE OF SERVICE DURING CONSTRUCTION ACTIVITIES.
- 5. THE WORK WILL REQUIRE THE CONTRACTOR TO USE THE JUNCTION MANHOLE LOCATED PARTIALLY WITHIN THE ALASKA DOT&PF RIGHT-OF-WAY. EXCAVATION WITHIN THE AKDOT&PF ROW IS NOT ALLOWED UNDER THE EXISTING UTILITY PERMIT.
- 6. THE CONTRACTOR SHALL DEVELOP AND SUBMIT A TRAFFIC CONTROL PLAN FOR REVIEW AND APPROVAL TO AKDOT&PF. TRAFFIC CONTROL PLAN SHALL ALSO BE PROVIDED TO THE CITY AND BOROUGH OF JUNEAU IN CONJUNCTION WITH AKDOT&PF REVIEW.
- 7. CONTRACTOR SHALL DIAL 811 OR 907-586-1333 FOR UTILITY LOCATES
- 8. CONTRACTOR TO FIELD VERIFY PIPE LENGTHS PRIOR TO FURNISHING CIPP LINER. LENGTHS SHOWN ARE CENTER OF MH TO 2'-8" PAST INTERIOR WALL FACE OF WET WELL.





MH1 (OD JUNCTION MANHOLE)

C - 103


SITE UTILITIES

**BID SET** 

**OUTER DRIVE PUMP STATION UTILITIES** 

(1) (C-103)

- ① CONTRACTOR SHALL PREPARE SURFACE OF EXISTING FLANGE TO ENSURE A FLUSH SEAL OF EXTENDED FLANGE BACK WITH EXISTING FLANGE
- SLIDE GATE SHALL BE NON-SELF CONTAINED, CAST IRON
- 3 40-POUND MAXIMUM EFFORT CRANK SHALL BE EASILY REMOVABLE FOR USE OF PORTABLE POWER OPERATOR.
- (4) STEM GUIDES SPACING SHALL BE AS RECOMMENDED BY GATE MANUFACTURER FOR THE SPECIFIC STEM SIZE. UNSUPPORTED STEM LENGTH/RADIUS OF GYRATION SHALL NOT EXCEED 200.
- (5) CONTRACTOR TO PROVIDE HILTI HIT—RE 500 V3, OR EQUAL EPOXY FOR ANCHORS
- 6 EXTENDED FLANGE BACK



- ONTRACTOR SHALL REMOVE AND REPLACE THIMBLE PRIOR TO INSTALLATION OF CIPP LINING.
- ② CUT EXISTING PIPE AND INSTALL COUPLER BEFORE CIPP LINING.
- 3 40-POUND MAXIMUM EFFORT CRANK SHALL BE EASILY REMOVABLE FOR USE OF PORTABLE POWER OPERATOR.
- (4) STEM GUIDES SPACING SHALL BE AS RECOMMENDED BY GATE MANUFACTURER FOR THE SPECIFIC STEM SIZE. UNSUPPORTED STEM LENGTH/RADIUS OF GYRATION SHALL NOT EXCEED 200.
- (5) CONTRACTOR TO PROVIDE HILTI HIT—RE 500 V3, OR EQUAL EPOXY FOR ANCHORS
- 6 EXTENDED FLANGE BACK
- (7) INSTALL CIPP IN EXISTING GRAVITY MAIN, EXTEND TO EDGE OF THIMBLE.
- (8) HYDROPHILIC END SEAL. NOT SHOWN.
- CORE STRUCTURE AND SEAL WITH LINK-SEAL(R) OR EQUAL, ALTERNATIVELY CAST THIMBLE INTO WALL WITH HYDROSWELL WATERSTOP.




### WEST JUNEAU SLIDE GATE ISOLATION VALVE DETAIL


- 1. UPON REMOVAL OF EXISTING SLIDE GATES AT EACH STATION CONTRACTOR SHALL COORDINATE WITH OWNER AND ENGINEER TO ALLOW CONDITION VERIFICATION OF THE EXISTING WALL THIMBLES. THE OWNER AND ENGINEER WILL CONFIRM THIMBLE REPLACEMENT OR REHABILITATION APPROACH FOR EACH STATION AS DETAILED.
- 2. THE APPROACH DETAILED IN 1A WILL REQUIRE OPEN CUT EXCAVATION, BACKFILL, COMPACTION TIDALLY INFLUENCED DEWATERING, SHORING, BRACING, AND OTHER TYPICAL CIVIL REQUIREMENTS.





### OUTER DRIVE SLIDE GATE ISOLATION VALVE DETAIL

- (1) EXISTING 30" DIP SANITARY SEWER MAIN
- (2) HYDROPHILIC END SEAL; LMK INSIGNIA OR APPROVED
- 3 CURED-IN-PLACE PIPE LINING
- 4 EXISTING WALL THIMBLE; SQUARE FLANGE, ROUND
- (5) NEW SLIDE GATE VALVE; SEE DETAIL 1 OR 1A, THIS










**OD JUNCTION MANHOLE PENETRATION** 

**BID SET** 

ER DRIVE & WEST JUNEAU PUN STATION REHABILITATION JUNEAU, AK


CIVIL DETAILS

C - 501



OUTER DRIVE & WEST JUNEAU PUMF STATION REHABILITATION JUNEAU, AK OD WET WELL IMPROVEMENTS

S-101





**BID SET** 


S-102

WJ WET WELL IMPROVEMENTS


wet the TTHEW J. METTLER.








WET WELL LADDER DETAIL
NTS





CONCRETE PEDESTAL DETAIL

NTS

**BID SET** 

PROJECT 1528.50233.01 DATE 01/17/2023

STRUCTURAL DETAILS

GENERAL

S-501

194737\SC-ST-DT-50233.dwg PLOT DATE 2023-1-17 15:04 SAVED E

4 S-501

(2) ½" GUSSET PL EA SIDE


EXISTING BEAM DETAIL

1/4/

VERIFY IN-FIELD

SECTION VIEW


TOP MOUNT PLATE PER MANUFACTURER





S - 502

WET WELL CONCRETE DETAILS









NOTES:

- PLATES SHALL BE HDG OR SPRAY-METALIZED COATED PER TECHNICAL SPECIFICATION
- 2. REFER TO METAL FABRICATIONS TECHNICAL SPECIFICATION FOR FASTENER REQUIREMENTS

L/3 L/3 ADD AIR CHIMNEY DURING POUR.—
PATCH W/ HIGH-STRENGTH,
NON-SHRINK GROUT AFTER
CONCRETE HARDENS -2 SEALANT BEAD (HYDRO SWELL) WATERSTOP, TYP. -2" CLR MIN −#3 @ 12" O.C. RADIAL SPACING, DRILL & EPOXY W/ MIN. 3" EMBED, TYP. EA. SIDE —SLEEVE FOR PIPE REFERENCE S-502 REPAIR MOTOR MIX, TYP. @ NEW CONC. OPENINGS -ROUGHEN SURFACE, MAX. 4" AMPLITUDE

### **NEW SECTION VIEW**

CONCRETE BULKHEAD REPAIR DETAIL



OD WET WEATHER PUMP CEILING-MOUNTED STANCHION DETAIL

**BID SET** 

WET WELL CONCRETE DETAILS

S - 503

INSTRUMENT NUMBER

P&ID SYMBOLS

CHECK VALVE  $\sim$ GATE VALVE  $\bowtie$ PLUG VALVE PUMP AIR ACTUATOR

 $\triangleright$ REDUCER

MOTORIZED ACTUATOR

**ABBREVIATIONS** 

CV CHECK VALVE DI DUCTILE IRON

ESD EMERGENCY SHUTDOWN

FLOW INDICATOR

FIT FLOW INDICATING TRANSMITTER

FM FLOW METER

KNIFE GATE VALVE KGV LEL LOWER EXPLOSIVE LIMIT

LSH LEVEL SWITCH HIGH LT LEVEL TRANSDUCER

PUMP

ZS0

PRESSURE TRANSMITTER

PV PLUG VALVE TLSH PUMP SEAL FAIL

TEMPERATURE SWITCH HIGH, LOWER BEARING TSHL TSHU TEMPERATURE SWITCH HIGH, UPPER BEARING


VALVE SWITCH FULLY OPEN


TEMPERATURE SWITCH HIGH, MOTOR WINDING TSHW


VEU VIBRATION ELEMENT UPPER ZSC VALVE SWITCH FULLY CLOSED


PROCESS LEGEND

D - 001











**BID SET** 


OD DEMOLITION

1/17/2023 © DOWL 202

SHEET D - 103







WJ PLAN & SECTION VIEWS


© DOWL 2021

D - 106

		SECT	ΓΙΟΝ L-L	
ID	DESCRIPTION	ND	QTY	COMMENTS
2	SCH 40 PVC PIPE	3"	16'-2 19/32"	EXISTING SUMP PIPING - TO REMAIN
3	DI PIPE	6"	17'-4 9/16"	FLANGED
4	DI PIPE	6"	3 27/32"	FLANGED
5	DI PIPE	10"	37'-11 5/32"	FLANGED
6	DI PIPE	16"	13'-3 7/16"	FLANGED
9	DI PIPE	30"	45'-5 3/4"	EXISTING 30" GRAVITY MAIN TO BE LINED WITH CIPP
12	SCH 40 PVC 90 DEGREE BEND	3"	3	EXISTING SUMP PIPING - TO REMAIN
13	90 DEGREE ELBOW	6"	4	-
14	EXPANSION JOINT	8"	2	-
17	FLOW METER	10"	1	FM-101; SEE ELECTRICAL
18	CONCENTRIC REDUCER	10"x8"	2	-
20	EXPANSION JOINT	12"	1	-
23	BLIND FLANGE	16"	2	-
24	90 DEGREE ELBOW	16"	1	-
26	CONCENTRIC REDUCER	16"x10"	1	-
27	CONCENTRIC REDUCER	16"x12"	1	-
28	TEE	16"	3	-
29	TEE	16"x10"x16"	2	-
32	45 DEGREE BEND	20"	1	EXTENT OF SCOPE OF WORK
33	CONCENTRIC REDUCER	20"x10"	1	-
35	BALL VALVE	1"	1	PH SENSOR ISOLATION VALVE
37	PLUG VALVE	6"	1	DRAIN ISOLATION VALVE
45	ADJUSTABLE WELDED STANCHION	4"	3	-
48	CLAMP	10"	4	SEE DETAIL 5/D-501
50	SWING STRUT ASSEMBLY	16"	1	ANVIL MODEL SIZE 2, OPTION 3, FIGURE 211
59	COMPANION FLANGE	6"	1	-
60	COMPANION FLANGE	16"x6"	1	-

# SGV-101 GROUND ELEV = 23.91'-6" = 4.43 FLANGED DUCKBILL CHECK VALVE ELEV = 1.6'**SECTION K-K**

EXISTING GENERATOR



### NOTES:

- 1. ALL PROCESS PIPING TO BE FACTORY PRIMED AND FIELD PAINTED PER SPECIFICATIONS  $\left( \frac{1}{2} \right)$
- 2. USE FLANGED COUPLING ADAPTERS AS NEEDED AND PER APPROVAL OF ENGINEER TO FACILITATE PIPE FITTING AND ASSEMBLY
- 3. PUMP SUPPORT BRACKETRY SHALL BE FOR FLYGT PUMP NZ INSTALLATION AND SUPPLIED BY MANUFACTURER

**BID SET** 

ROJECT 1528.50233.0 ATE 1/17/2023


OD ELEVATION VIEWS

D-201

		SECT	ION N-N	
ID	DESCRIPTION	ND	QTY	COMMENTS
2	SCH 40 PVC PIPE	3"	15'-8 13/16"	EXISTING SUMP PIPING
4	DI PIPE	8"	5'-3 7/8"	FLANGED
5	DI PIPE	10"	27'-5"	FLANGED
6	DI PIPE	12"	19'-1 9/16"	FLANGED
7	DI PIPE	18"	9'-7 11/32"	EXISTING 18" GRAVITY MAIN
10	SCH 40 PVC 90 DEGREE BEND	3"	3	-
12	FLOW METER	8"	1	FM-201; SEE ELECTRICAL
14	90 DEGREE ELBOW	10"	4	-
16	CONCENTRIC REDUCER	10"x4"	1	-
17	CONCENTRIC REDUCER	10"x8"	1	-
21	CONCENTRIC REDUCER	12"x8"	1	-
22	BALL VALVE	1"	1	ISOLATION BALL VALVE FOR PH PROBE
24	PLUG VALVE	4"	1	HANDWHEEL MANUAL OPERATO
25	KNIFE GATE VALVE	10"	2	AIR ACTUATED KNIFE GATE VALVE
27	PLUG VALVE	12"	1	CHAINWHEEL MANUAL OPERATOR
29	TAPPING SADDLE	10"x1"	1	-
35	CLAMP	10"	4	SEE DETAIL 5/D-501
37	FLANGE	1"	1	PH PROBE CONNECTION

## NOTES

- 1. ALL PROCESS PIPING TO BE FACTORY PRIMED AND FIELD PAINTED PER SPECIFICATIONS  $\ensuremath{\mathsf{N}}$
- 2. USE FLANGED COUPLING ADAPTERS AS NEEDED AND PER APPROVAL OF ENGINEER TO FACILITATE PIPE FITTING AND ASSEMBLY
- 3. PUMP SUPPORT BRACKETRY SHALL BE FOR FLYGT PUMP NZ INSTALLATION AND SUPPLIED BY MANUFACTURER




**BID SET** 

PROJECT 1528.50233.0°
PROJECT 1528.50233.0°
PROJECT 1/17/2023

WJ ELEVATION VIEWS

D-202




PROPOSED PIPING

**BID SET** 

© DOWL 202

OD ISOMETRIC VIEWS

D - 301



**EXISTING PIPING AND DEMOLITION** 


- 8" MAGNETIC FLOW METER 12" PLUG VALVE NEW WET WELL LADDER 4" DUCK BILL CHECK VALVE -4" PLUG VALVE AND RECIRCULATION BYPASS DRAIN EXISTING 18" GRAVITY SEWER -0" METRAFLEX COUPLING, TYP 2 NEW SOLIDS HANDLING PUMPS, TYP. 2 NEW TRASH SCREEN PER CBJ STANDARD 220-3 12" KNIFE GATE VALVE, TYP 2 2" BALL VALVE & ABS DRAIN PIPING, TYP. 2


PROPOSED PIPING

**BID SET** 

WJ ISOMETRIC VIEWS

© DOWL 202 D - 302





WEST JUNEAU GROUND LEVEL DOOR





### SEWER MAIN . NOTES:

SADDLE TEE (SEE NOTE 4)

STAINLESS STEEL

ADJUSTABLE STRAP


1. DIAMETER OF HOLE CUT IN SEWER MAIN SHALL NOT EXCEED 0.25" LARGER THAN THE SADDLE TEE CONNECTION. TEE SHALL BE CENTERED OVER CUT IN PIPE AND CLAMPED WITH METAL BAND SO TEE GASKET FORMS A WATER-TIGHT SEAL.


LIMITS OF TEE

- WATER AND DEBRIS SHALL NOT BE ALLOWED TO ENTER THE SEWER
- MAIN DURING THE TAPPING OPERATION.

  SWING TIES TO THE TEE MUST BE MEASURED AND FURNISHED TO CBJ ENGINEERING DEPARTMENT.
- SADDLE TEE SHALL BE A ROMAC CB SEWER SADDLE OR AN APPROVED EQUAL.











**BID SET** 


OUTER DRIVE & WEST JUNEAU F STATION REHABILITATION JUNEAU, AK

D - 501

GENERAL DETAILS








- PIPE SPACER

DIMENSIONS (IN) PIPE SIZE A (SS) S (MAX) (MAX) (MAX) 27 8 7/8 1 1/4 10 30 1 1/4 1 1/2 1 5/8 12 32 1 1/2 1 3/4 | 1 7/8 | 14 34 17 1 1/2 1 3/4 1 3/8 3 16 36 1 1/2 2 3

VERTICAL PIPE SUPPORT CLAMPS


OUTER DRIVE GROUND LEVEL DOOR



CAST IRON

3" Ø STANCHION

LIMIT SWITCH MOUNTING BRACKET DETAIL



- DEMOLISH GROUT SUBMERSIBLE SUMP PUMP

24" Ø CONCRETE PIPE

SEE MECHANICAL SHEETS FOR PIPING CONNECTION

AND POWER CORD

SUMP DETAIL

ABBREVIATION LEGEND

BRITISH THERMAL UNIT PER HOUR

BTUH

CFH

SYMBOL LEGEND

 $\Diamond$ 

AIR RELEASE VALVE

FANS									
TAG	LOCATION	SERVICE	CAPACITY (CFM)	EXT S.P. (IN H2O)	MOTOR POWER (HP)	VOLTAGE & PHASE (VAC/PH)	FAN SPEED (RPM)	MAKE & MODEL	REMARKS
EF-1	OUTER DRIVE	EXHAUST AIR FOR DE-CLASSIFICATION	1,630	0.40	1	460/3P	1750		SPARK RESISTANT B CONSTRUCTION, INVERTER DUTY-RATED MOTOR.
EF-2	WEST JUNEAU	EXHAUST AIR FOR DE-CLASSIFICATION	1,225	0.35	1	460/3P	1750		SPARK RESISTANT B CONSTRUCTION, INVERTER DUTY-RATED MOTOR.

UNIT	HEATERS							
TAG	LOCATION	ROOM	CAPACITY (kW)	VOLTAGE/ PHASE	FAN SPEED (RPM)	AIRFLOW (CFM)	MAKE & MODEL	REMARKS
UH-1	OUTER DRIVE	GROUND FLOOR	10	460/3	1,600	650	Q-MARK, MUH104	INTEGRAL THERMOSTAT
UH-2	OUTER DRIVE	VALVE LEVEL	7.5	460/3	1,600	650	Q-MARK, MUH074	INTEGRAL THERMOSTAT
UH-3	OUTER DRIVE	PUMP LEVEL	5	460/3	1,600	350	Q-MARK, MUH0541	INTEGRAL THERMOSTAT
UH-4	WEST JUNEAU	GROUND FLOOR	10	460/3	1,600	650	Q-MARK, MUH104	INTEGRAL THERMOSTAT
UH-5	WEST JUNEAU	VALVE LEVEL	10	460/3	1,600	650	Q-MARK, MUH104	INTEGRAL THERMOSTAT
UH-6	WEST JUNEAU	PUMP LEVEL	3	460/3	1,600	350	Q-MARK, MUH0341	INTEGRAL THERMOSTAT

WATER	WATER HEATERS											
TAG	LOCATION	SERVICE	CAPACITY (KW)	VOLTAGE/ PHASE	MIN FLOW (GPM)	TEMP RISE @ 0.5 GPM	TEMP RISE @ 1.0 GPM	MAKE & MODEL	REMARKS			
WH-1		WATER TEMPER FOR DRENCH HOSE	4.1	208/1	0.2	56°F	28 <b>°</b> F	EEMAX SPEX4208T EE	SELF LIMITING TO 90°F OUTPUT PER ANSI Z358.1			
WH-2		WATER TEMPER FOR DRENCH HOSE	4.1	208/1	0.2	56 <b>⁺</b> F	28 <b>*</b> F	EEMAX SPEX4208T EE	SELF LIMITING TO 90'F OUTPUT PER ANSI Z358.1			

PUMPS									
TAG	LOCATION	SERVICE	FLOW (GPM)	HEAD (FT)	SPEED (RPM)	POWER (HP)	VOLTAGE/ PHASE	MAKE & MODEL	REMARKS
SP-1A/B	OUTER DRIVE	SUMP PUMP	4.1	21	1,725	1/2	120/1	ZOELLER MODEL 98	
SP-2A/B	WEST JUNEAU	SUMP PUMP	4.1	21	1,725	1/2	120/1	ZOELLER MODEL 98	

MECH LEGEND, ABBREVIATIONS, AND SCHEDULES

ROJECT 1528.50233. ATE 01/16/202

© DOWL 2023

M-001

OD MECHANICAL DEMOLITION PLAN - GROUND LEVEL

M-201) SCALE: 1/2" = 1'-0"



### **GENERAL SHEET NOTES**

1. VERIFY FIELD CONDITIONS PRIOR TO WORK.

### SHEET NOTES

- $\overbrace{ \textcircled{1} \text{ DEMOLISH ALL EXHAUST DUCTING BETWEEN FLOOR AND CEILING PENETRATIONS.} }$
- $\bigcirc$  DEMOLISH EXISTING ELECTRIC UNIT HEATER.
- (3) DEMOLISH ALL DOMESTIC WATER PIPING, HOSE BIBS, AND VALVES ON THE GROUND LEVEL. HOSE REEL AND DRENCH HOSE TO REMAIN.










OD MECHANICAL DEMOLITION PLAN GROUND LEVEL

ROJECT 1528.50233. ATE 01/16/202

© DOWL 2023 SHEET

**BID SET** M-201



### **GENERAL SHEET NOTES**

1. VERIFY FIELD CONDITIONS PRIOR TO WORK.

### SHEET NOTES

- $\fbox{1}$  DEMOLISH 18X6 DUCTING AND 12X20 DUCTING ON THE GROUND FLOOR.
- $\stackrel{\frown}{2}$  DEMOLISH EXISTING ELECTRIC UNIT HEATERS ON THE GROUND LEVEL AND VALVE LEVEL.
- 3 DEMOLISH EXISTING 6X6 GRILLE ON THE VALVE LEVEL.
- DEMOLISH ALL POTABLE WATER PIPING ON THE GROUND FLOOR. EXISTING POTABLE WATER PIPING ON THE LOWER LEVELS TO REMAIN.
- $\Large{\Large{(5)}}$  DEMOLISH 3" CAST IRON WASTE PIPING ON VALVE LEVEL AND PUMP LEVEL.
- 6 DEMOLISH ALL HOSE BIBS.
- $\bigcirc$  DEMOLISH SUMP PUMP AND SUMP PUMP DISCHARGE PIPING.
- $\langle 8 \rangle$  DEMOLISH EXISTING 12X6 GRILLE ON PUMP LEVEL







OD MECHANICAL DEMO PLAN - VALVE PUMP LEVELS AND ELEVATION

ROJECT 1528.50233 ATE 01/16/202

© DOWL 2023

M-202

### **GENERAL SHEET NOTES**

1. VERIFY FIELD CONDITIONS PRIOR TO WORK.

### SHEET NOTES

- $\Large{\fbox{1}}$  DEMOLISH EXISTING ELECTRIC UNIT HEATER
- $\bigcirc$  DEMOLISH EXISTING 6X12 DUCTING UP TO 8X8 ROOF PENETRATION
- $\ensuremath{\mbox{\ensuremath{\mbox{\scriptsize (3)}}}}\xspace$  DEMOLISH ALL DOMESTIC WATER PIPING, FITTINGS, VALVES, AND HOSE BIBS ON THIS LEVEL.
- $\boxed{4}$  ENLARGE EXISTING 8X8 ROOF PENETRATION TO 18X18.








WJ MECHANICAL DEMOLITION PLAN GROUND LEVEL


ROJECT 1528.50233. ATE 01/16/202


© DOWL 2023 SHEET

M-203










### **GENERAL SHEET NOTES**

- 1. VERIFY FIELD CONDITIONS PRIOR TO WORK.
- 2. ALL EXISTING DOMESTIC WATER PIPING IS 3/4" COPPER.

### SHEET NOTES

- 1) DEMOLISH 12X6 DUCTING AND 8X8 DUCTING ON GROUND FLOOR. DUCTING IN THE VALVE AND PUMP LEVELS TO REMAIN.
- $\fbox{2}$  DEMOLISH EXISTING ELECTRIC UNIT HEATERS ON GROUND LEVEL AND VALVE LEVEL.
- $\begin{tabular}{lll} \hline \end{tabular} \begin{tabular}{lll} \hline \end{tabular} \begin{ta$
- ${\color{red} 4}$  DEMOLISH ALL CAST IRON WASTE PIPING.
- 5 DEMOLISH ALL AIR INTAKE GRILLES IN DUCTING.
- (6) ENLARGE EXISTING 8X8 ROOF OPENING TO 18X18.
- $\overline{7}$  DEMOLISH ALL HOSE BIBS.
- (8) DEMOLISH SUMP DISCHARGE PIPING AND SUMP PUMP.
- $\begin{picture}(400)\put(0,0){\line(0,0){10}}$










WJ MECHANICAL DEMO PLAN - VALVE PUMP LEVELS AND ELEVATION

© DOWL 2023

M-204

1 OD MECHANICAL NEW WORK PLAN - GROUND LEVEL
M-205 SCALE: 1/2" = 1'-0"




### **GENERAL SHEET NOTES**

1. VERIFY FIELD CONDITIONS PRIOR TO WORK.

### SHEET NOTES

- $\bigcirc$  INSTALL HOSE BIB ADJACENT TO EXISTING HOSE REEL.
- $\fbox{2}$  install new exhaust fan  $\ensuremath{\underline{\text{EF-1}}}$  on the roof. Connect to New 18x18 ducting.
- $\bigcirc$  INSTALL NEW 18X18 DUCTING TO/FROM <u>EF-1</u> THRU ROOF. SEE M-206.
- $\bigcirc$  INSTALL NEW UNIT HEATER  $\bigcirc$  REUSE EXISTING UNIT HEATER SUPPORTS.
- $\langle 5 \rangle$  INSTALL NEW WATER HEATER <u>WH-1</u> ON WALL ABOVE STAIRWELL.
- $\Large{\Large{\Large{\begin{tabular}{l} \begin{tabular}{l} \begi$
- $\bigcirc$  ALL NEW DOMESTIC WATER PIPING SHALL BE 3/4" TYPE L COPPER.










OD MECHANICAL NEW WORK PLAN GROUND LEVEL


ROJECT 1528.50233. ATE 01/16/202

M-205





OD MECHANICAL NEW WORK PLAN - PUMP LEVEL M-206 SCALE: 1/4" = 1'-0"



### **GENERAL SHEET NOTES**

1. VERIFY FIELD CONDITIONS PRIOR TO WORK.

### SHEET NOTES

- 1) INSTALL NEW 18X18 DUCTING AND 18X6 TRANSITION ON GROUND LEVEL.
- $\overline{\langle 2 \rangle}$  INSTALL NEW 6X8 GRILLE W/ BALANCING DAMPER ON GROUND LEVEL.
- (3) INSTALL TWO NEW 6X8 GRILLE W/ BALANCING DAMPER ON VALVE LEVEL.
- 4 INSTALL NEW 6X8 GRILLE W/ BALANCING DAMPER ON PUMP LEVEL.
- (5) EXTEND 12X6 DUCTING DOWN TO 12" AFF ON PUMP LEVEL.
- $\fbox{6}$  install NeW 12X6 grille W/ balancing damper on end of duct on pump level.
- $\begin{picture}(60,0)\put(0,0){\line(1,0){10}}\put(0,0){\line(1,0){10}$
- ${\color{red} 8}$  INSTALL NEW ELECTRIC UNIT HEATER  ${\color{red} \text{UH}-3}$  ON PUMP LEVEL.
- 9 INSTALL 3" ABS WASTE PIPING ON VALVE AND PUMP LEVELS.
- $\overleftarrow{\text{10}}$  install new sump pump and 3" abs discharge piping. Connect to new 3" flange installed thru wet well wall.
- 11 INSTALL WH-1 AS SHOWN ABOVE STAIRWELL.
- (12) INSTALL NEW HOSE BIB.
- $\langle\overline{13}\rangle$  INSTALL NEW 3/4" CW AND TW PIPING ON GROUND LEVEL.
- (14) INSTALL EF-1 ON ROOF W/ HIGH WIND ROOF CURB. PATCH AND REPAIR EXPANDED ROOF PENETRATION. CONTRACTOR TO CONFIRM EXISTING ROOF SYSTEM IS JOHN MANVILLE EPDM. PATCH EXISTING ROOF SYSTEM PER MANUFACTURER RECOMMENDED INSTRUCTIONS.







ROJECT 1528.50233 ATE 01/16/202

MECH I PUMP I

© DOWL 2023

M-206

**BID SET** 

OD MECHANICAL NEW WORK PLAN - ELEVATION M-206 SCALE: 1/4" = 1'-0"

-HOSE BIB FOR DRENCH HOSE (12)

## 1 WJ MECHANICAL NEW WORK PLAN - GROUND LEVEL SCALE: 1/2" = 1'-0"

### **GENERAL SHEET NOTES**

1. VERIFY FIELD CONDITIONS PRIOR TO WORK.

### SHEET NOTES

- $\begin{tabular}{llll} \hline \end{tabular}$  All new domestic water piping shall be 3/4" type L copper on this level.
- $\left\langle 2\right\rangle$  install freeze resistant hose bib in exterior wall for truck washdown.
- (3) INSTALL HOSE BIB.
- $\boxed{4}$  INSTALL ON-DEMAND WATER HEATER MIN 12" AFF.
- $\stackrel{\textstyle \frown}{\underbrace{5}}$  install quarter turn shutoff valve inside building for exterior hose bib.
- $\fbox{6}$  EXHAUST FAN <u>EF-2</u>, ROOF MOUNTED. SEE M-208.
- (7) INSTALL NEW 18X18 DUCTING THRU ROOF.
- $\stackrel{\textstyle \frown}{ }$  install new electric unit heater  $\underline{\text{UH-4}}.$  Reuse existing unit heater supports.

REVISIONS	DESCRIPTION				
	DATE				

B







WJ MECHANICAL NEW WORK PLAN GROUND LEVEL


ROJECT 1528.50233. ATE 01/16/2022

**BID SET** 

M-207


-3/4" UP TO GROUND LEVEL

-3/4" DOWN TO PUMP LEVEL



WJ MECHANICAL NEW WORK PLAN - PUMP LEVEL

M-208 SCALE: 1/4" = 1'-0"



-<u>EF-2</u> (10)

## **GENERAL SHEET NOTES**

1. VERIFY FIELD CONDITIONS PRIOR TO WORK.

## SHEET NOTES

- $\bigcirc$  ALL NEW DOMESTIC WATER PIPING SHALL BE 3/4" TYPE L COPPER.
- $\langle 2 \rangle$  INSTALL UH-5 ON EXISTING UH SUPPORTS ON VALVE LEVEL.
- $\boxed{3}$  INSTALL <u>UH-6</u> ON PUMP LEVEL. REUSE EXISTING SUPPORTS.
- 4 INSTALL NEW 6X8 GRILLE W/ BALANCING DAMPER ON GROUND LEVEL.
- (5) INSTALL NEW 6X8 GRILLE W/ BALANCING DAMPER 12' AFF ON VALVE LEVEL.
- (6) INSTALL NEW 6X8 GRILLE W/ BALANCING DAMPER 18" AFF ON VALVE LEVEL.
- (7) INSTALL NEW 6X8 GRILLE W/ BALANCING DAMPER 8' AFF ON PUMP LEVEL.

- (10) INSTALL EF-2 ON ROOF W/ HIGH WIND ROOF CURB. PATCH AND REPAIR EXPANDED ROOF PENETRATION. CONTRACTOR TO CONFIRM EXISTING ROOF SYSTEM IS JOHN MANVILLE EPDM. PATCH EXISTING ROOF SYSTEM PER MANUFACTURER RECOMMENDED INSTRUCTIONS.
- 11 INSTALL <u>WH-2</u>, WALL MOUNTED.
- (12) ALL DOMESTIC WATER PIPING SHALL BE 3/4".
- (13) INSTALL BACKFLOW PREVENTER MIN 12" AFF ON VALVE LEVEL.
- (14) INSTALL 3" ABS WASTE PIPING ON VALVE AND PUMP LEVELS.
- (5) INSTALL 3" ABS SUMP PUMP DISCHARGE PIPING AS SHOWN. CONNECT TO NEW 3" FLANGE INSTALLED THRU WET WELL WALL.
- (16) INSTALL NEW HOSE BIB.









ROJECT 1528.50233 ATE 01/16/202

MECH I PUMP I

© DOWL 2023

M-208

**BID SET** 

**WJ MECHANICAL NEW WORK - ELEVATION** 

M-208 SCALE: 1/4" = 1'-0"

UNIT HEATERS:
UNIT HEATERS ARE CONTROLLED VIA INTEGRAL THERMOSTAT IN EACH UNIT.


EXHAUST FAN:
THE EXHAUST FAN <u>EF-1</u> SHALL RUN CONTINUOUSLY TO MEET THE REQUIREMENTS OF NFPA 820 FOR ELECTRICAL DECLASSIFICATION OF THE SPACE. THE EXHAUST FAN SHALL BE CONTROLLED VIA THE LOCAL PLC IN THE FACILITY.

HIGH VENTILATION RATE:
BY DEFAULT THE FAN SHALL RUN AT THE DESIGNED <u>HIGH RATE</u> IN ORDER TO PROVIDE 6 AIR CHANGES PER HOUR TO THE FACILITY.

LOW VENTILATION RATE:
THE EXHAUST FAN VFD SHALL PROVIDE 50% AIRFLOW RATE WHEN THE FOLLOWING CONDITIONS ARE MET.

1. THE OUTSIDE AIR TEMPERATURE IS BELOW 50°F.

- THE OUTSIDE AIR TEMPERATUR
   THE BUILDING IS UNOCCUPIED.





OD MECHANICAL HVAC SCHEMATIC
M-301) SCALE: NTS

**BID SET** 

SCHEMATIC & DETAILS

MECH 8

© DOWL 2023

M-301

UNIT HEATERS: UNIT HEATERS ARE CONTROLLED VIA INTEGRAL THERMOSTAT IN EACH UNIT.


EXHAUST FAN:
THE EXHAUST FAN <u>EF-1</u> SHALL RUN CONTINUOUSLY TO MEET THE REQUIREMENTS OF NFPA 820 FOR ELECTRICAL DECLASSIFICATION OF THE SPACE. THE EXHAUST FAN SHALL BE CONTROLLED VIA THE LOCAL PLC IN THE FACILITY.

HIGH VENTILATION RATE:
BY DEFAULT THE FAN SHALL RUN AT THE DESIGNED <u>HIGH RATE</u> IN ORDER TO PROVIDE 6 AIR CHANGES PER HOUR TO THE FACILITY.

LOW VENTILATION RATE:
THE EXHAUST FAN VFD SHALL PROVIDE 50% AIRFLOW RATE WHEN THE FOLLOWING CONDITIONS ARE MET.

1. THE OUTSIDE AIR TEMPERATURE IS BELOW 50°F.

2. THE BUILDING IS UNOCCUPIED.





MECH (


© DOWL 2023 SHEET M-302

**BID SET** 

EXSTING INTAKE LOUVER SCHEMATIC & DETAILS

	RICAL LEGEND
SYMBOL	DESCRIPTION
	EXPOSED CONDUIT
	UNDERGROUND CONDUIT
ø	3/4" X 10' COPPER CLAD STEEL GROUND ROD
<b>⊸</b> •—	CONDUIT RUN - CHANGE IN ELEVATION
6	LIQUID-TIGHT FLEXIBLE METALLIC CONDUIT
	HOME RUN
₩₽	KILOWATT-HOUR METER
	PANELBOARD
$\bowtie$	CONTROL PANEL OR CONTROLLER
VFD	VARIABLE FREQUENCY DRIVE
-x/x-	MOLDED CASE CIRCUIT BREAKER, $X = AMPERE$ RATING, $Y = NO$ . OF POLES
<b>Ø</b>	MOTOR, 3-PHASE
0	MOTOR, SINGLE PHASE
Ľ	DISCONNECT - NON-FUSED
Φ.	20A, 120V, DUPLEX GFI RECEPTACLE, NEMA 5-20R; OR 5mA GFI CIRCUIT BREAKER/CIRCUIT
Φ	20A, 120V, DUPLEX RECEPTACLE, NEMA 5-20R
\$	20A, 120V, SINGLE POLE SWITCH
\$ <sub>T</sub>	MOTOR STARTER, MANUAL
1	THERMOSTAT
0	JUNCTION BOX OR FITTING
M	MOTORIZED VALVE OPERATOR
風	AIR ACTUATED KNIFE GATE VALVE
<b>~~</b> M	MOTORIZED DAMPER
0	LEVEL FLOAT SWITCH
•	LEVEL TRANSDUCER
	OTHER SYMBOLS ARE AS DEFINED BY NOTE.

## **EQUIPMENT TAG LEGEND**



ı	MOUNTING HEIGHT SCHEDULE	
ı	EQUIPMENT	HEIGHT
۱	PANELBOARDS (TOP)	72"
١	SERVICE EQUIPMENT (CENTER LINE OF METER)	PER UTILITY
l	VFDs, MOTOR STARTERS, DISCONNECT SWITCHES (TOP)	66"
l	RECEPTACLES IN NON-FINISHED AND MECH. SPACES (CENTER)	48"
I	WALL MOUNTED SWITCHES (CENTER)	46"

#### **ABBREVIATIONS**

AEL&P AFF

AFG

AHF

ΑO

BCU

CB

CT

CU

CV

DEG

DI

FLC

FVR

ICS

OD

POE

PR

SV

TJB

TYP

AMPERE, ANALOG SIGNAL

ABOVE FINISH FLOOR

ABOVE FINISH GRADE

ANALOG INPUT

BARE COPPER

ANALOG OUTPUT

CIRCUIT BREAKER

CONTROL VALVE

ACTIVE HARMONIC FILTER

ALASKA ELECTRIC LIGHT & POWER

CITY AND BOROUGH OF JUNEAU

CURRENT TRANSFORMER

ALL ELECTRICAL WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE SPECIFICATIONS, REQUIREMENTS OF THE LATEST ADOPTED EDITION OF THE NATIONAL ELECTRICAL CODE, LOCAL CODES AND CBJ'S REQUIREMENTS GOVERNING THIS PROJECT. ALL WORK SHALL BE PERFORMED UNDER THE SUPERVISION OF A STATE OF ALASKA LICENSED

**GENERAL NOTES** 

- 2. ALL ELECTRICAL EQUIPMENT SHALL INCLUDE THE SEAL OF A NATIONALLY RECOGNIZED TESTING LABORATORY (NRTL) FOR THE PURPOSE FOR WHICH
- 3. DIMENSIONS OF EQUIPMENT ARE APPROXIMATE. INSTALLATION SHALL BE VERIFIED BASED ON FIELD MEASUREMENTS AND ACTUAL MANUFACTURER'S DATA AND SHOP DRAWINGS.
- 4. ALL SITE WORK AND UTILITIES ARE SHOWN IN APPROXIMATE LOCATIONS. VERIFY ALL INSTALLATIONS PRIOR TO COMMENCEMENT OF WORK. COORDINATE ALL WORK WITH UTILITIES AS REQUIRED.
- 5. ALL SINGLE PHASE BRANCH CIRCUITS SHALL BE 3/4"C, 3#12, AND ALL THREE PHASE BRANCH CIRCUITS SHALL BE 3/4°C, 4#12, UNLESS OTHERWISE NOTED. ALL CIRCUITS SHALL HAVE A WIRE TYPE EQUIPMENT GROUND CONDUCTOR.
- 6. PROVIDE SEISMIC DESIGN AND SUPPORT PER IBC REQUIREMENTS.
- WHERE EXISTING UNDERGROUND UTILITIES ARE SHOWN ON THE PLANS, MULTIPLE PARALLEL LINES MAY BE ENCOUNTERED IN THE SAME TRENCH OR GENERAL AREA. SINGLE LINES WERE SHOWN FOR CLARITY.
- CALL 811 CALL BEFORE YOU DIG. ALL UTILITIES MAY NOT BE SHOWN IN THE PLANS. THE CONTRACTOR SHALL FIELD LOCATE ALL UTILITIES WITHIN THE WORK AREA PRIOR TO COMMENCEMENT OF WORK. THE CONTRACTOR SHALL NOTIFY THE ENGINEER OF ANY UTILITY CONFLICTS BETWEEN PROPOSED STRUCTURES AND UTILITIES. ADJUSTMENTS OF STRUCTURES MAY BE NECESSARY TO AVOID UTILITY CONFLICTS. ADJUSTMENTS SHALL BE APPROVED BY THE ENGINEER PRIOR TO CONSTRUCTION. HAND DIG WITHIN 36" OF ALL UTILITIES NOT SCHEDULED
- 9. COORDINATE WITH CBJ IN DISCONNECTION OF EQUIPMENT. DO NOT DISCONNECT EQUIPMENT UNTIL NOTIFICATION TO CBJ HAS BEEN MADE
- 10. COORDINATE AND PROVIDE EQUIPMENT WITH THE AMP INTERRUPTING CAPACITY (AIC) FOR THE AVAILABLE FAULT CURRENT AT THE POINT OF THE SYSTEM WHERE INSTALLED, PROVIDE ARC-HAZARD WARNING LABELS ON ALL SWITCHBOARDS, PANELBOARDS, MCC'S AND SIMILAR EQUIPMENT PER NEC ARTICLE 110.16 AND NFPA 70E.

Y	
	XX = FUNCTION / YY = LOOP
)PT	DIFFERENTIAL PRESSURE TRANSMITTER
ACA	CONTROL POWER FAILURE
CA	EMERGENCY POWER AVAILABLE/UPS FAULT
DCA DCC	BATTERY CHARGER ALARM BATTERY SYSTEM TEST
DCT	DC SYSTEM VOLTAGE
SD	EMERGENCY SHUTDOWN
1	FLOW INDICATING TRANSMITTED
IT	FLOW INDICATING TRANSMITTER
-S	FLOW SWITCH
T	FLOW TRANSMITTER
Y	FLOW TOTALIZATION
AOF	HAND-OFF-AUTO
HS	HAND SWITCH
_AH	HIGH LEVEL ALARM
.EL	LOWER EXPLOSIVE LIMIT
-S	LEVEL SWITCH
.SH	LEVEL SWITCH HIGH
SHH	LEVEL SWITCH HIGH-HIGH
SL	LEVEL SWITCH LOW
SLL	LEVEL SWITCH LOW-LOW
NCA	NORMAL POWER AVAILABLE
PCV	MOTORIZED PILOT CONTROL VALVE
PI	PRESSURE INDICATION
PIT	PRESSURE INDICATING TRANSMITTER
PT	PRESSURE TRANSMITTER
₹L	RUN LIGHT
SC	SPEED CONTROL

(XX	NICTOLIMENT IDENTIFIED
Y	() INSTRUMENT IDENTIFIER
	XX = FUNCTION / YY = LOOP
SD	SMOKE DETECTOR
SI	SPEED INDICATION
TAHL	TEMPERATURE ALARM HIGH, LOWER BEARING
TAHW	TEMPERATURE ALARM HIGH, MOTOR WINDING
TAHU	TEMPERATURE ALARM HIGH, UPPER BEARING
TE	TEMPERATURE ELEMENT
TLSH	SUBMERSIBLE PUMP SEAL FAIL
TSHL	TEMPERATURE SWITCH HIGH, LOWER BEARING
TSHU	TEMPERATURE SWITCH HIGH, UPPER BEARING
TSHW	TEMPERATURE SWITCH HIGH, MOTOR WINDING
ГТ	TEMPERATURE TRANSMITTER
ſΑ	FAULT INDICATION
′AL	PILOT LAMP
rc	RUN REQUEST
/CC	VALVE CLOSE REQUEST
YCO	VALVE OPEN REQUEST
YL	RUN STATUS
YS	HOA SWITCH POSITION
ZC	VALVE POSITION CONTROL
ZS	INTRUSION/POSITION SWITCH
ZSC	VALVE FULLY CLOSED
ZSE	TRANSFER SWITCH EMERGENCY POSITION
ZSHB	GENERATOR AUTO STATUS
ZSM	VALVE OFF SEAT
ZSN	TRANSFER SWITCH NORMAL POSITION
ZS0	VALVE FULLY OPEN
ZT	POSITION TRANSMITTER



			FIXTURE SCHED	DULE
TYPE	FIXTURE SYMBOL	LAMP SIZE	MOUNTING	DESCRIPTION/MANUFACTURER
EM1		36W LED	WALL MOUNT @ 8'	EMERGENCY LIGHT FIXTURE, 2-LAMP, 120V, 90 MIN. 12V, 36W, LEAD-CALCIUM BATTERY, LITHONIA #INDX1236-LP05VS-XTRA
EM2	Y	5W LED	WALL MOUNT ABOVE EXTERIOR DOORS	EXTERIOR EMERGENCY FIXTURE REMOTE HEAD, LED, 1-LAMP, 12V. REMOTE HEAD IS TO BE POWERED BY NEAREST EMERGENCY LIGHT FIXTURE 'EM1'.
EX1	⊗	1.0W LED	WALL MOUNT ABOVE DOOR	EXIT SIGN FIXTURE, SINGLE FACE, RED LETTERS, 120V, NI-CAD BATTERY, LITHONIA #LQM-S-W-R-MVOLT-EL N.
F1		38W LED	MOUNT @ CEILING HEIGHT	LINEAR LED, 48", 4,500 LUMENS, 5000K COLOR TEMPERATURE, 80 CRI, 120V, LITHONIA #ZL1F-L48-4500LM-MDD-MVOLT-50K-80CRI-WH
F2		40W LED	MOUNT ® 12' AFF. PENDANT MOUNT BELOW CEILING SUPPORT BEAMS/STRUCTURE TO MAXIMIZE LIGHTING DISTRIBUTION	WET LOCATION LED, 48", 6,000 LUMENS, 4000K COLOR TEMPERATURE, 80 CRI, 120V, LITHONIA #FEM-L48-6000LM-LPPCL-MD-MVOLT-40K-80CRI

INS	STRUMENTATION LEGEND
(XX	FIELD MOUNTED INSTRUMENT
YY	XX = FUNCTION; YY = TAG NO.
XX	MCC MOUNTED INSTRUMENT
YY	XX = FUNCTION; YY = TAG NO.
(XX)	PANEL MOUNTED INSTRUMENT
YY	XX = FUNCTION; YY = TAG NO.
(XX)	PLC MOUNTED INSTRUMENT
(YY)	XX = FUNCTION; YY = TAG NO.
XX YY	PLC FUNCTION XX = FUNCTION; YY = TAG NO.
XX	PLC CONTROL PANEL XX = CONTROL PANEL NAME/TAG



John A. Pepe EE 11387

PROFESSION 1/16/


© DOWL 2023

E-001

ND, ABF

 $\mathbb{R}$ 

Ш



DIGITAL INPUT DO DIGITAL OUTPUT

E, EM EMERGENCY FLA FULL LOAD AMPERES

DEGREES

FULL LOAD CURRENT

FULL VOLTAGE REVERSING (MOTOR STARTER)

GROUND CONDUCTOR GES GROUNDING ELECTRODE SYSTEM

GFI GROUND FAULT INTERRUPTING GRC GALVANIZED RIGID (STEEL) CONDUIT

HP

INSTRUMENTATION AND CONTROL SYSTEMS

KGV KNIFE GATE VALVE KVA KILO-VOLT-AMPERES

LONG TIME, SHORT TIME, INSTANTANEOUS, LSIG GROUND FAULT

1 TF LIQUID TIGHT FLEXIBLE CONDUIT (METALLIC)

MBJ MAIN BONDING JUMPER MCC MOTOR CONTROL CENTER

MCP MOTOR CIRCUIT PROTECTOR

MLO MAIN LUG ONLY MOV MOTOR OPERATED VALVE

NC NORMALLY CLOSED NEC NATIONAL ELECTRICAL CODE

NFPA NATIONAL FIRE PROTECTION ASSOCIATION

NIC NOT IN CONTRACT NO NORMALLY OPEN, NUMBER

> OUTER DRIVE PHASE

PROGRAMMABLE LOGIC CONTROLLER PLC РМ

POWER MONITOR POWER OVER ETHERNET

PAIR RTD

RESISTIVE TEMPERATURE DEVICE REDUCED VOLTAGE SOFT STARTER

RVSS SCP SCADA CONTROL PANEL

SIG SIGNAL SS

STAINLESS STEEL SOLENOID VALVE

TERMINAL JUNCTION BOX TWSH TWISTED WIRE SHIELDED


UON UNLESS OTHERWISE NOTED UNINTERRUPTIBLE POWER SUPPLY

VFD VARIABLE FREQUENCY DRIVE

VM VOLTAGE MONITOR

WEST JUNEAU WEATHERPROOF XFMR TRANSFORMER

EXPLOSION PROOF (HAZARDOUS AREA)



ATE DESCRIPTION BY

OF A S 149 1H S 149 1

EDC, INC.
213 W. FREWED LANE
ANCHORACE, AK 99503
(907) 276-7933
LICENSE NO. AECC705

STATION REHABILITATION JUNEAU, AK OD AND WJ ELEC SITE PLAN

ROJECT 1528.50233.0 ATE 01/16/2022

> © DOWL 2023 SHEET

OD ELECTRICAL EXISTING AND DEMOLITION PLAN - GROUND LEVEL E-201/ SCALE: 1/2" = 1'-0"

**GENERAL SHEET NOTES** 

- 1. FIELD VERIFY ALL (E) CONTROL/SCADA SYSTEM CONNECTIONS BACK TO THE CONTROL PANEL. REPLACE ALL (E) CIRCUITS SCHEDULED FOR DEMOLITION AS REQUIRED.
- 2. EXISTING CONDUITS AND WIRING MAY NOT BE RE-USED, UON.
- 3. ALL EMPTY CONDUITS SHALL BE REMOVED, UON.

## SHEET NOTES

- $\fbox{1}$  DEMOLISH (E) SERVICE ENTRANCE EQUIPMENT, CONDUCTORS AND CONDUIT. COORDINATE AND SCHEDULE ALL WORK WITH SERVING UTILITY (AEL&P) AS
- $\langle \overline{2} \rangle$  DEMOLISH (E) MCC EQUIPMENT SECTIONS AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CABLING, MAINTAIN OR EXPAND (E) SLAB PENETRATIONS TO ALLOW FOR NEW ROUTING AS REQUIRED. SEE SHEET E-301 FOR POWER ONE-LINE DEMOLITION DETAILS. PROVIDE NEW SYSTEM AS INDICATED ON NEW WORK PLANS.
- $\langle\overline{3}
  angle$  DEMOLISH (E) EQUIPMENT AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) MCC OR PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- $\langle 4 \rangle$  DEMOLISH (E) EQUIPMENT AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) CONTROL PANEL. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- $\overleftarrow{\text{5}}$  (E) GENERATOR SHALL REMAIN OPERATIONAL THROUGHOUT CONTRUCTION. PROVIDE CONNECTIONS TO NEW SWITCHGEAR AS SHOWN UNDER NEW WORK
- $\fbox{6}$  DEMOLISH (E) INTERIOR LIGHTING FIXTURES AND ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- MAINTAIN (E) EXTERIOR LIGHTING FIXTURES IN PLACE. PROVIDE NEW DEDICATED CIRCUIT FROM NEW PANEL 'L'.
- 8 HVAC DUCT TO BE REPLACED AND EXPANDED IN SIZE. COORDINATE WITH NEW MCC AND EQUIPMENT INSTALLATION. SEE MECHANICAL FOR DETAILS.
- (9) (E) ATS FEEDERS AND JUNCTION/PULL BOX. (E) FEEDERS ROUTED IN SLAB CONDUIT THROUGH INTERMEDIATE JUNCTION BOX TO GENSET CIRCUIT BREAKER. REROUTE NEW FEEDERS AS REQUIRED TO MAINTAIN SYSTEM OPERATION DURING CONSTRUCTION.
- (E) LOAD BANK AND CONTROL TO REMAIN OPERATIONAL THROUGHOUT PROJECT CONSTRUCTION. PROVIDE ANY REQUIRED CHANGES TO MAINTAIN
- (1) (E) MCC EQUIPMENT IS MOUNTED ABOVE EQUIPMENT PAD ON A STEEL FRAME TO ALLOW ROUTING OF CONDUCTORS FROM FLOOR PENETRATIONS. THE (E) FLOOR PENETRATIONS ARE CENTRIALIZED ALONG THE LENGTH OF THE (E) MCC EQUIPMENT. PROVIDE A NEW SUPPORT STRUCTURE TO ALLOW FOR CONDUCTOR ROUTING UNDER THE NEW MCC CUBICLES.
- $\langle\overline{12}\rangle$  DEMOLISH (E) GFI DUPLEX RECEPTACLES AND ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS, TYPICAL.
- (13) DEMOLISH (E) AUTOMATIC TRANSFER SWITCH (ATS) AND ASSOCIATED CONDUCTORS CONNECTIONS TO GENERATOR CIRCUIT BREAKER. PROVIDE NEW AS INDICATED ON NEW WORK PLANS, TYPICAL.








EXIST AND DEMO PLAN GROUND LEVEL ELEC - (


© DOWL 2023

E-201



OD ELECTRICAL DEMOLITION PLAN - PUMP LEVEL

E-202 SCALE: 1/4" = 1'-0"



## GENERAL SHEET NOTES

- 1. FIELD VERIFY ALL (E) CONTROL/SCADA SYSTEM CONNECTIONS BACK TO CONTROL PANEL. REPLACE ALL (E) CIRCUITS SCHEDULED FOR DEMOLITION.
- 2. EXISTING CONDUITS AND WIRING MAY NOT BE RE-USED UNLESS OTHERWISE NOTED
- 3. ALL EMPTY CONDUITS SHALL BE REMOVED, UON.

## SHEET NOTES

- DEMOLISH (E) MCC EQUIPMENT SECTIONS AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CABLING. MAINTAIN OR EXPAND (E) SLAB PENETRATIONS TO ALLOW FOR NEW ROUTING AS REQUIRED. SEE SHEET E-301 FOR POWER ONE-LINE DEMOLITION DETAILS. PROVIDE NEW SYSTEM AS INDICATED ON NEW WORK PLANS.
- (2) DEMOLISH (E) EQUIPMENT AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) MCC OR PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- (3) DEMOLISH (E) LIFT PUMPS, EQUIPMENT AND ALL ASSOCIATED POWER AND MONITORING CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) MCC. PROVIDE NEW CONNECTIONS AS INDICATED ON NEW WORK PLANS.
- (4) DEMOLISH (E) SUMP PUMP AND ALL ASSOCIATED POWER AND CONTROL CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) PANEL 'L'. PROVIDE NEW PUMPS AND CIRCUITS.
- (5) DEMOLISH ALL (E) LEVEL INSTRUMENTATION WITHIN THE WET WELL BACK TO THE (E) CONTROL PANEL AND BUBBLER SYSTEM CUBICLE. WORK SHALL INCLUDE ALL FUNCTIONAL OR ABANDONED EQUIPMENT, CONDUIT OR CONDUCTORS ASSOCIATED WITH THE LEVEL INSTRUMENTS OR BUBBLER SYSTEM.
- (6) DEMOLISH (E) FLOOD LEVEL SWITCH AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) CONTROL PANEL. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- (7) DEMOLISH (E) FLOW METER (FM-1) AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) CONTROL PANEL AND REMOTE DISPLAY. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- (8) DEMOLISH (E) LIGHTING FIXTURES AND ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- (9) DEMOLISH (E) AIR COMPRESSOR (AC-1, AC-2). 208V, 10 RECEPTACLES, DISCONNECTS AND CIRCUITS. PROVIDE NEW 208V, 10 DISCONNECTS, CIRCUITS AND RECEPTACLES AS SHOWN ON NEW WORK PLANS.
- (10) DEMOLISH (E) GFI DUPLEX RECEPTACLES AND ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- (1) (E) LIFT PUMP POWER AND CONTROL CONDUITS/CONDUCTORS.
  FLOOR/CEILING CONDUIT PENETRATIONS AT THESE LOCATIONS. CONFIRM ALL
  CONDUIT ROUTING AND PENETRATIONS WITH ACTUAL SITE CONDITIONS.

REVISIONS

DESCRIPTION



EDC., INC.
213 W. HEWED LANE
ANCHORACE, AK 9950.
(907) 276-7933
LICENSE NO. AECC706.



STATION REHABILITATION JUNEAU, AK OD ELEC EXIST AND DEMO PLAN VALVE & PUMP LEVELS AND ELEY

PROJECT 1528.50233.
DATE 01/16/2023

© DOWL 2023 SHEET

E-202

3 OD ELECTRICAL DEMOLITION - ELEVATION

E-202 SCALE: 1/4" = 1-0"

WJ ELECTRICAL DEMOLITION PLAN - GROUND LEVEL

SCALE: 1/2" = 1'-0"

0 2'

## GENERAL SHEET NOTES

- FIELD VERIFY ALL (E) CONTROL/SCADA SYSTEM CONNECTIONS BACK TO CONTROL PANEL. REPLACE ALL (E) CIRCUITS SCHEDULED FOR DEMOLITION AS REQUIRED.
- 2. EXISTING CONDUITS AND WIRING MAY NOT BE RE-USED, UON.
- 3. ALL EMPTY CONDUITS SHALL BE REMOVED, UON.

## SHEET NOTES

- DEMOLISH (E) SERVICE ENTRANCE EQUIPMENT, CONDUCTORS AND CONDUIT.
  COORDINATE AND SCHEDULE ALL WORK WITH SERVING UTILITY (AEL&P) AS REQUIRED TO MINIMIZE OUTAGES.
- DEMOLISH (E) MCC EQUIPMENT SECTIONS AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CABLING. MAINTAIN OR EXPAND (E) SLAB PENETRATIONS TO ALLOW FOR NEW ROUTING AS REQUIRED. SEE SHEET E-301 FOR POWER ONE-LINE DEMOLITION DETAILS. PROVIDE NEW SYSTEM AS INDICATED ON NEW WORK PLANS.
- (3) DEMOLISH (E) EQUIPMENT AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) MCC OR PANEL 'L/M'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- (4) DEMOLISH (E) EQUIPMENT AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) CONTROL PANEL. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- (E) GENERATOR SHALL REMAIN OPERATIONAL THROUGHOUT CONTRUCTION. PROVIDE CONNECTIONS TO NEW SWITCHGEAR AS SHOWN UNDER NEW WORK PLANS.
- (6) DEMOLISH (E) INTERIOR LIGHTING FIXTURES AND ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- $\begin{picture}(60,0)\put(0,0){\line(1,0){10}}\put(0,0){\line(1,0){10}$
- $\begin{tabular}{lll} \hline \& & & & & \\ \hline \& & & & & \\ \hline \& & & & \\ \hline & & \\$
- (9) DEMOLISH (E) GFI DUPLEX RECEPTACLES AND ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS, TYPICAL.
- (E) GENERATOR MANUAL TRANSFER SWITCH, LOAD BANK AND ASSOCIATED CIRCUIT BREAKERS TO REMAIN. RE-CONNECT AS SHOWN ON SHEET E-303.







STATION REHABILITATION
JUNEAU, AK

JUNEAU, AK


GROUND LEVEL

PROJECT 1528.50233.
DATE 01/16/202


© DOWL 2023 SHEET

E-203









## **GENERAL SHEET NOTES**

- 1. FIELD VERIFY ALL (E) CONTROL/SCADA SYSTEM CONNECTIONS BACK TO CONTROL PANEL. REPLACE ALL (E) CIRCUITS SCHEDULED FOR DEMOLITION
- 2. EXISTING CONDUITS AND WIRING MAY NOT BE RE-USED UNLESS OTHERWISE NOTED.
- 3. ALL EMPTY CONDUITS SHALL BE REMOVED, UON.

## SHEET NOTES

- 1 DEMOLISH (E) MCC EQUIPMENT SECTIONS AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CABLING. MAINTAIN OR EXPAND (E) SLAB PENETRATIONS TO ALLOW FOR NEW ROUTING AS REQUIRED. SEE SHEET E-301 FOR POWER ONE-LINE DEMOLITION DETAILS. PROVIDE NEW SYSTEM AS INDICATED ON NEW WORK PLANS.
- (2) DEMOLISH (E) EQUIPMENT AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) MCC OR (E) PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- (3) DEMOLISH (E) LIFT PUMPS, EQUIPMENT AND ALL ASSOCIATED POWER AND MONITORING CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) MCC. PROVIDE NEW CONNECTIONS AS INDICATED ON NEW WORK PLANS.
- $\overline{\langle 4 \rangle}$  DEMOLISH (E) SUMP PUMP AND ALL ASSOCIATED POWER AND CONTROL CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) PANEL 'L'.
- $\langle \overline{\bf 5} \rangle$  DEMOLISH ALL (E) LEVEL INSTRUMENTATION WITHIN THE WET WELL BACK TO THE (E) CONTROL PANEL AND BUBBLER SYSTEM CUBICLE. WORK SHALL INCLUDE ALL FUNCTIONAL OR ABANDONED EQUIPMENT, CONDUIT OR CONDUCTORS ASSOCIATED WITH THE LEVEL INSTRUMENTS OR BUBBLER
- $\langle \overline{6} \rangle$  DEMOLISH (E) FLOOD LEVEL SWITCH AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) CONTROL PANEL. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- $\langle \overline{7} \rangle$  DEMOLISH (E) FLOW METER (FM-1) AND ALL ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO THE (E) CONTROL PANEL AND REMOTE DISPLAY. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- $\langle 8 \rangle$  DEMOLISH (E) LIGHTING FIXTURES AND ASSOCIATED CONDUCTORS, CONDUIT AND CONNECTIONS BACK TO PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- (9) (E) DEMOLISH AIR COMPRESSOR (AC-1, AC-2). 208V, 10 RECEPTACLES, DISCONNECTS AND CIRCUITS. PROVIDE NEW 208V, 10 DISCONNECTS, CIRCUITS AND RECEPTACLES AS SHOWN ON NEW WORK PLANS.
- (E) MOTOR OPERATED VALVE (MOV) AND CONTROLLER. DEMOLISH (E) EQUIPMENT AND ASSOCIATED POWER ANC CONTROL CIRCUITS. REPLACE WITH NEW SYSTEM AS INDICATED ON NEW WORK PLANS.
- $\langle \overline{11} \rangle$  DEMOLISH (E) GFI DUPLEX RECEPTACLES AND ASSOCIATED CONDUCTORS. CONDUIT AND CONNECTIONS BACK TO PANEL 'L'. PROVIDE NEW AS INDICATED ON NEW WORK PLANS.
- (E) LIFT PUMP POWER AND CONTROL CIRCUIT CONDUIT PENETRATION LOCATIONS, TYPICAL OF 2. CONFIRM ALL CONDUIT ROUTING AND PENETRATIONS WITH ACTUAL SITE CONDITIONS.






AND DEMO PLAN LEVELS AND ELEV EXIST PUMP WJ ELEC VALVE & I

© DOWL 2023

**BID SET** E-204

WJ ELECTRICAL DEMOLITION - ELEVATION E-204/ SCALE: 1/4" = 1'-0"

OD ELECTRICAL NEW WORK PLAN - GROUND LEVEL E-205 SCALE: 1/2" = 1'-0"



## SHEET NOTES

- $\stackrel{\textstyle \frown}{}_{E-302.}$  Motor control center 'McC'. Provide sections as indicated on sheet
- $\ensuremath{\bigcirc}$  Scada control panel 'scp'. See system details on the e-5xx series sheets.
- 3 RELOCATE (E) TOOLS, BACKBOARDS, ETC. TO ACCOMMODATE NEW SCADA CONTROL PANEL 'SCP' LOCATION AND CIRCUITS.
- $\overleftarrow{\rm 4}$  (E) CIRCUIT BREAKERS SUPPLYING THE LOAD BANK AND GENERATOR. SEE POWER ONE-LINE ON SHEET E-302 FOR CONFIGURATION OF CONNECTIONS.
- PRIMARY RADAR LEVEL SENSOR MOUNTED ADJACENT TO THE NEW WET WELL HATCH. PROVIDE ALL REQUIRED CABLING, CONDUIT AND FITTINGS FOR CONNECTION BACK TO THE SCADA CONTROL PANEL 'SCP'. SEE E-5XX SERIES SHEETS, DIVISION 40 SPECIFICATIONS FOR EQUIPMENT DETAILS AND CIVIL/STRUCTURAL FOR MOUNTING DETAILS.
- (7) DEMOLISHED UNDERSLAB ATS FEEDERS. ABANDON CONDUITS IN PLACE. PROVIDE NEW FEEDERS/CONDUIT FROM ATS TO THE (E) GENERATOR CIRCUIT BREAKER. ROUTE NEW CONDUIT OVERHEAD IN (E) CEILING SPACE. SEE POWER ONE—LINE ON SHEET E—302.
- 8 ROOF MOUNTED VENTILATION FAN AND DUCTING TO EACH LEVEL. VENTILATION SYSTEM REDUCES STATION HAZARDOUS CLASSIFICATION TO UNCLASSIFIED. SEE SHEET E-502 FUNCTIONAL NARRATIVE AND MECHANICAL FOR SYSTEM DEFINITION AND FUNCTIONAL REQUIREMENTS. SYSTEM SHALL BE CONTROLLED BY THE SCADA CONTROL PANEL 'SCP'.
- (9) LIGHTING CONTROL SWITCHES. PROVIDE NEW SWITCHING TO CONTROL EACH BUILDING LEVEL (GROUND, VALVE AND PUMP) SEPERATELY. REPLACE ALL COMPONENTS (SNAP SWITCH, FACEPLATE AND WIRING) WITH NEW.
- $\overleftarrow{\mbox{10}}$  maintain (e) exterior lighting fixtures in place. Provide New Dedicated circuit from New Panel 'l'.
- (11) INTRUSION DETECTION SWITCH. SEE DETAIL 2, SHEET E-601.
- $\langle \overline{12} \rangle$  SMOKE DETECTOR. SEE SPECIFICATIONS FOR DETAILS.
- $\ensuremath{\overline{\text{13}}}$  Critical high level alarm strobe and signage. See specifications and sheet e-602 for signage details.
- (14) RE-CONNECT 120V POWER SUPPLY TO (E) GENERATOR MOTORIZED DAMPERS.
- (15) PROVIDE CONNECTION TO BRIDGE CRANE EQUIPMENT PER THE MANUFACTURER'S REQUIREMENTS.
- E# SEE SHEET E-302 FOR ELECTRICAL EQUIPMENT SCHEDULE.
- $\begin{pmatrix} \chi \chi \\ \chi \chi \end{pmatrix}$  SEE SHEETS E-401 FOR INSTRUMENT CONNECTION SCHEDULE.
- XX-X SEE SHEETS E-302 FOR EQUIPMENT SCHEDULE WITH ELECTRICAL CONNECTIONS.

DATE REVISIONS

DESCRIPTION B



EDC., INC.
213 W. REWED LANE
ANCHORAGE, AK 99503
(907) 276-7933
LICENSE NO. AECC705



ELEC NEW WORK PLAN - GROUND LEVE

PROJECT 1528.50233.0
DATE 01/16/2022

О

© DOWL 2023


E-205


OD ELECTRICAL NEW WORK PLAN - VALVE LEVEL

E-206


SCALE: 1/4" = 1'-0"

E-206 SCALE: 1/4" = 1'-0"





OD ELECTRICAL NEW WORK PLAN - PUMP LEVEL



# OD ELEVATION NEW WORK PLAN - VALVE LEVEL ELEVATION SCALE: 1/4" = 1'-0" 4 OD 4' 8'

## SHEET NOTES

- 1 PUMPS P-101, 102, 103: PROVIDE ALL REQUIRED CONNECTIONS TO POWER, SIGNAL AND SENSOR CIRCUITS AS SHOWN. SEE PUMP SPECIFICATIONS AND SHEET E-302 AND E-405 FOR CONNECTION REQUIREMENTS.
- PROVIDE ALL REQUIRED CABLING, CONDUIT AND FITTINGS FOR CONNECTION BACK TO SCADA CONTROL PANEL 'SCP'. SEE E-5XX SERIES SHEETS, DIVISION 40 SPECIFICATIONS FOR EQUIPMENT DETAILS AND CIVIL/STRUCTURAL FOR MOUNTING DETAILS.
- CRITICAL HIGH LEVEL FLOAT. PROVIDE ALL REQUIRED CABLING, CONDUIT AND FITTINGS FOR CONNECTION BACK TO THE SCADA CONTROL PANEL 'SCP'.
- PUMPS P-101, 102, 103: PROVIDE DISCHARGE PRESSURE
  TRANSMITTERS/EQUIPMENT, CONDUIT, CABLING AND UNISTRUT SUPPORT
  STRUCTURES AS REQUIRED FOR EACH PUMP. SEE SHEET E-601, DETAIL 1.
- (5) PUMP DISCHARGE CHECK VALVE POSITION SENSOR.
- (6) PUMPS P-101, 102, 103: PROVIDE NEW CIRCUITS FOR PUMP MOTOR SEAL-FAIL, WINDING OVER-TEMPERATURE AND UPPER AND LOWER BEARING TEMPERATURE SENSOR CIRCUIT ELEMENTS. ROUTE NEW SENSOR CIRCUITS BACK TO THE XYLEM MAS 812 BU MODULE IN THE MCC CUBICLE. PROVIDE CONDUIT/CABLING, UNISTRUT SUPPORT AND CONNECTIONS. SEE SHEET E-405 FOR DETAILS.
- 7 PUMPS P-101, 102, 103: PROVIDE VFD RATED CABLE IN LIQUID-TIGHT FLEXIBLE CONDUIT CONNECTION TO PUMPS. ROUTE CABLE TO THE TERMINAL JUNCTION BOX (TJB). PROVIDE FITTINGS AND SUPPORT TO SECURE CABLE IN ACCORDANCE WITH CODE AND THE MANUFACTURER'S RECOMMENDATIONS.
- (8) PUMPS P-101, 102, 103: PROVIDE TERMINAL JUNCTION BOX (TJB) FOR MOTOR CABLE CONNECTIONS, NEMA 4X SS. PROVIDE PROPERLY SIZED J-BOX, UL LISTED AS TERMINAL BOX, WITH FACTORY INSTALLED, RATED LUGS. MOUNT BOXES ON UNISTRUT SUPPORT STRUCTURE. PROVIDE TJB(S) AT VALVE LEVEL TO AVOID FLOODING FOR EASE OF ACCESS AND DISCONNECT.
- PROUTE CABLES/CONDUCTORS IN PVC-COATED RIGID METALLIC CONDUIT THROUGH TJB AND BACK TO NEW MOTOR CONTROL CENTER EQUIPMENT AS REQUIRED, TYPICAL. USE (E) PENETRATIONS OR CORE DRILL. PROVIDE NEW PENETRATIONS IN FLOOR SLABS AS REQUIRED. ALL NEW WORK SHALL BE REVIEWED AND APPROVED BY THE PROJECT ENGINEER PRIOR TO STARTING WORK. TYPICAL FOR ALL POWER AND SIGNAL/SENSOR CONDUITS BELOW GRADE.
- $\stackrel{\textstyle \langle 11 \rangle}{}$  Human-machine-interface (HMI) Panel, nema 4x ss. See sheet e-504, e-602 and division 40 specifications for details.
- 12 PROVIDE NEW 30A, 208V, 10 NEMA 4X, SS DISCONNECT AND TWIST-LOCK RECEPTACLE FOR (E) COMPRESSOR EQUIPMENT, AC-1 AND AC-2.
- T3) TRANSITION FROM CLASS 1, DIVISION 1 ENVIRONMENT. PROVIDE SEAL-OFFS FOR ALL ENTRY AND EXIT CONDUITS FROM THE WET WELL.
- PROVIDE NEW PENETRATIONS OR CORE DRILLS IN BLDG WALL SLABS, WET WELL WALLS/LIDS AS REQUIRED TO PROVIDE CONDUIT CHASES OF ADEQUATE SIZE PER THE NEC. PROVIDE CONDUIT SEAL—OFFS FOR ALL ENTRY AND EXIT CONDUITS FROM THE WET WELL CLASSIFIED AREA. ALL NEW PENETRATIONS SHALL BE REVIEWED AND APPROVED BY THE PROJECT ENGINEER PRIOR TO STARTING WORK. TYPICAL FOR ALL POWER AND SIGNAL/INSTRUMENTATION CONDUITS BELOW GRADE.
- PROVIDE ABOVE-GRADE NEMA 4X SS TERMINAL JUNCTION BOX(S) FOR CONNECTION OF LEVEL INSTRUMENTATION. SEAL-OFF FITTING SHALL BE USED FOR ALL CONDUIT TRANSITIONS FROM HAZARDOUS AREAS.
- (16) PROVIDE NEW DUPLEX RECEPTACLE ON GFI CIRCUIT BREAKERS. PROVIDE RECEPTACLES WITH NEW J-BOX, CONDUIT, WIRING AND METALLIC, WHILE-IN-USE COVERS. SEE PANEL 'L' SCHEDULE FOR CIRCUIT BREAKER DETAILS. TYPICAL OF ALL RECEPTACLES.
- (17) WALL MOUNTED FLOOD DETECTOR MOUNTED ON GUA J-BOX. SEE SHEET E-601 FOR DETAILS.
- (18) SUBMERSIBLE LEVEL PROBE IN THE (E) WET WELL (BACK UP LEVEL MEASUREMENT). UNIT SHALL BE MOUNTED ON SELF-CLEANING, STAINLESS STEEL WALL BRACKET. PROVIDE ALL REQUIRED CABLING, CONDUIT AND FITTINGS FOR CONNECTION BACK TO SCADA CONTROL PANEL 'SCP' THROUGH EXTERIOR JUNCTION BOX. MATCH REQUIRED LEAD/LAG AND CRITICAL LOW SETTINGS IN COMPONENT WIRING. SEE DIVISION 40 SPECIFICATIONS FOR EQUIPMENT DETAILS AND CIVIL/STRUCTURAL FOR MOUNTING DETAILS.
- (19) SMOKE DETECTOR. SEE SPECIFICATIONS FOR DETAILS.
- ph and temperature sensor controller. Mount adjacent to probe insertion point using SS unistrut and hardware. SEE Sheet E-504.
- E# SEE SHEET E-302 FOR ELECTRICAL EQUIPMENT SCHEDULE.
- $\begin{pmatrix} \chi \chi \\ \gamma \gamma \end{pmatrix}$  SEE SHEETS E-401 FOR INSTRUMENT CONNECTION SCHEDULE.

XX-X SEE SHEETS E-302 FOR EQUIPMENT SCHEDULE WITH ELECTRICAL CONNECTIONS.

REV DATE DESCRIPTION



EDC., INC.
213 W. HEWED LANE
ANCHORAGE, AK 9950
(907) 276-7933
LICENSE NO. AECC703



STATION REHABILITATION
STATION REHABILITATION
JUNEAU, AK
ELEC NEW WORK PLAN - VALVE
PUMP LEVELS AND ELEVATION

ROJECT 1528.50233.0 ATE 01/16/2022

© DOWL 2023

E-206

## SHEET NOTES

- 1 motor control center 'mcc'. Provide sections as indicated on sheet E-303.
- $\fbox{2}$  SCADA CONTROL PANEL 'SCP'. SEE SYSTEM DETAILS ON THE E-5XX SERIES SHEETS.
- (3) (E) CIRCUIT BREAKERS SUPPLYING THE LOAD BANK AND PORTABLE GENERATOR RECEPTACLE. SEE POWER ONE—LINE ON SHEET E—303 FOR CONFIGURATION OF CONNECTIONS.
- PRIMARY RADAR LEVEL SENSOR MOUNTED ADJACENT TO THE NEW WET WELL HATCH. PROVIDE ALL REQUIRED CABLING, CONDUIT AND FITTINGS FOR CONNECTION BACK TO THE SCADA CONTROL PANEL 'SCP'. SEE E-5XX SERIES SHEETS, DIVISION 40 SPECIFICATIONS FOR EQUIPMENT DETAILS AND CIVIL/STRUCTURAL FOR MOUNTING DETAILS.
- (5) ROOF MOUNTED VENTILATION FAN AND DUCTING TO EACH LEVEL. VENTILATION SYSTEM REDUCES STATION HAZARDOUS CLASSIFICATION TO UNCLASSIFIED. SEE SHEET E-503 FUNCTIONAL NARRATIVE AND MECHANICAL FOR SYSTEM DEFINITION AND FUNCTIONAL REQUIREMENTS. SYSTEM SHALL BE CONTROLLED BY THE SCADA CONTROL PANEL 'SCP'.
- (6) LIGHTING CONTROL SWITCHES. PROVIDE NEW SWITCHING TO CONTROL EACH BUILDING LEVEL (GROUND, VALVE AND PUMP) SEPERATELY. REPLACE ALL COMPONENTS (SNAP SWITCH, FACEPLATE AND WIRING) WITH NEW.
- 7 INTRUSION DETECTION SWITCH. SEE DETAIL 2, SHEET E-601.
- $\langle 8 \rangle$  SMOKE DETECTOR. SEE SPECIFICATIONS FOR DETAILS.
- $\ensuremath{\bigcirc} 9 \ensuremath{\rangle}$  MAINTAIN 36" WORK CLEARANCE IN FRONT OF SWITCHGEAR AS REQUIRED BY NEC.
- $\stackrel{\textstyle \frown}{}$  Critical high level alarm strobe and signage. See specifications and sheet e-602 for details.
- (1) MAINTAIN (E) EXTERIOR LIGHTING FIXTURES IN PLACE. PROVIDE NEW DEDICATED CIRCUIT FROM NEW PANEL 'L'.
- (12) RE-CONNECT 120V POWER SUPPLY TO (E) GENERATOR MOTORIZED DAMPERS.
- $\ensuremath{\overline{\mbox{13}}}$  Provide connection to bridge crane equipment per the manufacturer's requirements.
- SEE SHEET E-303 FOR ELECTRICAL EQUIPMENT SCHEDULE.
- $\begin{pmatrix} \chi\chi \\ \gamma\gamma \end{pmatrix}$  SEE SHEETS E-402 FOR INSTRUMENT CONNECTION SCHEDULE.
- XX-X SEE SHEETS E-303 FOR EQUIPMENT SCHEDULE WITH ELECTRICAL CONNECTIONS.







**GROUND LEVEL** 

WORK PLAN -

NEW

ELEC





OUTER DRIVE & WEST JUNEAU PUMP STATION REHABILITATION JUNEAU, AK


PROJECT 1528.50233 DATE 01/16/202

> © DOWL 2023 SHEET

E-207







SHEET NOTES

- PUMPS P-201, 202: PROVIDE ALL REQUIRED CONNECTIONS TO POWER, SIGNAL AND SENSOR CIRCUITS AS SHOWN. SEE MOTOR SPECIFICATIONS FOR CONNECTION REQUIREMENTS.
- (2) RADAR LEVEL SENSOR MOUNTED ADJACENT TO THE NEW WET WELL HATCH. PROVIDE ALL REQUIRED CABLING, CONDUIT AND FITTINGS FOR CONNECTION BACK TO SCADA CONTROL PANEL 'SCP'. SEE SHEET E-510, DIVISION 40 SPECIFICATIONS FOR EQUIPMENT DETAILS AND CIVIL/STRUCTURAL FOR
- (3) CRITICAL HIGH LEVEL FLOAT. PROVIDE ALL REQUIRED CABLING, CONDUIT AND FITTINGS FOR CONNECTION BACK TO THE SCADA CONTROL PANEL 'SCP'. FLOAT SETTINGS SHALL BE ON CITICAL HIGH WET WELL LEVEL. SEE DIV. 40 SPECIFICATIONS FOR DETAILS.
- PUMPS P-201, 202: PROVIDE DISCHARGE PRESSURE TRANSMITTERS/EQUIPMENT, CONDUIT, CABLING AND UNISTRUT SUPPORT STRUCTURES AS REQUIRED FOR EACH PUMP.
- (5) HUMAN-MACHINE-INTERFACE (HMI) PANEL, NEMA 4X SS. SEE SHEET E-505 AND DIVISION 40 SPECIFICATIONS FOR DETAILS.
- PUMPS P-201, 202: PUMP TERMINAL JUNCTION BOX FOR SEAL-FAIL AND WINDING OVER-TEMPERATURE RELAY CIRCUITS. ROUTE NEW CIRCUITS BACK TO RELAYS IN MCC WITH CONNECTION TO SCADA CONTROL PANEL 'SCP'. PROVIDE CONDUIT/CABLING, UNISTRUT SUPPORT AND CONNECTIONS. SEE
- CONDUIT CONNECTIONS TO PUMPS. ROUTE CABLE TO THE TERMINAL JUNCTION BOX (TJB). PROVIDE FITTINGS AND SUPPORT TO SECURE CABLE IN ACCORDANCE WITH CODE AND THE MANUFACTURER'S RECOMMENDATIONS.
- (8) PUMPS P-201, 202: PROVIDE TERMINAL JUNCTION BOX (TJB) FOR MOTOR CABLE CONNECTIONS, NEMA 4X SS. PROVIDE PROPERLY SIZED JBOX, UL LISTED AS TERMINAL BOX, WITH FACTORY INSTALLED, RATED LUGS. MOUNT BOXES ON UNISTRUT SUPPORT STRUCTURE. PROVIDE TJB(S) AT VALVE LEVEL FOR EASE OF ACCESS AND DISCONNECT.
- THROUGH TJB AND BACK TO NEW MOTOR CONTROL CENTER (MCC) EQUIPMENT AS REQUIRED. USE (E) PENETRATIONS OR CORE DRILLS TO THE EXTENT POSSIBLE, PROVIDE NEW PENETRATIONS OR CORE DRILLS IN FLOOR SLABS AS REQUIRED. ALL WORK SHALL BE REVIEWED AND APPROVED BY THE PROJECT ENGINEER PRIOR TO STARTING WORK. TYPICAL FOR ALL POWER AND SIGNAL/SENSOR CONDUITS BELOW GRADE.
- 10 PUMP EMERGENCY SHUTDOWN SWITCH. RED, MUSHROOM HEAD PUSHBUTTON
- BY THE PROJECT ENGINEER PRIOR TO STARTING WORK. TYPICAL FOR ALL POWER AND SIGNAL/INSTRUMENTATION CONDUITS BELOW GRADE.
- CONNECTION OF RADAR LEVEL TRANSDUCERS. SEAL-OFF FITTING SHALL BE USED FOR TRANSITIONS FROM HAZARDOUS AREAS.
- PROVIDE NEW DUPLEX RECEPTACLE ON GFI CIRCUIT BREAKERS. PROVIDE RECEPTACLES WITH NEW J-BOX, CONDUIT, WIRING AND METALLIC, WHILE-IN-USE COVERS. SEE PANEL 'L' SCHEDULE FOR CIRCUIT BREAKER DETAILS. TYPICAL OF ALL RECEPTACLES.
- (15) WALL MOUNTED FLOOD DETECTOR MOUNTED ON GUA J-BOX. SEE SHEET
- MEASUREMENT). UNIT SHALL BE MOUNTED ON SELF-CLEANING, STAINLESS STEEL WALL BRACKET. PROVIDE ALL REQUIRED CABLING, CONDUIT AND FITTINGS FOR CONNECTION BACK TO SCADA CONTROL PANEL 'SCP' THROUGH EXTERIOR JUNCTION BOX. MATCH REQUIRED LEVEL SETTINGS FROM PRIMARY TRANSDUCER IN COMPONENT WIRING, SEE DIVISION 40 SPECIFICATIONS FOR EQUIPMENT DETAILS AND CIVIL/STRUCTURAL FOR LEVEL AND MOUNTING
- (17) SMOKE DETECTOR. SEE SPECIFICATIONS FOR DETAILS.
- 9 PH AND TEMPERATURE SENSOR CONTROLLER, MOUNT ADJACENT TO PROBE INSERTION POINT USING SS UNISTRUT AND HARDWARE. SEE SHEET E-505.
- TRANSITION FROM CLASS 1, DIVISION 1 ENVIRONMENT. PROVIDE SEAL-OFFS FOR ALL ENTRY AND EXIT CONDUITS FROM THE WET WELL.
- E# SEE SHEET E-303 FOR ELECTRICAL EQUIPMENT SCHEDULE.
- SEE SHEETS E-402 FOR INSTRUMENT CONNECTION SCHEDULE.

XX-X SEE SHEETS E-303 FOR EQUIPMENT SCHEDULE WITH ELECTRICAL CONNECTIONS.

**BID SET** 

\$ 49 ⊞ K/ Alm John A. Pepe EE 11387 PROFESSION 1/16/2 VANE 99503

OUTER DRIVE & WEST JUNEAU STATION REHABILITATION JUNEAU, AK

ELEC NEW WORK PLAN - VALVE PUMP LEVELS AND ELEVATION

OJECT 1528.50233 TE 01/16/202

© DOWL 2023

MOUNTING DETAILS.

E5 'MCC'

SHEET E-519 FOR DETAILS. 7) PUMPS P-201, 202: PROVIDE VFD RATED CABLE IN LIQUID-TIGHT FLEXIBLE

- 9 ROUTE CABLES/CONDUCTORS IN PVC-COATED RIGID METALLIC CONDUIT
- IN NEMA 4X SS ENCLOSURE. SEE SHEET E-602 FOR DETAILS. PROVIDE NEW 30A, 208V, 10 NEMA 4X, SS DISCONNECT AND TWIST-LOCK
- RECEPTACLE FOR (E) COMPRESSOR EQUIPMENT, AC-1 AND AC-2. T2) PROVIDE NEW PENETRATIONS OR CORE DRILLS IN FLOOR SLABS/WET WELL WALLS/LIDS AS REQUIRED TO PROVIDE CONDUIT CHASES OF ADEQUATE SIZE PER THE NEC. ALL NEW PENETRATIONS SHALL BE REVIEWED AND APPROVED
- PROVIDE ABOVE-GRADE NEMA 4X SS TERMINAL JUNCTION BOX FOR
- E-601 FOR DETAILS. (16) SUBMERSIBLE LEVEL PROBE IN THE (E) WET WELL (BACK UP LEVEL
- (18) PUMP DISCHARGE CHECK VALVE POSITION SENSOR.

WJ ELECTRICAL NEW WORK PLAN - PUMP LEVEL E-208 SCALE: 1/4" = 1'-0"

SCALE: 1/4" = 1'-0"

E-208 SCALE: 1/4" = 1'-0"

WJ ELECTRICAL NEW WORK - ELEVATION

WJ ELECTRICAL NEW WORK - ELEVATION





OD (E) PUMP LEVEL AREA
E-209 SCALE: NTS



5 OD (E) VALVE LEVEL AREA E-2009 SCALE: NTS



2 OD (E) MOTOR CONTROL CENTER (MCC)
E-209 SCALE: NTS



4 OD (E) VALVE AREA E-209 SCALE: NTS




6 OD (E) VALVE LEVEL WET WELL PENETRATIONS
E-209 SCALE: NTS

**BID SET** 

PROJECT 1528.50233.01 DATE 01/16/2022

OD PHOTOS OF EXISTING EQUIPMENT


© DOWL 2023 SHEET







5 WJ (E) VALVE LEVEL CONDUIT CEILING PENETRATIONS
SCALE: NTS



CABLE DUCT

ATS









6 WJ (E) STANDBY GENERATOR AND MTS SCALE: NTS

**BID SET** 

WJ PHOTOS OF EXISTING EQUIPMENT

ROJECT 1528.50233. DATE 01/16/202


© DOWL 2023 SHEET

## SHEET NOTES

- 1) DEMOLISH (E) SERVICE ENTRANCE CONDUCTORS. COORDINATE ALL WORK WITH SERVICE UTILITY (AEL&P) AS REQUIRED.
- $\fbox{2}$  DEMOLISH (E) STANDBY POWER CIRCUIT TO ATS. PROVIDE NEW CONDUCTORS AS INDICATED ON NEW WORK PLANS.
- $\begin{tabular}{llll} \hline $\langle 3 \rangle$ DEMOLISH (E) EQUIPMENT AND ALL ASSOCIATED CONDUCTORS, CONDUIT, EQUIPMENT AND CONNECTIONS BACK TO THE MCC. PROVIDE NEW AS$ INDICATED ON NEW WORK PLANS.
- (E) LIFT PUMPS (P-1, P-2, P-3) TO BE DEMOLISHED. DEMOLISH ALL ASSOCIATED EQUIPMENT CONDUCTORS, CONDUIT AND EQUIPMENT BACK THE MCC.
- (5) (E) STANDBY GENERATOR SYSTEM AND ASSOCIATED MANUAL TRANSFER EQUIPMENT, CIRCUIT BREAKERS AND LOAD BANKS TO REMAIN FOR CONNECTION AND REUSE.
- (E) PANEL 'M' INCLUDES A LIMITED NUMBER OF BRANCH CIRCUITS. TWO (2) 20A/2P CIRCUITS FOR THE (E) COMPRESSORS 1 AND 2. PROVIDE NEW CIRCUITS AS REQUIRED IN THE NEW PANEL 'L'.

VOLTAGE: 208Y/12(				(E) PANEL SCHEDULE 'L'						MIN. A.I.C. RATING: 10,000			
	BUS:	(L) PANEL SCHEDOLL L							ENCLOSURE: NEMA 1				
MAIN: 100				ATION:	OUTE	R DRIV	E LIFT :	OITAT	N	MOUNTING	: SURF	ACE	
СКТ	AMP TRIP	LOAD DESCRIPTION	KVA	LOAD	Α	В	С	LOAD	KVA	LOAD DESCRIPTION	AMP TRIP	CK	
1	20/1	TOP FLOOR/EXTERIOR WET WELL LTG								TOP FLOOR AND EXTERIOR RECEPT	20/1	2	
3	20/1	MID LEVEL LTG								MID LEVEL RECEPT	20/1	4	
5	20/1	LOW LEVEL LTG								LOWER LEVEL RECEPT	20/1	6	
7	20/1	SPARE								SPARE	20/1	8	
9	20/1	SYSTEM CONTROLS/UPS								SUMP PUMP	20/2	10	
11	20/1	FLOW RECORDERS								COMPRESSOR NO.1	20/2	12	
13	20/1	GENSET DAMPERS								CONFRESSOR NO.1	20/2	14	
15	20/1	EXHAUST FAN - DRY WELL								COMPRESSOR NO. 2	20/2	16	
17	20/1	EXHAUST FAN - WET WELL								CONFRESSOR NO. 2	20/2	18	
19	20/1	MOTOR HEATERS										20	
21	20/1	GENSET BATTERY CHARGER/DAY TANK								MOTORIZED VALVE	15/3	22	
23	20/1	GENSET JACKET HEATER										24	
25												26	
27	100/3	MAIN								·		28	
29										· · · · · · · · · · · · · · · · · · ·		30	

OD POWER ONE-LINE - EXIST AND DEMOLITION E-301 SCALE: NTS



VOLTAGE: 208Y/120 BUS: 100			(E) P	(E) PANEL 'L' SCHEDULE MIN. A.I.C. RATII ENCLOSU						ING: 10,000 URE: NEMA 1			
MAIN: 100				ATION:	WEST	JUNEA	U LIFT	STATIC	N	MOUNTING: SURFACE			
СКТ	AMP TRIP	LOAD DESCRIPTION	KVA	LOAD	Α	В	С	LOAD	KVA	LOAD DESCRIPTION	AMP TRIP	СКТ	
1	20/1	MIDDLE LEVE LTG								SPARE	20/1	2	
3	20/1	UPPER LEVEL LTG								SPARE	20/1	4	
5	20/1	LOWER LEVEL LTG								SUMP PUMP	20/1	6	
7	20/1	LOWER LEVEL RECPT								COMPRESSOR NO. 1	20/2	8	
9	20/1	UPPER LEVEL RECPT								COMPRESSOR NO. 1		10	
11	20/1	FLOW RECORDERS								OUTSIDE LTG	20/1	12	
13	20/1	DRY WELL EXHAUST FAN								480V MOTOR HEATERS	20/1	14	
15	20/1	FLOW RECORDER								PLC CONTROL POWER	20/2	16	
17	20/1	DIESEL FUEL DAY TANK								BUBBLER COMPRESSOR		18	
19	20/1	GENSET JACKET HEATER										20	
21	20/1	BATTERY CHARGER								MOVEABLE VALVE	15/3	22	
23	20/1	WALL VENT EXHAUST FAN										24	
25												26	
27												28	
29												30	

2 WJ POWER ONE-LINE - EXISTING AND DEMOLITION

E-301 SCALE: NTS

**BID SET** 





AND WJ POWER ONE-LINE - EXIST AND DEMO

© DOWL 2023

1A	2A		3A	4A	5A	6A	
MAIN LUGS	PANEL L		VFD		FVR	FCB	
						6B FCB	
1B VFD				4B		6C FCB	
						6D	
				4C		6E	
				VFD		VFD	
	2B				5B		
	XFMR				FCB		
1C					5C		
					5D		
		-			FVR		
	2C				' ''`		
1D							
טו							
							4

SECTION 4

SECTION 5

SECTION 6

SECTION

SECTION 2

SECTION 3

1A	MAIN LUGS
1B	EXHAUST FAN EF-1 VFD
1C	MOTOR PROTECTION
1D	ETHERNET EQUIPMENT
2A	PANEL 'L'
2B	XFMR
2C	SPACE
3A	PUMP P-102 VFD
4A	POWER MONITOR
4B	SPACE
4C	PUMP P-101 VFD
5A	PUMP P-101 FVR WITH BYPASS
5B	BRIDGE HOIST BC-1
5C	SPACE
5D	PUMP P-103 FVR WITH BYPASS
6A	UNIT HEATER UH-1 FCB
6B	UNIT HEATER UH-2 FCB
6C	UNIT HEATER UH-3 FCB
6D	SPACE
6E	PUMP P-103 VFD

**DESCRIPTION** 

SPACE

	NO	I۲

CIRCUIT SCHEDULE

1 2 EACH: 3"C, 4#350 KCMIL (3H,N), 1#2/0 EGC

2 EACH: 2-1/2"C, 4#300 KCMIL (3H,N),

5 3"C, 3#350 KCMIL (3H), 1#2 EGC, VFD RATED

ELECTRICAL EQUIPMENT SCHEDULE

DESCRIPTION

MAIN CIRCUIT BREAKER (MCB). 600A, 480V, 3ø, 4-WIRE, NEMA 4X SS. ELECTRONIC TRIP WITH

METER BASE AND CT CABINET, NEMA 4X SS.

EQUIPMENT SHALL BE IN ACCORDANCE WITH

ADJUSTABLE LSIG AND ARC-HAZARD

30KVA, 480: 208Y/120V, 3ø, 4-WIRE.

LOAD

٧

208

208

480

480

480

480

480

120

120

480

3

3

HP

2.5

1

45

175

45

1/2

1/2

MCC MOUNTED PANEL 'L':

(E) STANDBY GENERATOR, 300KW/375KVA,

AUTOMATIC TRANSFER SWITCH (ATS), 600A, 480V, 3Ø, 4-WIRE, 3-POLE, NEMA 12

225A, 208Y/120V, 3ø, 4-WIRE, 42-SPACE. SCADA CONTROL PANEL 'SCP', 120V, NEMA 4X SS. SEE E-5XX SERIES SHEETS FOR DETAILS.

MOTOR CONTROL CENTER, 'MCC', 600A, 480V, 3Ø, 4-WIRE, NEMA 12. MCC MOUNTED DRY-TYPE TRANSFORMER 'T-1':

REDUCTION MAINTENANCE MODE.

TAG

ITEM

E3>

TAG ID

AC-1

AC-2

BC-1

EF-1

P-101

P-102

P-103

SP-1A

SP-1B

UH-1

ΚW

3.2

3.2

10

1#1/0 EGC

3 3/4"C, 3#12 (3H), 1#12 EGC 4 2"C, 3#4 (3H), 1#6 EGC, VFD RATED

6 3/4"C, 2#12 (H,N), 1#12 EGC

AEL&P STANDARDS.

480V, 3ø.

DESCRIPTION

- 1) PROVIDE NEW SERVICE ENTRANCE CONDUCTORS AND EQUIPMENT. COORDINATE ALL WORK WITH SERVICE UTILITY (AEL&P) AS REQUIRED. INSTALLATION AND EQUIPMENT SHALL BE IN ACCORDANCE WITH AEL&P STANDARDS.
- 2) PROVIDE MAIN BUS WITH 100kA/PHASE AC SURGE PROTECTION MOUNTED IN THE MCB CABINET. SEE SPECIFICATIONS FOR DETAILS.
- $\begin{tabular}{lll} \hline $\langle 3 \rangle$ PROVIDE GROUNDING ELECTRODE SYSTEM (GES) IN ACCORDANCE WITH NEC 250. SEE DETAIL 1 ON$ SHEET E-304.
- PUMPS P-101, 102, 103: PROVIDE VFD RATED CABLE. ROUTE CABLE THROUGH THE TERMINAL JUNCTION BOX (TJB) TO THE MCC CUBICLE.
- 5 PUMPS P-101, 102, 103: PROVIDE TERMINAL JUNCTION BOX (TJB) FOR MOTOR CABLE CONNECTIONS, NEMÁ 4X SS. PROVIDE PROPERLY SIZED JBOX, UL LISTED AS TERMINAL BOX, WITH FACTORY INSTALLED, RATED LUGS. MOUNT BOXES ON UNISTRUT SUPPORT STRUCTURE.
- 6 PROVIDE RECONNECTION TO (E) STANDBY GENERATOR SYSTEM.

NOTES

1

2

2

2

2

- 7) POWER MONITOR. SEE SPECIFICATIONS AND SHEET E-404 FOR DETAILS.
- 8 PROVIDE FULL VOLTAGE REVERSING (FVR) STARTERS AS BYPASS TO VFDs. UNITS WILL HAVE SEPARATE OVERCURRENT PROTECTION.

* 49 H	*
A Shaha A Basa	
John A. Pepe EE 11387 PROFESSIONAL	
PROFESSIONA	/16/2

E-LINE - NEW WORK

8

POWER

ОО

OJECT 1528.50233 TE 01/16/202

© DOWL 2023 SHEET

**BID SET** 

E-302

7.5 480 3 SEE POWER ONE-LINE UH-2 480 UH-3SEE POWER ONE-LINE 208 3/4"C, 2#10(2H), 1#12 EGC WH-1 4.1 I. (E) EQUIPMENT TO BE RECONNECTED. 2. PROVIDE VFD RATED CABLE

**EQUIPMENT SCHEDULE** 

CIRCUIT SIZE

3/4"C, 2#10(2H), 1#12 EGC

3/4"C, 2#10(2H), 1#12 EGC

3/4"C, 3#12(3H), 1#12 EGC

SEE POWER ONE-LINE

SEE POWER ONE-LINE

SEE POWER ONE-LINE

SEE POWER ONE-LINE

3/4"C, 2#12(H,N), 1#12 EGC

3/4"C, 2#12(H,N), 1#12 EGC

SEE POWER ONE-LINE

OUTER DRIVE 'MCC' ELEVATION SCALE: N/A

	CIRCUIT SCHEDULE
TAG	DESCRIPTION
1	4"C, 4#600 KCMIL (3H,N), 1#2 EGC
2	3"C, 4#350 KCMIL (3H,N), 1#4 EGC
3	3/4"C, 3#12 (3H). 1#12 EGC
4	2-1/2"C, 3#2/0 (3H). 1#4 EGC, VFD RATED
(5)	3/4"C, 2#12 (H,N). 1#12 EGC

## SHEET NOTES

- PROVIDE NEW SERVICE ENTRANCE CONDUCTORS AND EQUIPMENT. COORDINATE ALL WORK WITH SERVICE UTILITY (AEL&P) AS REQUIRED. INSTALLATION AND EQUIPMENT SHALL BE IN ACCORDANCE WITH AEL&P STANDARDS.
- 2 PROVIDE MAIN BUS WITH 100kA/PHASE AC SURGE PROTECTION MOUNTED IN THE MCB CABINET. SEE SPECIFICATIONS FOR DETAILS.
- (3) PROVIDE GROUNDING ELECTRODE SYSTEM (GES) IN ACCORDANCE WITH NEC 250. SEE DETAIL 1 ON SHEET E-305.
- 4 PUMPS P-201, 202: PROVIDE VFD RATED CABLE. ROUTE CABLE THROUGH THE TERMINAL JUNCTION BOX (TJB) TO THE MCC CUBICLE.
- PUMPS P-201, 202: PROVIDE TERMINAL JUNCTION BOX (TJB) FOR MOTOR CABLE CONNECTIONS, NEMA 4X SS. PROVIDE PROPERLY SIZED J-BOX, UL LISTED AS TERMINAL BOX, WITH FACTORY INSTALLED, RATED LUGS. MOUNT BOXES ON UNISTRUT SUPPORT STRUCTURE.
- PROVIDE RECONNECTION TO (E) STANDBY GENERATOR SYSTEM.
- $\begin{picture}(60,0)\put(0,0){\line(0,0){10}}\put(0,0){\line(0,0){10}$
- 8 PROVIDE FULL VOLTAGE REVERSING STARTERS (FVRS) AS BYPASS TO VFDs. UNITS WILL HAVE SEPARATE OVERCURRENT PROTECTION.

1 WJ POWER ONE-LINE - NEW WORK E-303) SCALE: NTS

SECTION 1	SECTION 2	SECTION 3	SECTION 4	SECTION 5	SECTION 6
1A	2A	3A	4A	5A	6A
MAIN	PANEL 'L'	VFD	FVR	VFD	6B
1B					6C
					6D
1C					6E
					VFD
1D	2B XFMR		4B		
1E			4C		6F
			FVR		
1F	2C				
1G					

SPACE	DESCRIPTION
1A	MAIN LUGS
1B	POWER MONITOR
1C	SPACE
1D	INSR
1E	ENPS
1F	ENET SWITCH
1G	SPACE
2A	PANEL 'L'
2B	XFMR
2C	SPACE
3A	PUMP P-201 VFD
4A	PUMP P-201 FVR WITH BYPASS
4B	SPACE
4C	PUMP P-202 FVR WITH BYPASS
5A	PUMP P-202 VFD
6A	UNIT HEATER UH-4 FCB
6B	UNIT HEATER UH-5 FCB
6C	UNIT HEATER UH-6 FCB
6D	BRIDGE CRANE BC-1 FCB
6E	EXHAUST FAN EF-2 VFD AND FCB
6F	SPACE

RIPTION	ELE	ECTRICAL EQUIPMENT SCHEDULE
	ITEM NO.	DESCRIPTION
	€1	METER BASE AND CT CABINET, NEMA 4X SS.
	E2>	MAIN CIRCUIT BREAKER (MCB). 300AT/400AF, 480V, 3Ø, ELECTRONIC TRIP WITH ADJUSTABLE LSIG AND ARC-HAZARD REDUCTION MAINTENANCE MODE, NEMA 4X SS.
	E3>	(E) STANDBY GENERATOR, 200KW/250KVA, 480V, 3ø, 60HZ. CUMMINS MODEL #DGFC
	E4>	AUTOMATIC TRANSFER SWITCH (ATS), 400A, 480V, 3ø, 4-WIRE, 3-POLE, NEMA 12
WITH BYPASS	E5	MOTOR CONTROL CENTER, 'MCC', 400A, 480V, 3ø, 4-WIRE, NEMA 12.
WITH BYPASS	<b>€</b> 6>	SCADA CONTROL PANEL 'SCP', 120V, NEMA 4X SS. SEE E-500 SERIES SHEETS FOR DETAILS.
	€7>	MCC MTD DRY-TYPE TRANSFORMER: 30KVA, 480:208Y/120V, 3ø, 4-WRE.
FCB	(E8)	MCC MOUNTED PANEL 'L'
5 FCB		225A, 208Y/120V, 3ø, 4-WIRE, 42-SPACE
5 FCB		
_1 FCB		

		EQU	IPMEN	IT SCHEDULE		
	LO	AD		CIDCUIT CITE	NOTES	
KW	HP	٧	PH	CIRCUIT SIZE	NO IES	
5		208	1	3/4"C, 2#10(2H), 1#12 EGC	1	
5		208	1	3/4"C, 2#10(2H), 1#12 EGC	1	
	5	480	3	SEE POWER ONE-LINE		
	1	480	3	SEE POWER ONE-LINE		
0.6		120	1	3/4"C, 2#12(H,N), 1#12 EGC	2	
	85	480	3	SEE POWER ONE-LINE	2	
	85	480	3	SEE POWER ONE-LINE	2	
	1/2	120	1	3/4"C, 2#12(H,N), 1#12 EGC		
	1/2	120	1	3/4"C, 2#12(H,N), 1#12 EGC		
10		480	3	SEE POWER ONE-LINE		
10		480	3	SEE POWER ONE-LINE		
3		480	3	SEE POWER ONE-LINE		
4.1		208	1	3/4"C, 2#10(2H), 1#12 EGC		
	5 5 0.6	KW HP 5 5 5 1 0.6 85 85 1/2 1/2 10 10 3	LOAD       KW     HP     V       5     208       5     208       5     480       0.6     120       85     480       1/2     120       1/2     120       10     480       10     480       3     480	LOAD         KW       HP       V       PH         5       208       1         5       208       1         5       480       3         0.6       120       1         85       480       3         1/2       120       1         1/2       120       1         10       480       3         3       480       3         3       480       3         3       480       3	KW         HP         V         PH         CIRCUIT SIZE           5         208         1         3/4"C, 2#10(2H), 1#12 EGC           5         208         1         3/4"C, 2#10(2H), 1#12 EGC           5         480         3         SEE POWER ONE—LINE           1         480         3         SEE POWER ONE—LINE           0.6         120         1         3/4"C, 2#12(H,N), 1#12 EGC           85         480         3         SEE POWER ONE—LINE           1/2         120         1         3/4"C, 2#12(H,N), 1#12 EGC           10         480         3         SEE POWER ONE—LINE           10         480         3         SEE POWER ONE—LINE           3         480         3         SEE POWER ONE—LINE	

NOTE

1. (E) EQUIPMENT TO BE RECONNECTED. 2. PROVIDE VFD RATED CABLE.

WEST JUNEAU 'MCC' ELEVATION
SCALE: N/A

BID SET

REV DATE DESCRIPTION

FORESSION 1/16/22



STATION REHABILITATION JUNEAU, AK

ONE-LINE - NEW WORK

**WJ POWER** 

PROJECT 1528.50233.
DATE 01/16/202

© DOWL 2023 SHEET

MIN. A.I.C. RATING: 65,000

6

8 10

12

14

16 18

26

28

30

TOTAL KVA (PHASE)

PHASE BALANCE, ABO

TOTAL AMPERES


PERCENT

6.5 7.0 3.9

23.5 25.3 14.2

A-B B-C C-A

VOLTAGE: 480



OD ELECTRICAL GROUNDING SCHEMATIC

E-304 SCALE: NTS

VO	LTAGE:	208Y/120							-5	_			MIN. A.I.C. RATING	10,000	
	BUS:	100				PANI	FL 'L'	SCHE	וטטב	.E			ENCLOSURE:	NEMA 1	1
Ì	MAIN:	100				LOCATION: OUTER DRIVE PUMP STATIO						ΓΑΤΙΩ	MOUNTING: SURFACE		
СКТ	AMP TRIP	LOAD	DESCRIP	TION			LOAD		В	С	LOAD			AMP TRIP	СКТ
1		LTG : EXTERIOR				0.5	L	1.0			R	0.5	RECEPT - GROUND LEVEL AND EXT.	20/1*	2
3	20/1	LTG : GROUND LEV	LEVEL		0.2	L		0.6		R	0.4	RECEPT - VALVE LEVEL	20/1*	4	
5	20/1	LTG: VALVE LEVE	L			0.2	L			0.6	R	0.4	RECEPT - PUMP LEVEL	20/1*	6
7	20/1	LTG: PUMP LEVEL				0.2	L	1.4			М	1.2	SUMP PUMP, SP-1A	20/1**	8
9	20/1	SCADA CONTROL	PANEL'	SCP'		0.5	С		1.7		М	1.2	SUMP PUMP, SP-1B	20/1**	10
11	20/1	GENSET DAMPER				0.1	М			1.7	LM	1.6	AIR COMPRESSOR NO. 1 (AC-1)	30/2	12
13	20/1	GENSET BAT CHAP	RGER/DA	AYTANK		0.5	С	2.1			LM	1.6	AIR COMI RESSOR NO. 1 (AC-1)	30/2	14
15	_	GENSET JACKET H				1.2	N		2.8		М	1.6	AIR COMPRESSOR NO. 2 (AC-2)	30/2	16
17	15/1	FLOW METER, FM	-201			0.1	С			1.7	М	1.6	AIR COMI RESSOR NO. 2 (AC-2)	30/2	18
19								2.0			N	2.0	WATER HEATER (WH-1)	30/2	20
21									2.0		N	2.0	WATER TEATER (WIFT)	30/2	22
23										0.0					24
25							0.0							26	
27								0.0						28	
29									0.0					30	
31							0.0							32	
33									0.0						34
35										0.0					36
37	,	SPARE						0.0					SPARE	20/1	38
39	-,	SPARE							0.0				SPARE	20/1	40
41	20/1	SPARE						<u> </u>	<u> </u>	0.0			SPARE	20/1	42
*	PROV	DE 5mA GFCI CIRC	UIT BRE	AKER				6.5	7.0	3.9	J		TOTAL KVA:	17.4	
**	PROV	DE 30mA GFCI EQI	JIPMEN	T CIRCU	IT BREA	KER							AMPS:	48.4	
				CONN	IECTED	KVA		TOT	NE.	C%					
SU	MMAR	Y BY LOAD TYPE	PHA	PHB	PHC	FE	ED	AL	INL	.070	NEC T	OTAL	NOTES:		
L	LIGHT	NG	0.7	0.2	0.2			1.1	1.	25	1.	4			
R	RECEP	TACLES	0.5	0.4	0.4			1.3	10K-	+50%	1.	.3			
M	MOTO	RS	1.2	2.8	1.7			5.7	1.	00	5.	.7			
LM	LARGE	ST MOTOR	1.6	0.0	1.6			3.1	1.	25	3.	9			
С	CONT	NUOUS	0.5	0.5	.5 0.1			1.1	1.	25	1.	4			
N	NON-	CONTINUOUS	2.0 3.2 0.0				5.2	1.	00	5.	2				
S	SPARE		0.0	0.0	0.0			0.0	1.	00	0.	.0			
Χ	NON-	COINCIDENT	0.0	0.0	0.0			0.0	0.	00	0.	.0			
0	OTHER	?	0.0	0.0	0.0			0.0	1.	00	0.	.0			
F	FEEDE	R	0.0	0.0	0.0			0.0	1.	00	0.	.0			
1		· ·													

18.8

22.6





AND DETAILS

SCHEDULES


ELEC

О

E-304

© DOWL 2023

									AMPS: 274.1
		CONNECTED KVA		TOTAL	NEC%				
SUN	IMARY BY LOAD TYPE	PHA	PHB	PHC	FEED	KVA	INLC/0	NEC TOTAL	NOTES:
L	LIGHTING	0.0	0.0	0.0		0.0	1.25	0.0	
R	RECEPTACLES	0.0	0.0	0.0		0.0	10K+50%	0.0	
M	MOTORS	32.1	32.1	32.1		96.3	1.00	96.3	
LM	LARGEST MOTOR	30.2	30.2	30.2		90.6	1.25	113.3	
С	CONTINUOUS	7.7	7.7	7.7		23.0	1.25	28.7	
N	NON-CONTINUOUS	0.0	0.0	0.0		0.0	1.00	0.0	
S	SPARE	0.0	0.0	0.0		0.0	1.00	0.0	
Χ	NON-COINCIDENT	0.0	0.0	0.0		0.0	0.00	0.0	
0	OTHER	0.0	0.0	0.0		0.0	1.00	0.0	
F	FEEDER	6.6	7.0	4.4		18.0	1.00	18.0	
TOTA	L KVA (PHASE)	76.6	77.0	74.4		209.9		238.3	
TOTA	L AMPERES	638.0	641.3	619.7		252.4		286.6	
PHAS	E BALANCE, ABC	A-B	B-C	C-A					
PFRCI	NT				Ì				





VO		208Y/120				PA	NEL 'L	' SCH	EDUL	.E			MIN. A.I.C. RATING	: 10,000	
	BUS:	100A											ENCLOSURE	: NEMA 1	L
	MAIN:	100A				LOCA	ATION:		WE	ST JUN	EAU PL	JMP ST	TATION MOUNTING	: SURFAC	Œ
СКТ	AMP TRIP	LOAD	DESCRIPT	TION		KVA	LOAD	Α	В	С	LOAD	KVA	LOAD DESCRIPTION	AMP TRIP	CKT
1	20/1	LTG : EXTERIOR				0.5	L	1.0			R	0.5	RECEPT - GROUND LEVEL AND EXT.	20/1*	2
3	20/1	LTG : GROUND LEV	/EL			0.2	L		0.6		R	0.4	RECEPT - VALVE LEVEL	20/1*	4
5	20/1	LTG: VALVE LEVEL	_			0.2	L			0.6	R	0.4	RECEPT - PUMP LEVEL	20/1*	6
7	20/1	LTG: PUMP LEVEL				0.2	L	1.4			М	1.2	SUMP PUMP, SP-2A	20/1**	8
9	20/1	SCADA CONTROL	PANEL'S	SCP'		0.5	С		1.7		М	1.2	SUMP PUMP, SP-2B	20/1**	10
11	20/1	GENSET DAMPER	PER		0.1	М			1.7	LM	1.6	AIR COMPRESSOR NO. 1 (AC-1)	30/2	12	
13	20/1	GENSET BAT CHAP	NSET BAT CHARGER/DAYTANK			0.5	С	2.1			LM	1.6	AIR COMPRESSOR NO. 1 (AC-1)	30/2	14
15	20/1	GENSET JACKET HI	EATER			1.2	N		2.8		М	1.6	AIR COMPRESSOR NO. 2 (AC-2)	20/2	30/2
17	20/1	(E) WALL MTD EXH	HAUST F	AN, EF-3	3	0.6	М			2.2	М	1.6	AIR COMFRESSOR NO. 2 (AC-2)	30/2	
19	15/1	FLOW METER, FM-	-201			0.1	С	2.1			N	2.0	WATER HEATER (WH-2)	30/2	20
21									2.0		N	2.0	WATER HEATER (WH-2)	30/2	22
23										0.0					24
25								0.0							26
27									0.0						28
29										0.0					30
31								0.0							32
33									0.0						34
35										0.0					36
37		SPARE						0.0					SPARE	20/1	38
39	_	SPARE							0.0				SPARE	20/1	40
41	20/1	SPARE								0.0			SPARE	20/1	42
*	DDO) //	DE E A CECI CIDO		AKED				6.6	7.0	4.4	ļ		TOTAL 10/A	40.0	
**		IDE 5mA GFCI CIRC			T DDE 4	/FD							TOTAL KVA		
	PRUV	IDE 30mA GFCI EQL	JIPIVIEN					тота	1		1		AMPS	: 50.1	
C.I.		V DV I O A D TVDE	DII A	PHB	PH C		- F.D.	TOTA	NE	C%	NECT	ОТ41	NOTES		
		Y BY LOAD TYPE	PH A 0.7	0.2	0.2	FE	ED	L KVA 1.1	<b>—</b>	25			NOTES:		
<u>L</u>	LIGHT	TACLES	0.7	0.2	0.2			1.1	_	25 +50%		.4			
R			1.2	2.8	2.3			6.3	_	00					
M	MOTO	_	1.6	0.0	1.6			3.1		25	_	.3 .9			
		ST MOTOR INUOUS	0.6	0.0	0.0			1.1		25 25	_	.4			
C			2.0	3.2	0.0			5.2		00	5.				
N S	SPARE	CONTINUOUS	0.0	0.0	0.0			0.0		00		.0			
X		COINCIDENT	0.0	0.0	0.0			0.0		00		.0			
0	OTHER		0.0	0.0	0.0			0.0		00		.0			
F	FEEDE		0.0	0.0	0.0			0.0		00	0.				
		PHASE)	6.6	7.0	4.4			18.0	1.			).4			
	_ KVA (		23.8	25.3	16.0			50.1			53				
_		NCE, ABC	25.6 A-B	25.3 B-C	C-A			30.1							
DEDC		NCL, ADC	A-D	B-C	C-A										

PERCENT





SCHEDULES AND DETAILS

ELEC

M

ROJECT 1528.50233 ATE 01/16/202

© DOWL 2023

E-305

TAG ID	SIGNAL CIRCUIT SIZE	DESTINATION	POWER CIRCUIT SIZE (IF REQUIRED)	DESTINATION	NOTES
AIT-201	CAT 6A	SCP	3/4"C, 2#14 (+24V,-0V), 1#14(G)	SCP	pH AND TEMP METE
EDCT-112	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			
EDCT-116	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			
ESD-101	3/4"C, 2#14 (SIG,COM), 1#14(G)	VFD			EM STOP
ESD-102	3/4"C, 2#14 (SIG,COM), 1#14(G)	VFD			EM STOP
ESD-103	3/4"C, 2#14 (SIG,COM), 1#14(G)	VFD			EM STOP
FIT-201	3/4"C, 1PR#18 TWSH	SCP	120VAC, 3/4"C, 2#14, 1#14(G)	SCP	
LAHH-421	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			CRITICAL W HIGH LEVE FLOAT
LEL-251	3/4"C, 1PR#18 TWSH	SCP		SCP	
LEL-252	3/4"C, 1PR#18 TWSH	SCP		SCP	
LAHH-101	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			SUMP HIG LEVEL
LT-401	3/4"C, 1PR#18 TWSH	SCP	3/4°C, 2#14 (+24V,-0V), 1#14(G)	SCP	PRIMARY W LEVEL SENSOR
LT-402A -402B -402C -402D -402E	1"C, 10#14 (10SIG,2COM), 1#14(G)	SCP			BACKUP W LEVEL SENSOR
PT-101	3/4"C, 1PR#18 TWSH	SCP			
PT-102	3/4"C, 1PR#18 TWSH	SCP			
PT-103	3/4"C, 1PR#18 TWSH	SCP			
SD-100 SD-101	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			SMOKE DETECTOR
SD-102 SD-103	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			SMOKE DETECTOR
TLSH-101 TSHW-101	3/4"C, 4PR#18 TWSH	MCC/SCP			PROTECTION
TLSH-102 TSHW-102 TSHU-102 TSHL-102	3/4"C, 4PR#18 TWSH	MCC/SCP			PROTECTION MODULES
TLSH-103 TSHW-103	3/4"C, 4PR#18 TWSH	MCC/SCP			PROTECTION MODULES
TT-120	3/4"C, 1PR#18 TWSH	SCP			STATION TEMP
TT-121	3/4"C, 1PR#18 TWSH	SCP			OUTSIDE TEMP
ZSN-500 ZSE-500 NCA-500	3/4"C, 8#14 (8SIG,8COM), 1#14(G)	SCP			ATS
YA-600 YS-600	3/4"C, 4#14 (2SIG,2COM), 1#14(G)	SCP			GENSET
YAL-200	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			ALARM STROBE
FS-120	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			EF FLOW SWITCH
ZS-100	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			INTRUSIO
ZSC-101 ZSO-101	3/4"C, 4#14 (2SIG,2COM), 1#14(G)	SCP			
ZSC-102 ZSO-102	3/4"C, 4#14 (2SIG,2COM), 1#14(G)	SCP			
ZSC-103 ZSO-103	3/4"C, 4#14 (2SIG,2COM), 1#14(G)	SCP			

			POWER CIRCUIT SIZE		
TAG ID	SIGNAL CIRCUIT SIZE	DESTINATION	(IF REQUIRED)	DESTINATION	NOTES
HS-101 YA-101 YS-101 RC-101	3/4"C, 8#14 (4SIG,4COM), 1#14(G)	SCP			PUMP P-101 VFD
HS-101 YA-101 YS-101 RC-102	3/4"C, 8#14 (4SIG,4COM), 1#14(G)	SCP			PUMP P-102 VFD
HS-103 YA-103 YS-103 RC-103	3/4"C, 8#14 (4SIG,4COM), 1#14(G)	SCP			PUMP P-103 VFD
ZSO-101	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			
ZSO-102	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			
ZSO-103	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			
OTE 1.	I			1	I

REVISIONS
REVISIONS
DESCRIPTION
B:



EDC, INC. 213 W. FREWED JAN ANCHORAGE, AK 995 (907) 276–7933 LICENSE NO. AECC?

OUTER DRIVE & WEST JUNEAU PUMP STATION REHABILITATION JUNEAU, AK OD INSTRUMENT CONNECTION SCHEDULE

PROJECT 1528.50233.0 DATE 01/16/2022

© DOWL 2023 SHEET

E-401

	WJ INS	TRUMENT CO	NNECTION SCHEDULE		
TAG ID	SIGNAL CIRCUIT SIZE	DESTINATION	POWER CIRCUIT SIZE (IF REQUIRED)	DESTINATION	NOTES
AIT-201	1PR#18 TWSH	SCP	3/4"C, 2#14 (+24V,-0V), 1#14(G)	SCP	pH AND TEMP METER
EDCT-112	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP		SCP	
EDCT-116	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			
ESD-201	3/4"C, 2#14 (SIG,COM), 1#14(G)	VFD			EM STOP
ESD-202	3/4"C, 2#14 (SIG,COM), 1#14(G)	VFD			EM STOP
FIT-201	3/4"C, 1PR#18 TWSH	SCP	120VAC, 3/4"C, 2#14, 1#14(G)	SCP	
LAHH-101	3/4"C, 2#14 (SIG,COM), 1#14(G)				
LAHH-421	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			CRITICAL HIGH LEVEL FLOAT
LEL-251	3/4"C, 1PR#18 TWSH	SCP		SCP	
LEL-252	3/4"C, 1PR#18 TWSH	SCP		SCP	
LT-401	3/4"C, 1PR#18 TWSH	SCP	3/4"C, 2#14 (+24V,-0V), 1#14(G)	SCP	PRIMARY WW LEVEL SENSOR
LT-402A -402B -402C -402D -402E	1"С, 10#14 (10SiG,2COM), 1#14(G)	SCP			BACKUP WW LEVEL SENSOR
PT-201	3/4"C, 1PR#18 TWSH	SCP			
PT-202	3/4"C, 1PR#18 TWSH	SCP			
SD-100 SD-101	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			SMOKE DETECTOR
SD-102 SD-103	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			SMOKE DETECTOR
TLSH-201 TSHW-201	3/4"C, 4#14 (2SIG,2COM), 1#14(G)	MCC/SCP			PUMP PROTECTION
TLSH-202 TSHW-202	3/4"C, 4#14 (2SIG,2COM), 1#14(G)	MCC/SCP			PUMP PROTECTION
TT-120	3/4"C, 1PR#18 TWSH	SCP			STATION TEMP
TT-121	3/4"C, 1PR#18 TWSH	SCP			OUTSIDE TEMP
ZSN-500 ZSE-500 NCA-500 ECA-500	3/4"C, 8#14 (8SIG,8COM), 1#14(G)	SCP			ATS
YA-600 YS-600	3/4"C, 4#14 (2SIG,2COM), 1#14(G)	SCP			GENSET
YAL-200	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			ALARM STROBE
FS-120	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			EF FLOW SWITCH
ZS-100	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			INTRUSION
ZSC-201 ZSO-201	3/4"C, 4#14 (2SIG,2COM), 1#14(G)	SCP			
ZSC-202 ZSO-202	3/4"C, 4#14 (2SIG,2COM), 1#14(G)	SCP			
NOTE 1. NOTE 2.				•	

	OD INST	TRUMENT CO	ONNECTION SCHEDULE		
TAG ID	SIGNAL CIRCUIT SIZE	DESTINATION	POWER CIRCUIT SIZE (IF REQUIRED)	DESTINATION	NOTES
HS-201 YA-201 YS-201 RC-201	3/4"C, 8#14 (4SIG,4COM), 1#14(G)	SCP			PUMP P-201 VFD
HS-202 YA-202 YS-202 RC-202	3/4"C, 8#14 (4SIG,4COM), 1#14(G)	SCP			PUMP P-202 VFD
ZS0-201	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			
ZS0-202	3/4"C, 2#14 (SIG,COM), 1#14(G)	SCP			
NOTE 1. NOTE 2.				1	






WJ INSTRUMENT CONNECTION SCHEDULE

PROJECT 1528.50233. DATE 01/16/2022

E-402



SHEET NOTES

ALLEN BRADLEY E300 ELECTRONIC OVERLOADS.

REVISIONS
DATE DESCRIPTION



EDC., INC.
213 W. REWED LAVE
ANCHORACE, AK 99503
(907) 276–7933
LICENSE NO. AECC705





OUTER DRIVE & WEST JUNEAU PUMP STATION REHABILITATION JUNEAU, AK TYPICAL MOTOR STARTER ELEMENTARY DIAGRAMS

PROJECT 1528.50233. DATE 01/16/2023

> © DOWL 2023 SHEET

E-404





BILL OF MATERIALS								
ITEM	QTY DESCRIPTION OR EQUAL							
1	AS REQUIRED	ALLEN BRADLEY 1769-L33ER-2MB COMPACT LOGIC PROCESSOR (CPU).						
2	AS REQUIRED	1769-IA16 ALLEN BRADLEY - COMPACT LOGIX 16 POINT, 120VAC DISCRETE INPUT MODULE.						
3	AS REQUIRED	ALLEN BRADLEY 1769-PA4, 120VAC: 24VDC POWER SUPPLY.						
4	AS REQUIRED	ALLEN BRADLEY 1769—IF8 COMPACT LOGIX 8 POINT ANALOG INPUT MODULE.						
(5)	1	LTE CELLULAR GATEWAY ROUTER - SIERRA WIRELESS RV50X						
6	AS REQUIRED	PANDUIT - WIRE DUCT, ANALOG WIRING.						
7	AS REQUIRED	PANDUIT - WIRE DUCT, DISCRETE WIRING.						
8	AS REQUIRED	ENTRELEC – DIN RAIL.						
9	1	HOFFMAN — NEMA TYPE 4X WALL MOUNTED WITH BACK PANEL. SIZE AS REQUIRED.						
10	AS REQUIRED	ALLEN BRADLEY — 1492AIFM8—F—5 ANALOG INPUT WIRING MODULE.						
11)	AS REQUIRED	ALLEN BRADLEY - 1492-ACAB-ED69 CABLE ASSEMBLY.						
12	AS REQUIRED	ENTRELEC - GMUXXT - DIN RAIL MOUNTED CIRCUIT BREAKER.						
13)	AS REQUIRED	ENTRELEC - M 4/8.SF FUSED TERMINAL BLOCK						
14)	AS REQUIRED	DISCRETE OUTPUT WIRING MODULE W/ (16) 120VAC FUSED RELAYS, ALLEN BRADLEY - 1492-XIM20120-16RF						
15)	AS REQUIRED	ALLEN BRADLEY - 1492-CAB-H69 CABLE ASSEMBLY.						
16)	AS REQUIRED	HOFFMAN - PANELLITE LEDA1S35 - 120VAC LED LIGHT.						
17	AS REQUIRED	ALLEN BRADLEY 1492—RIFM20F—F120A02 — DISCRETE INPUT WIRING MODULE WITH FUSIBLE INPUTS AND REMOVABLE FIELD TERMINALS.						
18	AS REQUIRED	ALLEN BRADLEY 1492-CAB-A69 CABLE ASSEMBLY.						
19	AS REQUIRED	MAINTAIN MANUFACTURER'S CLEARANCES AROUND THE PLC.						
20	AS REQUIRED	PROVIDE PHENOLIC TAG. BLACK LETTERS ON WHITE BACKGROUND. TEXT SHALL BE 0.75".						
21)	AS REQUIRED	INDUSTRIAL PC, HUMAN-MACHINE INTERFACE (HMI) PANEL. CONNECT CAT-6A PATCH CABLE FROM GATEWAY. SEE SHEETS E-504 AND E-505 FOR DETAILS.						
22	AS REQUIRED	QUINT4 - PS/1AC/24DC/5 - 2866750 24VDC POWER SUPPLY (5A).						
23	AS REQUIRED	1769-0A16 ALLEN BRADLEY. COMPACTLOGIX 16-POINT DISCRETE OUTPUT MODULE.						
24)	AS REQUIRED	120V, 20A, SURGE SUPRESSOR AND FILTER. ALLEN BRADLEY-4983-DC120-20.						
25)	AS REQUIRED	1769-ECL RIGHT END CAP.						
26	1	20A, 120V, DUPLEX RECEPTACLE. DIN RAIL MOUNT.						
27	1	ALLEN BRADLEY PANEL MOUNT INDICATOR LIGHT 800L, 30MM, 24 AC/DC.						
28	AS REQUIRED	GROUND BAR.						
29	1	ALARM HORN, 120V, FEDERAL SIGNAL MODEL 350-120-30						
30	1	NORMALLY OPEN PUSHBUTTON, 30MM, NEMA 4/13, BLACK, ALLEN BRADLEY CAT# 800TA2A.						
31)	1	120V, 2000VA, UPS, LIEBERT MODEL# GXT4-2000RT120.						

49 IH A Page EE 11387

OD AND WJ PANEL LAYOUT AND EQUIPMENT LIST

ROJECT 1528.50233. ATE 01/16/202

© DOWL 2023 SHEET

E-501

OD AND WJ PANEL LAYOUT AND EQUIPMENT LIST SCALE: NTS

#### **OUTER DRIVE PUMP STATION FUNCTIONAL NARRATIVES**

#### LIFT PUMP OPERATION

PUMPS P-101, P-102 AND P-103 ARE CONTROLLED BY THE PLC IN THE SCADA CONTROL PANEL 'SCP'. EACH PUMP IS EQUIPPED WITH HAND-OFF-AUTO CONTROLS AT THE VFD ENCLOSURE. EACH PUMP HAS THE FOLLOWING FAILURE/FAULT ALARMS WHICH WILL SHUT DOWN THE PUMP: OVERCURRENT, OVER/UNDER VOLTAGE, PHASE LOSS, WINDING OVER-TEMPERATURE AND HIGH BEARING TEMPERATURE (P-102). THE PUMPS WILL BE CONTROLLED AS FOLLOWS:

- 1) IN HAND MODE: THE PUMP RUNS CONTINUOUSLY AT A PRE-SET RPM (FULL SPEED AT 60 HZ, MINIMUM SPEED IS 42 HZ) UNLESS A PUMP FAILURE/FAULT ALARM CONDITION OCCURS, IN WHICH CASE THE VFD WILL INITIATE THE SHUTDOWN SEQUENCE:
  - THE VFD WILL REDUCE PUMP SPEED FROM THE MANUAL SETPOINT DOWN TO 45 HZ OVER A FIVE (5) SECOND PERIOD (OPERATOR ADJUSTABLE 2-10 SECONDS), AND UPON REACHING 45 HZ THE PUMP WILL BE SHUT DOWN.
- 2) IN OFF MODE: THE PUMP WILL NOT RUN
  - WHEN THE PUMP IS RUNNING AND MANUALLY SWITCHED TO THE "OFF" MODE, THE VFD WILL ENTER A PROGRAMMED VFD SHUTDOWN SEQUENCE DESCRIBED ABOVE.
- 3) IN AUTO MODE:
  - THE PUMPS WILL START IN A STAGED, LEAD-LAG-STANDBY, PUMPING SEQUENCE BASED ON LIQUID LEVEL IN THE WET WELL, AS SENSED BY THE PRIMARY LEVEL TRANSMITTER LT-401 AND THE BACKUP LEVEL TRANSMITTER LT-402. INITIALLY, P-101 = LEAD, P-102 = LAG/STANDBY (FOR DRY WEATHER CONDITIONS) AND PUMP P-103 = STANDBY (FOR WET WEATHER CONDITIONS).
  - FOR DRY WEATHER CONDITIONS, PUMPS P-101 AND P-103 WILL ALTERNATE BETWEEN 'LEAD' AND 'LAG' AFTER EACH PUMP CYCLE TO EQUALIZE WEAR ON THE PUMP EQUIPMENT. PUMP P-102 WILL REMAIN ON 'STANDBY' UNTIL IT IS CALLED ON EITHER MANUALLY OR BY THE SCADA CONTROL PANEL 'SCP' IF THE CAPACITY OF PUMPS P-101 AND P-103 ARE EXCEEDED. IT WILL OPERATE INDEPENDENTLY OF P-101 AND P-103. THE PUMP LEAD/LAG SETTINGS SHALL BE OPERATOR ADJUSTABLE THROUGH EACH OF THE HUMAN-MACHINE INTERFACES (HMI'S) LOCATED AT THE STATION SCP.
  - THE SCADA CONTROL PANEL 'SCP' WILL CONTROL THE LIFT PUMPS BASED ON THE FOLLOWING PROGRAMMED SEQUENCE:
    - 1. AS THE LIQUID LEVEL IN THE WET WELL RISES ABOVE THE "LEAD PUMP START" SETPOINT, THE LEAD PUMP WILL START AND RAMP FROM 0 TO 60 HZ IN FIVE (5) SECONDS, IT WILL THEN RUN AT FULL SPEED (60HZ) FOR A TEN (10) SECOND FLUSHING PERIOD.
    - 2. FOLLOWING THIS FLUSHING PERIOD, THE PUMP WILL RAMP DOWN TO 45 HZ OVER A FIVE (5) SECOND PERIOD AND MAINTAIN THIS SPEED UNTIL THE 'LEAD PUMP HIGH' (WET WELL RISING) OR 'LEAD/LAG PUMP OFF' (WET WELL FALLING) SET POINT LEVEL IS REACHED.
    - 3. IF THE LIQUID IN THE WET WELL REACHES THE 'LEAD PUMP HIGH' SET POINT AND CONTINUES RISING TO THE 'LAG PUMP START' SET POINT, THE LEAD PUMP WILL RAMP TO FULL SPEED AND THE LAG PUMP WILL START AND RAMP TO FULL SPEED OVER A FIVE (5) SECOND PERIOD (OPERATOR ADJUSTABLE 2-10 SECONDS) UNTIL EITHER THE 'LEAD PUMP START' (WET WELL FALLING) OR 'HIGH HIGH' (WET WELL RISING) SET POINT IS REACHED.
    - 4. IF THE 'LEAD PUMP START' SET POINT IS REACHED (WET WELL FALLING), THE LAG PUMP WILL BEGIN IT'S SHUTDOWN SEQUENCE. WHEN THE 'LEAD/LAG OFF' SET POINT IS REACHED, BOTH PUMPS WILL BE OFF WHEN THIS LEVEL IS REACHED.
    - 5. IF THE 'HIGH HIGH' SETPOINT IS REACHED, BOTH THE LEAD AND LAG (DRY WEATHER PUMPS) WILL START THE SHUTDOWN SEQUENCE AND P-102 WILL RAMP FROM 0 TO 60HZ IN FIVE (5) SECONDS FOR A TEN (10) SECOND FLUSHING PERIOD. P-102 WILL THEN RAMP DOWN TO 45 HZ OVER A FIVE (5) SECOND PERIOD (OPERATOR ADJUSTABLE 2-10 SECONDS).
    - 6. WHEN THE LIQUID LEVEL IN THE WET WELL REACHES THE 'LEAD ON' SET POINT THE VFD WILL INITIATE THE SHUTDOWN SEQUENCE OF RAMPING DOWN FROM 45 HZ TO ZERO IN A 5 SECOND (OR AS REQUIRED) PERIOD TO PREVENT UNWANTED HYDRAULIC SURGE. PUMP P-102 WILL BE OFF WHEN THE 'LEAD /LAG OFF' LEVEL IS REACHED.
    - 7. REFERENCE GENERAL SHEET G-003 FOR FURTHER PUMP SEQUENCE DETAILS.
  - d. IF THE LIQUID IN THE WET WELL REACHES THE 'LOW ALARM' SET POINT, AN ALARM WILL INDICATE CRITICAL LOW WATER LEVEL AND ANY PUMP REMAINING IN OPERATION WILL IMMEDIATELY BEGIN A SHUTDOWN SEQUENCE.

#### STATION OPERATION ALARMS

THE STATION ALARMS SENT TO OPERATORS VIA SCADA SHALL INCLUDE BUT ARE NOT LIMITED TO:

-WET WELL: HIGH HIGH LEVEL (LAHH 421)

-WET WELL: CRITICAL LOW LEVEL

-LIFT PUMP P-101 MOTOR FAULT (OVER-TEMP, SEAL-FAIL)

-LIFT PUMP P-101 VFD FAULT

-LIFT PUMP P-102 FAULT (OVER-TEMP, SEAL-FAIL, BEARING TEMP)

-LIFT PUMP P-102 VFD FAULT

-LIFT PUMP P-103 FAULT (OVER-TEMP, SEAL-FAIL)

-LIFT PUMP P-103 VFD FAULT

-DRY WELL: PUMP LEVEL FLOOD CRITICAL HIGH LEVEL (LAHH-101)

-DRY WELL: SMOKE DETECTED (SD-101, 102, 103, 104)

-DRY WELL: GENERATOR FAULT, FAILURE TO START (YA-600)

-DRY WELL: LEL EXPLOSIVE GAS DETECTION (ABOVE SAFE LEVEL)

-BUILDING: LOW TEMPERATURE & INTRUSION

-BUILDING: EXHAUST FAN FAILURE

#### **BUILDING EXHAUST FAN OPERATION**

THE STATION VENTILATION FAN (EF-1) SHALL BE CONTROLLED BY THE PLC VIA A VARIABLE FREQUENCY DRIVE (VFD) MOUNTED IN THE MCC. CONTROL INPUTS SHALL INCLUDE A DUCT-MOUNTED FLOW SWITCH (FS-120) ON THE GROUND LEVEL AND AN OUTSIDE AMBIENT TEMPERATURE SENSOR (TT-121). THE VENTILATION SYSTEM SHALL HAVE A SCREEN IN THE HMI THAT INCLUDES STATUS AND MODE CHANGES VIA THE TOUCH SCREEN FOR CONTROL OF THE EXHAUST FAN. THE FAN SHALL BE CONTROLLED AS FOLLOWS:

#### IN 'MANUAL' MODE:

- a. THE FAN WILL RAMP UP TO TO FULL SPEED (AT 60 HZ) AND RUN CONTINUOUSLY UNTIL THE SWITCH IS MOVED TO 'OFF' OR 'AUTO'
- IF A FAILURE/FAULT ALARM CONDITION OCCURS, THE VFD WILL SHUTDOWN AND PRODUCE AN ALARM TO NOTIFY STATION PERSONNEL
- 2) IN 'OFF' MODE: THE FAN SHALL NOT RUN:
  - a. WHEN THE FAN IS RUNNING AND MANUALLY SWITCHED TO THE 'OFF' MODE, THE VFD WILL SHUTDOWN.

## 3) IN 'AUTO' MODE:

HIGH VENTILATION RATE: WHEN IN OCCUPIED MODE (SEE OCCUPANCY STATUS BELOW), THE FAN WILL RAMP TO FULL SPEED (AT 60 HZ) - A VENTILATION RATE OF 6 AIR CHANGES PER HOUR.

- a. AFTER 30 SECONDS, IF THE FAN HIGH SPEED OPERATION RUNNING SIGNAL SWTCH (FS-120) DOES NOT CLOSE TO VERIFY THE SYSTEM IS IN HIGH SPEED OPERATION, AN EXHAUST FAN HIGH SPEED FAILURE ALARM IS GENERATED THROUGH THE SCADA PANEL.
- b. THE FAN WILL RUN AT THE HIGH VENTILATION RATE UNTIL THE LIFT STATION IS UNOCCUPIED AS DESCRIBED BELOW.

#### LOW VENTILATION RATE:

- a. IF THE OUTSIDE TEMPERATURE (TT 121) IS 50 DEG F OR BELOW AND THE LIFT STATION IS UNOCCUPIED, THE FAN SHALL RUN AT THE LOW VENTILATION RATE OR 50% OF THE HIGH VENTILATION RATE (3 AIR CHANGES PER HOUR)
- b. IF THE OUTSIDE TEMPERATURE RISES ABOVE 50 DEG F OR THE LIFT STATION BECOMES OCCUPIED. THE SYSTEM SHALL RAMP BACK UP TO THE FULL SPEED 'HIGH' VENTILATION RATE.

#### OCCUPANCY STATUS

WHEN THE LIFT STATION DOOR IS OPENED (AS SENSED BY THE DOOR INTRUSION SWITCH (ZS-100)) A TIMER STARTS AND AN INTRUSION ALARM WILL BE GENERATED UNLESS THE OPERATOR ENTERS AN ACCESS CODE INTO THE CONTROL SYSTEM AT THE SCADA CONTROL PANEL'S HMI BEFORE THE TIMER TIMES OUT. THE OPERATOR SHALL ALSO ENTER AN ANTICIPATED OCCUPANCY TIME NOT TO EXCEED 8-HOURS. THE CONTROL SYSTEM SHALL INDICATE THAT THE LIFT STATION IS OCCUPIED UNTIL THE OCCUPANCY TIMER TIMES OUT. THE STATUS OF THE DOOR INTRUSION SWITCH WILL BE IGNORED DURING THIS TIME. ONCE THE OCCUPANCY TIMER TIMES OUT, THE CONTROL SYSTEM SHALL INDICATE THAT THE LIFT STATION IS UNOCCUPIED AND THE DOOR INTRUSION SWITCH WILL BE MONITORED FOR THE NEXT EVENT. THE OPERATOR MAY ALSO PLACE THE OCCUPANCY STATUS TO UNOCCUPIED AT THE HMI PRIOR TO LEAVING WHICH WILL REDUCE THE REMAINING TIME ON THE OCCUPANCY TIMER TO 2 MINUTES ALLOWING THE OPERATOR TIME TO LEAVE BEFORE RE-ACTIVATING THE DOOR SWITCH.







NARRATIVE

FUNCTIONAL

© DOWL 2023

## WEST JUNEAU PUMP STATION FUNCTIONAL NARRATIVES

#### LIFT PUMP OPERATION

PUMPS P-201, P-202 ARE CONTROLLED BY THE PLC IN THE SCADA CONTROL PANEL 'SCP'. EACH PUMP IS EQUIPPED WITH HAND-OFF-AUTO CONTROLS AT THE VFD ENCLOSURE. EACH PUMP HAS THE FOLLOWING FAILURE/FAULT ALARMS WHICH WILL SHUT DOWN THE PUMP: OVERCURRENT, OVER/UNDER VOLTAGE, PHASE LOSS, SEAL-FAIL, AND WINDING OVER-TEMPERATURE. THE PUMPS WILL BE CONTROLLED AS FOLLOWS:

- 1) IN HAND MODE: THE PUMP RUNS CONTINUOUSLY AT A PRE-SET RPM (FULL SPEED AT 60 HZ, MINIMUM SPEED IS 42 HZ) UNLESS A PUMP FAILURE/FAULT ALARM CONDITION OCCURS, IN WHICH CASE THE VFD WILL INITIATE THE SHUTDOWN SEQUENCE:
  - a. THE VFD WILL REDUCE PUMP SPEED FROM THE MANUAL SETPOINT DOWN TO 45 HZ OVER A FIVE (5) SECOND PERIOD (OPERATOR ADJUSTABLE 2-10 SECONDS), AND UPON REACHING 45 HZ THE PUMP WILL BE SHUT DOWN.
- 2) IN OFF MODE: THE PUMP WILL NOT RUN
  - a. WHEN THE PUMP IS RUNNING AND MANUALLY SWITCHED TO THE "OFF" MODE, THE VFD WILL ENTER A PROGRAMMED VFD SHUTDOWN SEQUENCE DESCRIBED ABOVE.
- 3) IN AUTO MODE:
  - a. THE PUMPS WILL START IN A STAGED, LEAD-LAG, PUMPING SEQUENCE BASED ON LIQUID LEVEL IN THE WET WELL, AS SENSED BY THE PRIMARY LEVEL TRANSMITTER LT-401 AND THE BACKUP LEVEL TRANSMITTER LT-402. INITIALLY, P-201 = LEAD, P-202 = LAG/STANDBY.
  - b. PUMPS P-201 AND P-202 WILL ALTERNATE BETWEEN 'LEAD' AND 'LAG' AFTER EACH PUMP CYCLE TO EQUALIZE WEAR ON THE PUMP EQUIPMENT. THE PUMP LEAD/LAG SETTINGS SHALL BE OPERATOR ADJUSTABLE THROUGH EACH OF THE HUMAN-MACHINE INTERFACE (HMI) LOCATED AT THE STATION SCP.
  - c. THE SCADA CONTROL PANEL 'SCP' WILL CONTROL THE LIFT PUMPS BASED ON THE FOLLOWING PROGRAMMED SEQUENCE:
    - 1. AS THE LIQUID LEVEL IN THE WET WELL RISES ABOVE THE "LEAD PUMP ON" SET POINT, THE LEAD PUMP WILL START AND RAMP FROM 0 TO 60 HZ IN FIVE (5) SECONDS, IT WILL THEN RUN AT FULL SPEED (60HZ) FOR A TEN (10) SECONDS FLUSHING PERIOD.
    - FOLLOWING THIS FLUSHING PERIOD, THE PUMP WILL RAMP DOWN TO 45 HZ OVER A FIVE (5) SECOND PERIOD
      AND MAINTAIN THIS SPEED UNTIL THE 'LAG PUMP ON' (WET WELL RISING) OR THE 'LEAD PUMP OFF' SET POINT
      LEVEL IS REACHED.
    - 3. IF THE LIQUID IN THE WET WELL (CONTINUES TO RISE) REACHES THE 'LAG PUMP ON' SET POINT, THE LAG PUMP WILL START AND RAMP TO FULL SPEED OVER A FIVE (5) SECOND PERIOD (OPERATOR ADJUSTABLE 2-10 SECONDS) UNTIL EITHER THE 'LAG OFF' (WET WELL FALLING) OR 'HIGH ALARM' (WET WELL RISING) SET POINT IS REACHED.
    - 4. IF THE 'LAG OFF' SET POINT IS REACHED (WET WELL FALLING), THE LAG PUMP WILL BEGIN IT'S SHUTDOWN SEQUENCE. WHEN THE 'LEAD OFF' SET POINT IS REACHED (WET WELL FALLING), BOTH PUMPS WILL BE OFF.
    - 5. IF THE 'HIGH ALARM' SET POINT IS REACHED AND BOTH LEAD AND LAG PUMPS ARE RUNNING AT FULL
    - 6. SPEED THE PLC WILL GENERATE AN ALARM AND SEND TO OPERATORS VIA SCADA FOR IMMEDIATE ATTENTION.
    - 7. REFERENCE GENERAL SHEET G-003 FOR FURTHER PUMP SEQUENCE DETAILS.
  - d. IF THE LIQUID IN THE WET WELL REACHES THE 'LOW ALARM' SET POINT, AN ALARM WILL INDICATE CRITICAL LOW WATER LEVEL AND ANY PUMP REMAINING IN OPERATION WILL IMMEDIATELY BEGIN A SHUTDOWN SEQUENCE.

#### STATION OPERATION ALARMS

THE STATION ALARMS SENT TO OPERATORS VIA SCADA SHALL INCLUDE BUT ARE NOT LIMITED TO:

- -WET WELL: CRITICAL HIGH LEVEL (LAHH 421)
- -WET WELL: CRITICAL LOW LEVEL
- -LIFT PUMP P-201 MOTOR FAULT (OVER-TEMP, SEAL-FAIL)
- -LIFT PUMP P-201 VFD FAULT
- -LIFT PUMP P-202 FAULT (OVER-TEMP, SEAL-FAIL, BEARING TEMP)
- -LIFT PUMP P-202 VFD FAULT
- -DRY WELL: PUMP LEVEL FLOOD CRITICAL HIGH LEVEL (LSHH-101)
- -DRY WELL: SMOKE DETECTED (SD-101, 102, 103, 104)
- -DRY WELL: GENERATOR FAULT, FAILURE TO START (YA-600)
- -DRY WELL: LEL EXPLOSIVE GAS DETECTION (ABOVE SAFE LEVEL)

#### BUILDING EXHAUST FAN OPERATION

THE STATION VENTILATION FAN (EF-2) SHALL BE CONTROLLED BY THE PLC VIA A VARIABLE FREQUENCY DRIVE (VFD) MOUNTED IN THE MCC. CONTROL INPUTS SHALL INCLUDE A DUCT-MOUNTED FLOW SWITCH (FS-120) ON THE GROUND LEVEL AND AN OUTSIDE AMBIENT TEMPERATURE SENSOR (TT-121). THE VENTILATION SYSTEM SHALL HAVE A SCREEN IN THE HMI THAT INCLUDES STATUS AND MODE CHANGES VIA THE TOUCH SCREEN FOR CONTROL OF THE EXHAUST FAN. THE FAN SHALL BE CONTROLLED AS FOLLOWS:

#### IN 'MANUAL' MODE:

- a. THE FAN WILL RAMP UP TO TO FULL SPEED (AT 60 HZ) AND RUN CONTINUOUSLY UNTIL THE SWITCH IS MOVED TO 'OFF' OR 'AUTO'
- b. IF A FAILURE/FAULT ALARM CONDITION OCCURS, THE VFD WILL SHUTDOWN AND PRODUCE AN ALARM TO NOTIFY STATION PERSONNEL VIA SCADA.
- 2) IN 'OFF' MODE: THE FAN SHALL NOT RUN:
  - a. WHEN THE FAN IS RUNNING AND MANUALLY SWITCHED TO THE 'OFF' MODE, THE VFD WILL SHUTDOWN.

#### 3) IN 'AUTO' MODE:

HIGH VENTILATION RATE: WHEN IN OCCUPIED MODE (SEE OCCUPANCY STATUS BELOW), THE FAN WILL RAMP TO FULL SPEED (AT 60 HZ) — A VENTILATION RATE OF 6 AIR CHANGES PER HOUR.

- a. AFTER 30 SECONDS, IF THE FAN HIGH SPEED OPERATION RUNNING SIGNAL SWTCH (FS-120) DOES NOT CLOSE TO VERIFY THE SYSTEM IS IN HIGH SPEED OPERATION, AN EXHAUST FAN HIGH SPEED FAILURE ALARM IS GENERATED THROUGH THE SCADA PANEL.
- b. THE FAN WILL RUN AT THE HIGH VENTILATION RATE UNTIL THE LIFT STATION IS UNOCCUPIED AS DESCRIBED BELOW.

## LOW VENTILATION RATE:

- a. IF THE OUTSIDE TEMPERATURE (TT 121) IS 50 DEG F OR BELOW AND THE LIFT STATION IS UNOCCUPIED, THE FAN SHALL RUN AT THE LOW VENTILATION RATE OR 50% OF THE HIGH VENTILATION RATE (3 AIR CHANGES PER HOUR).
- b. IF THE OUTSIDE TEMPERATURE RISES ABOVE 50 DEG F OR THE LIFT STATION BECOMES OCCUPIED, THE SYSTEM SHALL RAMP BACK UP TO THE FULL SPEED 'HIGH' VENTILATION RATE.

#### OCCUPANCY STATUS

WHEN THE LIFT STATION DOOR IS OPENED (AS SENSED BY THE DOOR INTRUSION SWITCH (ZS-100)) A TIMER STARTS AND AN INTRUSION ALARM WILL BE GENERATED UNLESS THE OPERATOR ENTERS AN ACCESS CODE INTO THE CONTROL SYSTEM AT THE SCADA CONTROL PANEL'S HMI BEFORE THE TIMER TIMES OUT. THE OPERATOR SHALL ALSO ENTER AN ANTICIPATED OCCUPANCY TIME NOT TO EXCEED 8-HOURS. THE CONTROL SYSTEM SHALL INDICATE THAT THE LIFT STATION IS OCCUPIED UNTIL THE OCCUPANCY TIMER TIMES OUT. THE STATUS OF THE DOOR INTRUSION SWITCH WILL BE IGNORED DURING THIS TIME. ONCE THE OCCUPANCY TIMER TIMES OUT, THE CONTROL SYSTEM SHALL INDICATE THAT THE LIFT STATION IS UNOCCUPIED AND THE DOOR INTRUSION SWITCH WILL BE MONITORED FOR THE NEXT EVENT. THE OPERATOR MAY ALSO PLACE THE OCCUPANCY STATUS TO UNOCCUPIED AT THE HMI PRIOR TO LEAVING WHICH WILL REDUCE THE REMAINING TIME ON THE OCCUPANCY TIMER TO 2 MINUTES ALLOWING THE OPERATOR TIME TO LEAVE BEFORE RE-ACTIVATING THE DOOR SWITCH.







DRIVE & WEST JUNEAU F TATION REHABILITATION JUNEAU, AK NARRATIVE

FUNCTIONAL

JECT 1528.5023

© DOWL 2023

E-503


REF PART NUMBER MFGR MODULE USE / TYPE  1 1769-L30ER-2MB AB COMPACT LOGIX CENTRAL PROCESSOR (CPU)  2 1769-IA16 AB 16-POINT DISCRETE INPUT MODULE  3 1769-PA4 AB 120VAC: 24VDC POWER SUPPLY  4 1769-OA16 AB 16-POINT DISCRETE OUTPUT MODULE  5 1769-IF8 AB 8-POINT ANALOG INPUT MODULE  6 1769-ECR AB RIGHT END CAP  1 1783 STRATIX 5700 AB 10-PORT NETWORK SWITCH (MANAGED)  8 1783 STRATIX 5700 AB 4-PORT NETWORK SWITCH (MANAGED)	REF PART NUMBER  9 6300P-XXXB  10 RV50X  11 A-OMNI-292-V2  12 -  13 -  14 -  15 -	MFGR MODULE USE / TYPE  AB INDUSTRIAL PC, WINDOWS 10 / 11 OS, MINIMUM 128GB SSD, 15 PROCESSOR, 8GB SO-DIMM DDR4 RAM  SIERRA WL LTE CELLULAR GATEWAY ROUTER  POYNTING 2.4GHZ LTE CELLUAR OMNI-DIRECTIONAL ANTENNA  AB POWER MONITOR - SEE SHEET E-404  POLYPHASER LIGHTNING ARRESTOR  CAT6A ETHERNET CABLE, 4PR, RJ45	REF PART NUMBER  [6] - [7] SC4500  [8] - [9] - [20] - [21] - [22] - [23] -	MFGR MODULE USE / TYPE  - 50 OHM COAXIAL CABLE, EXTERIOR RATED  HACH DIGITAL CONTROLLER, RJ45 ETHERNET (10/100 Mbps). pH AND TEMPERATURE METER	BE OF ADEQUATE HEIGHT AND POSITION TO ALLOW FOR OPTIMAL SIGNAL RECEPTION AND TRANSMISSION OVER THE CELLULAR SCADA NETWORK. COORDINATE THE INSTALLATION AND TESTING OF THE COMMUNICATIONS SYSTEM WITH CBJ SCADA PERSONNEL.	DATE DESCRIPTION E
MOTOR CONTROL CENTER 'MCC'  MOTOR CONTROL CENTER 'MCC'	OLLER -201  T 10/10  GROUND -OVDC DC	CCP/IP  OO BASET  TCP/IP  10/100 BASET	<b>1991</b>	L PANEL 'SCP'  3  4  5  6  PLC RACK 00	CELLULAR SERVICE CONNECTION ANTENNA  SPACED MIN. 4'-0" APART  10  13  13	213 W. HEWED LANE ANCHORAGE, K. 99503 LICENSE NO. AECC705
NED P-103   VFD P-102   VFD P-101   PM   Stations/Dwgs/Elec/E-504 00 Ptc Block Divisions (Dwgs/Midwg)   Published Prince and West Juneau Lift Stations/Dwgs/Elec/E-504 00 Ptc Block Divisions (Dwgs/Midwg)   Philipped Prince and West Juneau Lift Stations/Dwgs/Elec/E-504 00 Ptc Block Divisions (Dwgs/Midwg)   Philipped Prince and West Juneau Lift Stations/Dwgs/Elec/E-504 00 Ptc Block Divisions (Dwgs/Midwg)   Philipped Prince and West Juneau Lift Stations/Dwgs/Elec/E-504 00 Ptc Block Divisions (Dwgs/Midwg)   Philipped Prince and West Juneau Lift Stations/Dwgs/Midwg)   Philipped Pri	15) 10/10	00 BASET [15] T.	CP/IP 10 BASET  ENS—1  TCP, 10/100  15  HMI—2  JOROUND JOROUND	TCP/IP 10/100 BASET  Jeround 24470C  /IP	MP	OUTER DRIVE & WEST JUNEAU PUMP STATION REHABILITATION JUNEAU, AK JUNEAU, AK JUNEAU, AK OLY/10/10/10/2057

OD PLC BLOCK DIAGRAM

E-504 SCALE: NTS

**BID SET** 

© DOWL 2023 SHEET




John A. Pepe EE 11387


PLC BLOCK DIAGRAM

M

© DOWL 2023 SHEET

E-505





**BID SET** 

ROJECT 1528.50233 ATE 01/16/202 © DOWL 2023

E-507

OF ALA

\* 49世


QCT CALy

John A. Pepe EE 11387 PROFESSION 1/16/ John A. Pepe EE 11387

EDC., INC. 213 W. HERMED LANE ANCHORAGE, AK 99503 (907) 276-7933 LICENSE NO. AECC705

PLC DISCRETE INPUTS

О



REV DATE DESCRIPTION B

# 49 TH \*\*

# 49 TH \*\*

# 49 TH \*\*

# 1187

# 1/16/2

EDC., INC. 213 W. RRWED LANE ANCHORAGE, AK 99503 (907) 276-7933 LICENSE NO. AECC705

EDC, 213 W. F. MCHO.

OUTER DRIVE & WEST JUNEAU P STATION REHABILITATION JUNEAU, AK OD PLC DISCRETE INPUTS

PROJECT 1528.50233.
DATE 01/16/202

© DOWL 2023 SHEET

TO CB-13

RACK 02 SLOT -

1756-0B16E +DC -0 16 DISCRETE OUTPUT MODULE A1 801 A2 CR-801 OH HO

CR 802 A2 CR 802 OH OH

CR 808 A2 CR 802 CR 802

CR 804 A2 CR 802 CR 802

CR 805 A2 CR 802 CR 802

CR 806 A2 CR 802 CR 802

CR - 802 CR - 802

CR 808 A2 CR 802 CR 802

CR 809 A2 CR 802 CR 802

CR 810 A2 CR 802 CR 802

CR-802

CR-802

CR 813 A2 CR 802 OH OHO

CR 0 814 A2 CR - 802 OH OHO

CR -802 CR-802

CR 816 A2 CR 802 CR 802

LIFT STATION ALARM HORN STROBE, YAL -200

PUMP P-101 VFD RUN COMMAND, RC-101

PUMP P-102 VFD RUN COMMAND, RC-102

PUMP P-103 VFD RUN COMMAND, RC-103

120V, 60Hz, PANEL 'L'

TO HORN/STROBE

John A. Pepe EE 11387


OD PLC DISCRETE OUTPUTS

E-509

**BID SET** 

ROJECT 1528.50233. ATE 01/16/202


© DOWL 2023 SHEET




John A. Pepe EE 11387

ROJECT 1528.50233. ATE 01/16/202

© DOWL 2023 SHEET



ROJECT 1528.50233. ATE 01/16/202



REV DATE DESCRIPTION B'

OF A A A Solin A Pepe E 11387

\*\*\* 176/2\*\*
\*\*\* 17/6/2\*\*

EDC, INC. 213 W. FREWED LAVE ANCHORACE, AK 99503 (907) 276-7933 LICENSE NO. AECC705


EDC, 213 W, ANGK

OTER DRIVE & WEST JUNEAU PU STATION REHABILITATION JUNEAU, AK PLC DISCRETE INPUTS

PROJECT 1528.50233 DATE 01/16/202

> © DOWL 2023 SHEET

E-512




John A. Pepe EE 11387 EDC., INC. 213 W. HEWED LANE ANCHORAGE, AK 99503 (907) 276-7933 LICENSE NO. AECC705 

WJ PLC DISCRETE INPUTS

ROJECT 1528.50233. ATE 01/16/202

© DOWL 2023 SHEET E-513



REVISIONS

REVISIONS

DESCRIPTION

B

EDC., INC.
213 W. FREWED LANE
ANCHORAGE, AK 99503
(907) 276-7933
LICENSE NO. AECC705


EDC. III 213 W. FR ANCHOR ANCHOR LICENSE I

UTER DRIVE & WEST JUNEAU PUN STATION REHABILITATION JUNEAU, AK WJ PLC DISCRETE OUTPUTS

PROJECT 1528.50233.0 DATE 01/16/2022

> © DOWL 2023 SHEET

BID SET E-514





John A. Pepe EE 11387

ROJECT 1528.50233. ATE 01/16/202

WJ PLC ANALOG INPUTS


© DOWL 2023 SHEET






John A. Pepe EE 11387

GENSET AND ATS INPUTS - OUTPUTS







WJ MOTOR PROTECTION INPUTS OUTPUTS

© DOWL 2023

☑ SWAGELOK SS-8-RB-4 REDUCING BUSHING AS REQUIRED

2 SWAGELOK SS-4-ST STREET TEE

3 SWAGELOK SS-4-SE STREET ELBOW

4 SWAGELOK SS-4-HLN-2.00 NIPPLE

SWAGELOK SS−4−HLN−1.50 NIPPLE


SWAGELOK SS-QC4-B-4PM FEMALE QUICK CONNECT


SWAGELOK SS-400-1-4 TUBING CONNECTOR

1 INLINE 204F-02S6-M-01 BALL VALVE


2/2" LIQUID FILLED SS GAUGE, SAME RATING AS INSTRUMENT

















PH AND TEMPERATURE SENSOR MOUNTING




TYPICAL INSTRUMENT PRESSURE TAP


SCALE: NTS

INTRUSION SWITCH

SCALE: NTS










**BID SET** 

E-601 SCALE: NTS


DETAILS ELECTRICAL


© DOWL 2023



E-602 SCALE: NTS

EMERGENCY SHUTDOWN (ESD) STATION DETAIL





ENCLOSURE ELEVATION VIEW

HUMAN-MACHINE-INTERFACE (HMI-2 AND 3) REMOTE PANEL DETAIL

ELECTRICAL DETAILS

John A. Pepe EE 11387

© DOWL 2023 SHEET

E-602