



## ADDENDUM TO THE CONTRACT

for the

### CHANNEL DRIVE & CHANNEL VISTA PUMP STATION REHABILITATION Contract No. BE21-148

**ADDENDUM NO.:** THREE

**CURRENT DEADLINE FOR BIDS:**  
December 15, 2020

**PREVIOUS ADDENDA:** TWO

**ISSUED BY:** City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801

**DATE ADDENDUM ISSUED:** December 9, 2020

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <http://www.juneau.org/engineering ftp/contracts/Contracts.php>

#### **CLARIFICATIONS:**

**Question:** *"Regarding the Channel Drive & Channel Vista Pump Station Rehabilitation project, is it the intent of Specification 11176, Sections 1.1.A and 1.1.B that the pump control panels be supplied by ITT Flygt in addition to the pumps?"*

**Response:** Yes, the specification intends the control panels and level sensors be manufactured by ITT Flygt.

**Question:** *"In the pre-bid meeting, it was stated that the cost of work for AEL&P and ACS should be borne by the owner. Bid schedule and pay item descriptions look to agree with this. However, Special Provisions section 260500 (1.11) and (1.12) say, "All costs related to service application... shall be paid for by the Contractor. Please advise."*

**Response:** See Project Manual Item numbers 2 and 3 below.

**PROJECT MANUAL:**

Item No. 1      **SPECIAL PROVISIONS SECTION 11176 – Sewage Pump Station, 1.1 Description**  
**Replace** paragraph B with the following:

“B.      The CONTRACTOR shall assume full responsibility for furnishing and the functional operation of the complete pump system including the control panel and level controls in accordance with this section and Division 260000. The CONTRACTOR shall coordinate the assembly, fabrication and installation of the pumps, control panels, wet wells, valve vaults, hatch lids (location, size, etc.), piping etc. to ensure the completed assembly meets the requirements of the pump manufacturer.”

Item No. 2      **SPECIAL PROVISIONS SECTION 260500 – General Electrical Provisions, 1.11 Electrical Supply**  
**Replace** paragraphs C and D with the following:

“C.      The CONTRACTOR shall coordinate with the electric utility to ensure timely application and installation of service. All costs related to service application and installation, including one-time line extension and utility connection costs, shall be paid for by the OWNER.

D.      The CONTRACTOR shall coordinate with the telephone utility to ensure timely coordination of any site conflicts with existing infrastructure. All costs related relocation of infrastructure will be the responsibility of the OWNER.”

Item No. 3      **SPECIAL PROVISIONS SECTION 260500 – General Electrical Provisions, 1.12 Telecommunications Utility**  
**Replace** paragraphs C and D with the following:

“C.      The CONTRACTOR shall coordinate with the utility to ensure timely application and installation of service. All costs related to service application and installation, including one-time line extension and utility connection costs, shall be paid for by the OWNER.

D.      The CONTRACTOR shall coordinate with the utility to ensure timely coordination of any site conflicts with existing infrastructure. All costs related relocation of infrastructure will be the responsibility of the OWNER.”

By:   
\_\_\_\_\_  
Greg Smith,  
Contract Administrator

Total number of pages contained within this Addendum: 2