



ENGINEERING DEPARTMENT

INFORMATION TO BIDDERS
for

Contract No. BE21-144
Rainforest Recovery Center Exterior Upgrade

ISSUED BY:

City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

Date Issued: April 2, 2021

The following information is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: http://www.juneau.org/engineering_ftp/contracts/Contracts.php. This is **not** an addendum.

Question: *"Addendum 2 page 11 is a product to plumb a gutter from a pitched fascia. Is this product being suggested as cost savings alternative? If so, what is the spacing for them? I've verified the existing gutters are installed with a full length metal gutter kick per detail 2/A801 & 4/A804 which is a more costly detail. Just want to be sure everyone prices you the same thing."*

Response: A continuous cleat as shown on 2/A801 is required behind the gutter. This will match the existing installation.