

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

MINOR
(SUBR 01)
F - FINAL

PERMITTEE NAME/ADDRESS		AK0021407		001 A							
NAME: JUNEAU, CITY AND BOROUGH OF		PERMIT NUMBER		DISCHARGE NUMBER							
ADDRESS: 155 SOUTH SEWARD		MONITORING PERIOD									
JUNEAU, ALASKA 99801		YR	MO	DAY	YEAR	MO	DAY				
FACILITY: AUK BAY TREATMENT FACILITY		2003	04	01	2003	04	30				
LOCATION: JUNEAU, ALASKA		FROM		TO		MAJOR (SUBR 01)					
PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****		*****	11.8	17.0	(04)	0	5/7	
00010 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX	DEG. C		DAILY	GRAB
BOD, 5-DAY (20 DEG. C)	SAMPLE MEASUREMENT	5	5	(26)	*****	7	7	(19)	0	1/MO	
00310 1 0 0	PERMIT REQUIREMENT	25	50		*****	30	60			ONCE/MONTH	COMP 24
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	DAILY AVG	DAILY MAX	LBS/DAY	*****	DAILY AVG	DAILY MAX	MG/L			
pH	SAMPLE MEASUREMENT	*****	*****		6.0	*****	6.5	(12)	0	5/7	
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	6.0 MIN	*****	9.0 MAXIMUM	SU		DAILY	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	30	60			ONCE/MONTH	COMP 24
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	4	4	(26)	*****	7	7	(19)	0	1/MO	
00530 1 0 0	PERMIT REQUIREMENT	25	50		*****	30	60			ONCE/MONTH	COMP 24
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	DAILY AVG	DAILY MAX	LBS/DAY	*****	DAILY AVG	DAILY MAX	MG/L			
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****		*****	0.00	0.00	(25)	0	1/MO	
00545 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT DAILY AVG	REPORT DAILY MAX	ML/L		DAILY	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	30 DAY GEO	7 DAY GEO	# / 100 ML		ONCE/MONTH	GRAB
COLIFORM, FECAL MF, M-FC BROTH, 44.5C	SAMPLE MEASUREMENT	*****	*****		*****	2	2	(13)	0	1/MO	
31616 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	*****	200	400			ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	30 DAY GEO	7 DAY GEO	# / 100 ML			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.075	*****	(03)	*****	*****	*****		0	7/7	CONT.
50050 1 0 0	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****		DAILY	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****			
<p>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SF 18 USC 1001 AND 22 USC 1319 (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$ 10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND SIX YEARS.)</p>											
NAME/TITLE PRINCIPAL EXEC. OFFICER		TELEPHONE				DATE					
SCOTT JEFFERS, WW UTILITY SUPERINTENDENT		907	586	0393	2003	05	08				
COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)											PG 1 OF 2