

Appendix C

State of Alaska Discharge Monitoring Report

PERMITTEE NAME/ADDRESS (Include Facility Name/location If Different):


Submit Report to:
 Alaska Department of Environmental Conservation
 Division of Air and Water Quality
 410 Willoughby Avenue, Suite 105
 Juneau, AK 99801-1795
 Telephone (907) 465-5300, FAX (907) 465-5274

NAME:	City and Borough of Juneau, Bonnie Brae Subdivision		
ADDRESS:	Public Works Department, 155 South Seward Street, Juneau, Alaska 99801-1397		
FACILITY:	Bonnie Brae Subdivision, Secondary Wastewater Treatment Discharge to Gastineau Channel		
LOCATION:	4 1/2 Mile N. Douglas Highway, Douglas Island, Near Juneau, Alaska	PERMIT NUMBER:	9711-DB009
ATTN.:	Mr. Ernie Mueller, Public Works Director, City and Borough of Juneau, / Mr. Peter Freer, Board President, Bonnie Brae Home Owners Association, (907) 586-6891	PERMIT EXPIRATION DATE:	8 / 31 / 2002

REQUIRED REPORTING FREQUENCY: Quarterly (4 per Year)	DISCHARGE: Secondary treated effluent discharged to Gastineau Channel, North Douglas Island, via a 200 ft. long, 8 inch diameter marine outfall line without a diffuser at + 8 ft. M.L.L.W.	SAMPLE PERIOD: FROM: 07 / 01 / 2001 TO: 07 / 31 / 2001
--	--	---

PARAMETER	SUMMARY OF RESULTS						Units	Frequency of Analysis	Sample Type
	Min	Avg 30-day	Avg 7-day	Max 24-hr.	No. Of Exceed-ences				
Flow (Effluent)	SAMPLE RESULT	N/A	18,000	18,000	18,000	0	gpd	Weekly 1 / 7 days	Estimate Daily Total
	PERMITTED	N/A	25000	28000	30000				
Biochemical Oxygen Demand (Effluent)	SAMPLE RESULT	N/A	48.7	48.7	48.7	2	mg/l	Quarterly 4 / year	Grab or Composite
	PERMITTED	N/A	30	45	60				
Total Suspended Solids (Effluent)	SAMPLE RESULT	N/A	40.6	40.6	40.6	1	mg/l	Quarterly 4 / year	Grab or Composite
	PERMITTED	N/A	30	45	60				
Dissolved Oxygen (Effluent)	SAMPLE RESULT		N/A	N/A	N/A		mg/l	Upon Request by the Dept.	Grab
	PERMITTED	2.0	N/A	N/A	N/A				
PH (Effluent)	SAMPLE RESULT	7.3	N/A	N/A	7.3	0	Std. Units	Quarterly 4 / year	Grab
	PERMITTED	6.5	N/A	N/A	8.5				
Fecal Coliform Bacteria (Effluent)	SAMPLE RESULT	N/A	7X10 ⁵	N/A	7X10 ⁵	2	#/100 ml	Monthly 1 / Month	Grab
	PERMITTED	N/A	1 X 10 ⁵	N/A	1.5 X 10 ⁵				
Dissolved Oxygen (Outside Leading Edge of the Mixing Zone)	SAMPLE RESULT		N/A	N/A	N/A		mg/l	Upon Request by the Dept.	Grab
	PERMITTED	5.0	N/A	N/A	N/A				
Fecal Coliform Bacteria (Outside Leading Edge of the Mixing Zone)	SAMPLE RESULT	N/A		N/A			#/100 ml	1 per Year (Nov. thru Apr.) Bi-Monthly (May thru Oct.)	Grab
	PERMITTED	N/A	14	N/A	43				

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND, BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THAT INFORMATION, I BELIEVE THAT THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	TELEPHONE	DATE				
Ernie Mueller Public Works Director	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY
		907	789-9919	2001	10	11

COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

9 CHECK HERE IF THERE WAS NO DISCHARGE DURING THE ENTIRE REPORTING PERIOD.

Appendix C

State of Alaska Discharge Monitoring Report


Submit Report to:
 Alaska Department of Environmental Conservation
 Division of Air and Water Quality
 410 Willoughby Avenue, Suite 105
 Juneau, AK 99801-1795
 Telephone (907) 465-5300, FAX (907) 465-5274

PERMITTEE NAME/ADDRESS (Include Facility Name/location If Different):

NAME:	City and Borough of Juneau, Bonnie Brae Subdivision		
ADDRESS:	Public Works Department, 155 South Seward Street, Juneau, Alaska 99801-1397		
FACILITY:	Bonnie Brae Subdivision, Secondary Wastewater Treatment Discharge to Gastineau Channel		
LOCATION:	4 1/2 Mile N. Douglas Highway, Douglas Island, Near Juneau, Alaska	PERMIT NUMBER:	9711-DB009
ATTN.:	Mr. Ernie Mueller, Public Works Director, City and Borough of Juneau, / Mr. Peter Freer, Board President, Bonnie Brae Home Owners Association, (907) 586-6891	PERMIT EXPIRATION DATE:	8 / 31 / 2002

REQUIRED REPORTING FREQUENCY: Quarterly (4 per Year)		DISCHARGE: Secondary treated effluent discharged to Gastineau Channel, North Douglas Island, via a 200 ft. long, 8 inch diameter marine outfall line without a diffuser at + 8 ft. M.L.L.W.					SAMPLE PERIOD: FROM: 08 / 01 / 2001 TO: 08 / 31 / 2001		
PARAMETER		SUMMARY OF RESULTS					Units	Frequency of Analysis	Sample Type
		Min	Avg 30-day	Avg 7-day	Max 24-hr.	No. Of Exceed-ences			
Flow (Effluent)	SAMPLE RESULT	N/A	18,000	18,000	18,000	0	gpd	Weekly 1 / 7 days	Estimate Daily Total
	PERMITTED	N/A	25000	28000	30000				
Biochemical Oxygen Demand (Effluent)	SAMPLE RESULT	N/A	110	110	110	3	mg/l	Quarterly 4 / year	Grab or Composite
	PERMITTED	N/A	30	45	60				
Total Suspended Solids (Effluent)	SAMPLE RESULT	N/A	49.8	49.8	49.8	2	mg/l	Quarterly 4 / year	Grab or Composite
	PERMITTED	N/A	30	45	60				
Dissolved Oxygen (Effluent)	SAMPLE RESULT		N/A	N/A	N/A		mg/l	Upon Request by the Dept.	Grab
	PERMITTED	2.0	N/A	N/A	N/A				
PH (Effluent)	SAMPLE RESULT	7.6	N/A	N/A	7.6	0	Std. Units	Quarterly 4 / year	Grab
	PERMITTED	6.5	N/A	N/A	8.5				
Fecal Colliform Bacteria (Effluent)	SAMPLE RESULT	N/A	1.6X10 ⁵	N/A	1.6X10 ⁵	2	#/100 ml	Monthly 1 / Month	Grab
	PERMITTED	N/A	1 X 10 ⁵	N/A	1.5 X 10 ⁵				
Dissolved Oxygen (Outside Leading Edge of the Mixing Zone)	SAMPLE RESULT		N/A	N/A	N/A		mg/l	Upon Request by the Dept.	Grab
	PERMITTED	5.0	N/A	N/A	N/A				
Fecal Colliform Bacteria (Outside Leading Edge of the Mixing Zone)	SAMPLE RESULT	N/A	13	N/A	13	0	#/100 ml	1 per Year (Nov. thru Apr.) Bi-Monthly (May thru Oct.)	Grab
	PERMITTED	N/A	14	N/A	43				

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND, BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THAT INFORMATION, I BELIEVE THAT THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Ernie Mueller Public Works Director	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE		DATE		
		AREA CODE	NUMBER	YEAR	MONTH	DAY
		907	789-9919	2001	10	11

COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

9 CHECK HERE IF THERE WAS NO DISCHARGE DURING THE ENTIRE REPORTING PERIOD.

Appendix C

State of Alaska Discharge Monitoring Report


PERMITTEE NAME/ADDRESS (Include Facility Name/location If Different):

Submit Report to:
 Alaska Department of Environmental Conservation
 Division of Air and Water Quality
 410 Willoughby Avenue, Suite 105
 Juneau, AK 99801-1795
 Telephone (907) 465-5300, FAX (907) 465-5274

NAME:	City and Borough of Juneau, Bonnie Brae Subdivision		
ADDRESS:	Public Works Department, 155 South Seward Street, Juneau, Alaska 99801-1397		
FACILITY:	Bonnie Brae Subdivision, Secondary Wastewater Treatment Discharge to Gastineau Channel		
LOCATION:	4 1/2 Mile N. Douglas Highway, Douglas Island, Near Juneau, Alaska	PERMIT NUMBER:	9711-DB009
ATTN.:	Mr. Ernie Mueller, Public Works Director, City and Borough of Juneau, / Mr. Peter Freer, Board President, Bonnie Brae Home Owners Association, (907) 586-6891	PERMIT EXPIRATION DATE:	8 / 31 / 2002

REQUIRED REPORTING FREQUENCY: Quarterly (4 per Year)		DISCHARGE: Secondary treated effluent discharged to Gastineau Channel, North Douglas Island, via a 200 ft. long, 8 inch diameter marine outfall line without a diffuser at + 8 ft. M.L.L.W.					SAMPLE PERIOD: FROM: 09 / 01 / 2001 TO: 09 / 30 / 2001		
PARAMETER	SUMMARY OF RESULTS						Units	Frequency of Analysis	Sample Type
	Min	Avg 30-day	Avg 7-day	Max 24-hr.	No. Of Exceed-ences				
Flow (Effluent)	SAMPLE RESULT	N/A	18,000	18,000	18,000	0	gpd	Weekly 1 / 7 days	Estimate Daily Total
	PERMITTED	N/A	25000	28000	30000				
Biochemical Oxygen Demand (Effluent)	SAMPLE RESULT	N/A	68.3	68.3	68.3	3	mg/l	Quarterly 4 / year	Grab or Composite
	PERMITTED	N/A	30	45	60				
Total Suspended Solids (Effluent)	SAMPLE RESULT	N/A	85.6	85.6	85.6	3	mg/l	Quarterly 4 / year	Grab or Composite
	PERMITTED	N/A	30	45	60				
Dissolved Oxygen (Effluent)	SAMPLE RESULT		N/A	N/A	N/A		mg/l	Upon Request by the Dept.	Grab
	PERMITTED	2.0	N/A	N/A	N/A				
PH (Effluent)	SAMPLE RESULT	7.4	N/A	N/A	7.4	0	Std. Units	Quarterly 4 / year	Grab
	PERMITTED	6.5	N/A	N/A	8.5				
Fecal Coliform Bacteria (Effluent)	SAMPLE RESULT	N/A	.7X10 ⁵	N/A	.7X10 ⁵	0	#/100 ml	Monthly 1 / Month	Grab
	PERMITTED	N/A	1 X 10 ⁵	N/A	1.5 X 10 ⁵				
Dissolved Oxygen (Outside Leading Edge of the Mixing Zone)	SAMPLE RESULT		N/A	N/A	N/A		mg/l	Upon Request by the Dept.	Grab
	PERMITTED	5.0	N/A	N/A	N/A				
Fecal Coliform Bacteria (Outside Leading Edge of the Mixing Zone)	SAMPLE RESULT	N/A		N/A			#/100 ml	1 per Year (Nov. thru Apr.) Bi-Monthly (May thru Oct.)	Grab
	PERMITTED	N/A	14	N/A	43				

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND, BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THAT INFORMATION, I BELIEVE THAT THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
		AREA CODE	NUMBER	YEAR	MONTH	DAY
Ernie Mueller Public Works Director		907	789-9919	2001	10	11

COMMENT AND EXPLANATION OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

9 CHECK HERE IF THERE WAS NO DISCHARGE DURING THE ENTIRE REPORTING PERIOD.