

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUB 01)  
F - FINAL EFFLUENT  
\*\*\* NO DISCHARGE  
NOTE: Read instructions before completing this form.

Form Approved.  
OMB No. 2040-0004  
Approval Expires 05-31-98

PERMITTEE NAME/ADDRESS(Include Facility name/Location if different)

NAME: JUNEAU, CITY AND BOROUGH OF  
ADDRESS: MENDENHALL TREATMENT PLANT  
155 SOUTH SEWARD,  
JUNEAU, ALASKA 99801  
FACILITY: MENDENHALL VALLEY SERVICE AREA  
LOCATION: JUNEAU, ALASKA 99801  
ATT: SCOTT JEFFERS, WW UTILITIES SUPT


AK0022951  
PERMIT NUMBER

001 A  
DISCHARGE NUMBER

MONITORING PERIOD						
YR	MO	DAY	TO	YR	MO	DAY
2003	4	01		2003	4	30

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG, CENTIGRADE 00010 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT ***** PERMIT REQUIREMENT *****	*****	*****	*****	*****	12.5	14.0	(04)	0	5/7	GRAB
BOD, 5-DAY (20 DEG. C) 00310 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT 3006 PERMIT REQUIREMENT REPORT MO AVG REPORT DAILY MAX	3006	3837	(26)	*****	205	257	(19)	0	1/7	COMP 24
DOD, 5-DAY (20 DEG. C) 00310 W 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT 140.0 PERMIT REQUIREMENT 1839 WKLY AVG *****	140.0	*****	(20)	*****	10.0	*****	(19)	0	1/7	COMP 24
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT 146.8 PERMIT REQUIREMENT 1226 MO AVG 2452 DAILY MAX	146.8	184.1	(26)	*****	10.0	12.0	(19)	0	1/7	COMP 24
pH	SAMPLE MEASUREMENT ***** PERMIT REQUIREMENT *****	*****	*****	*****	6.5	*****	6.8	(12)	0	5/7	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT ***** PERMIT REQUIREMENT *****	*****	*****	*****	6.5 MIN	*****	6.5 MAXIMUM	SU	0	WEEK DAYS	GRAB
ALKALINITY AS CaCO3 00425 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT ***** PERMIT REQUIREMENT *****	*****	*****	*****	*****	137.0	137.0	(19)	0	1/ month	COMP 24
SOLIDS, TOTAL SUSPENDED 00530 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT 3116.2 PERMIT REQUIREMENT REPORT MO AVG REPORT DAILY MAX	3116.2	4821.9	(26)	*****	211.6	323.0	(19)	0	1/7	COMP 24

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN: AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER SCOTT JEFFERS WW UTILITY SUPERINTENDENT TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT (REFERENCE ALL ATTACHMENTS HERE)	907 AREA CODE	586-0393 PHONE NUMBER	2003 YEAR	5 MO	08 DAY
--	---	--	------------------	--------------------------	--------------	---------	-----------