



**NOTES:**

1. CONCRETE INTERNATIONAL CORPORATION ASHFORD FORMULA OR APPROVED EQUAL SHALL BE APPLIED AS A CURING COMPOUND. APPLICATION SHALL CONFORM TO THE MANUFACTURERS RECOMMENDATIONS.
2. COLD JOINT REQUIRED BETWEEN SIDEWALK, CURB AND RAMP.
3. WIRE MESH IN CONCRETE, 4" COMPACTED D-1 BASE AND 24" ADDITIONAL NON-FROST SUSCEPTIBLE MATERIAL AS SHOWN IN GENERAL SIDEWALK STANDARD 111A ARE REQUIRED FOR CURB RAMPS. FIBER REINFORCING MAY BE ALLOWED PER THE ENGINEER.
4. MINIMUM THICKNESS ON ALL CONCRETE IS 6" WITHIN THE RAMP AND TRANSITIONS.
5. DETECTABLE WARNING, YELLOW TRUNCATED DOMES, FULL LENGTH OF CURBCUT, 2' WIDE.

SCALE: NTS	DATE: 4/11/00	CITY AND BOROUGH OF JUNEAU, ALASKA	
DRAWN BY: TAD	CHECKED BY: JB/STAFF	ACCESSIBLE SIDEWALK RAMP	
APPROVED BY: <i>[Signature]</i>	REVISED: 8/14/2011	STANDARD 106	