



NOTES:

1. ALL MATERIALS AND CONSTRUCTION SHALL CONFORM TO SECTION 02708-GUARDRAIL, OF THE MOST CURRENT EDITION OF THE STANDARD SPECIFICATIONS FOR CIVIL ENGINEERING PROJECTS AND SUBDIVISION IMPROVEMENTS.
2. W 6"x8"x6'-0" STEEL POST MAY BE SUBSTITUTED FOR PRESSURE TREATED POST.
3. 2' MINIMUM OFFSET FROM EDGE OF PAVEMENT OR REQUIRED LANE WIDTH. SEE STANDARD DETAIL 102B.

SCALE: NTS	DATE: 1/4/09	CITY AND BOROUGH OF JUNEAU, ALASKA GUARDRAIL	
DRAWN BY: RDK	CHECKED BY: JB/STAFF		
APPROVED BY: 		REVISED: 8/14/2011	STANDARD 110