



NOTES:

1. DIAMETER OF HOLE CUT IN SEWER MAIN SHALL NOT EXCEED 0.25" LARGER THAN THE SADDLE TEE CONNECTION. TEE SHALL BE CENTERED OVER CUT IN PIPE AND CLAMPED WITH METAL BAND SO TEE GASKET FORMS A WATER-TIGHT SEAL.
2. WATER AND DEBRIS SHALL NOT BE ALLOWED TO ENTER THE SEWER MAIN DURING THE TAPPING OPERATION.
3. SWING TIES TO THE TEE MUST BE MEASURED AND FURNISHED TO CBJ ENGINEERING DEPARTMENT.
4. SADDLE TEE SHALL BE A ROMAC CB SEWER SADDLE OR AN APPROVED EQUAL.

SCALE: NTS		DATE: 7/5/95	CITY AND BOROUGH OF JUNEAU, ALASKA SANITARY SEWER SADDLE TEE
DRAWN BY: DRW		CHECKED BY: STAFF	
APPROVED BY: <i>DRW</i>		REVISED: 8/14/2011	STANDARD 210