



ELEVATION VIEW

NOTES:

1. HDPE PORTION OF SEWER SERVICE LATERAL SHALL BE CONTINUOUS. LENGTH OF PIPE VARIES.
2. EXTEND 4" PVC SEWER LATERAL AT LEAST TO EDGE OF SHOULDER.
3. USE MINIMUM DISTANCE TO BEND PIPE TO INCREASE DEPTH.
4. INSULATE PIPE WITH ONE SIX FOOT LENGTH OF IMCLOCK WRAPAROUND PIPE INSULATION OR AN APPROVED EQUAL.
5. MAINTAIN 60" OF COVER TO THE PROPERTY LINE OR INSULATE FOR LOSS OF COVER DIMENSION.
6. INSTALL REBAR WITH GREEN CAP, 2"x4" WOOD POST FROM INVERT TO 4" ABOVE GROUND, PAINTED GREEN, EXTEND WARNING RIBBON TO TOP OF POST AND STAPLE TO TOP OF POST.

SCALE: NTS	DATE: 12/2/96	CITY AND BOROUGH OF JUNEAU, ALASKA PRESSURE SANITARY SEWER SERVICE LATERAL	
DRAWN BY: DRW	CHECKED BY: STAFF		
APPROVED BY: <i>DRW</i>	REVISED: 8/14/2011	STANDARD 216	