



NOTES:

1. CONTROL PANEL SHALL LOCATED ON SIDE AWAY FROM THE ADJACENT ROADWAY, IF APPLICABLE.
2. WHEN 6 FEET OF CLEAR SPACE IS NOT AVAILABLE IN THE FRONT OF THE ELECTRICAL EQUIPMENT DUE TO PROPERTY LINES OR OTHER OBSTRUCTIONS, PROVIDE A THIRD GUARD POST AND REVERSE GENSET RECEPTACLE, METER, SWITCH, ETC., TO VAULT SIDE OF EQUIPMENT RACK.

SCALE: NTS	DATE: 1/18/00	CITY AND BOROUGH OF JUNEAU, ALASKA	
DRAWN BY: STAFF	CHECKED BY: JB/STAFF	PUMP STATION PLAN VIEW	
APPROVED BY: 	REVISED: 8/14/2011	STANDARD 220-1	