



**NOTES:**

1. MARK SERVICE WITH GREEN PAINTED 2"x4" POST. POST SHALL EXTEND TO DEPTH OF SERVICE LATERAL. REBAR SHALL BE DRIVEN TO GROUND LEVEL. WRAP WARNING TAPE AROUND POST AND STAPLE TO TOP OF POST.
2. ACCEPTABLE PIPE FOR USE WITHIN R.O.W. INCLUDES C900 PVC, SDR 35 PVC, AND HD CPP.
3. MINIMUM CLEARANCE OF 18" REQUIRED BENEATH DITCH LINE.
4. DISTANCE FROM THE TEE TO THE CATCH BASIN AND TWO MEASURED DISTANCES FROM END OF SERVICE PIPE TO PERMANENT OBJECTS SHALL BE NOTED ON THE AS BUILT PLANS.
5. THE SERVICE LATERAL SHALL END AT THE PROPERTY LINE WITH A BELL END OF PIPE.
6. LATERALS SHALL BE CONSTRUCTED AT 2% SLOPE UNLESS APPROVED BY THE ENGINEER.
7. PIPE CONNECTIONS IN THE RIGHT OF WAY THAT DO NOT USE BELL AND SPIGOT SHALL CONFORM TO STANDARD 218.

SCALE: NTS	DATE: 2/1/10	CITY AND BOROUGH OF JUNEAU, ALASKA	
DRAWN BY: STAFF	CHECKED BY: STAFF	STORM DRAIN SERVICE LATERAL	
APPROVED BY: <i>DRW</i>	REVISED: 8/14/2011	STANDARD 307	