



## ADDENDUM TO THE CONTRACT

for the

### AUGUSTUS BROWN POOL UPPER ROOF REPLACEMENT Contract No. BE-21-030

**ADDENDUM NO.:** TWO

**CURRENT DEADLINE FOR BIDS:**

August 11, 2020

**PREVIOUS ADDENDA:** ONE

**ISSUED BY:** City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801

**DATE ADDENDUM ISSUED:** August 6, 2020

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <http://www.juneau.org/engineering ftp/contracts/Contracts.php>

#### **INFORMATION TO BIDDERS:**

Question: The vertical metal siding is at all four (4) elevations?

Response: Correct

Question: Can you specify the locations of Painting other than General Note 3 on the A sheets

Response: The intent of the general note is to repair any finishes adjacent to the Work that may be damaged or altered in completing the Work.

Question: The Warranted wind speed spec is 135+ gust. Carlisle offers 120. Is this sufficient?

Response: Per CBJ, 120 mph wind speed is acceptable for downtown Juneau area.

#### **PROJECT MANUAL:**

Item No. 1 SECTION 075419- PVC ROOFING, PART 2 PRODUCTS, ARTICLE 2.1 PERFORMANCE REQUIREMENTS, paragraph C 1.a **Change** wind speed **from** 135 miles per hour **to** 120 miles per hour.

Item No. 2 SECTION 075419- PVC ROOFING, PART 2 PRODUCTS, ARTICLE 2.2 PVC ROOFING, paragraph A **Change from** "PVC Sheet: ASTM D4434, Type II, Grade 1, glass fiber reinforced PVC sheet." **to** "PVC Sheet: ASTM D 4434, **Type III/IV, polyester fiber** reinforced PVC sheet."

- Item No. 3 SECTION 075419- PVC ROOFING, PART 2 PRODUCTS, ARTICLE 2.4  
TEMPORARY ROOF MEMBRANE./PERMANENT VAPOR RETARDER, paragraph  
C, **Change from** "Vap Air Seal MD" **to** "Vap Air Seal 725TR"
- Item No. 4 SECTION 075419- PVC ROOFING, PART 3 EXECUTION, ARTICLE 3.12 ROOFING  
INSTALLER'S WARRANTY, paragraph D 1. B **Change** wind speed **from** 135 miles  
per hour **to** "120 miles per hour."



By: \_\_\_\_\_  
Greg Smith,  
Contract Administrator

Total number of pages contained within this Addendum: 2