



ADDENDUM TO THE CONTRACT

for the

BARTLETT REGIONAL HOSPITAL ASU-1 GLYCOL CONVERSION

Contract No. BE21-169

ADDENDUM NO.: TWO

CURRENT DEADLINE FOR BIDS:
March 9, 2021

PREVIOUS ADDENDA: ONE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

PREVIOUS DEADLINE FOR BIDS:
March 3, 2021

DATE ADDENDUM ISSUED: March 2, 2021

The following items of the contract are modified as herein indicated. All other items remain the same. This is a faxed addendum. A confirming copy will not be mailed to you. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at:
<http://www.juneau.org/engineering ftp/contracts/Contracts.php>

PROJECT MANUAL:

Item No. 1 SECTION 00030 - NOTICE INVITING BIDS. DEADLINE FOR BIDS.

Change the date of the Deadline for Bids **from** March 3, 2021 **to** March 9, 2021. The time remains the same.

Item No. 2 ELECTRICAL SHEET E901 SPECIFICATIONS, CONSTRUCTION DOCUMENTS
New spec section titled TRANSFORMERS (added in Amendment 1) **delete**
Section 1.1.D and **replace** with the following:

D. Enclosure: Ventilated, steel painted with gray enamel.

By: 
for _____
Greg Smith,
Contract Administrator