



INFORMATION TO BIDDERS
for

Contract No. BE21-149
BRH Behavioral Health Facility

ISSUED BY:

City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

Date Issued: March 15, 2021

The following information is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <https://juneau.org/engineering-public-works> This is **not** an addendum.

Question: *“The spec section 28462.11 Section 2.2 states that the notification is to be horn/strobe evacuation. The hospital is an audio voice evacuation system, and we are tying into that, shall the new BH building be audio voice evcec as well, or chime/strobe notification?”*

Answer: No. Behavioral Health Facility occupancy does not require Audio Voice Evac Fire Alarm System. Integration with the Main Hospital Building, Audio Voice Evac is not required for Behavioral Health Facility.