

ADDENDUM TO THE CONTRACT

for the

CREST STREET RECONSTRUCTION Contract No. BE21-219

ADDENDUM NO.:

ONE

CURRENT DEADLINE FOR BIDS:

May 18, 2021

PREVIOUS ADDENDA: NONE

ISSUED BY:

City and Borough of Juneau **ENGINEERING DEPARTMENT**

155 South Seward Street Juneau, Alaska 99801

DATE ADDENDUM ISSUED:

May 5, 2021

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: https://juneau.org/engineering-public-works/current-bids-and-rfps

PROJECT MANUAL:

Item No. 1 **Add** the following Special Provision:

> "SECTION 02801 - ASPHALT CONCRETE PAVEMENT, PART 1 - GENERAL, Article 1.1, DESCRIPTION, add paragraph C as follows:

Asphalt concrete mix for sidewalks, driveways and hydrant pads may be C. either Type III, Class B, or Type II-A, Class B. See Table 02801-1 and Table 02801-2."

Item No. 2 Delete the Special Provision that reads:

> "SECTION 02801 - ASPHALT CONCRETE PAVEMENT, PART 1 - GENERAL, Article 1.1, DESCRIPTION, revise TABLE 02801-1, ASPHALTIC CONCRETE MIX REQUIREMENTS, as follows:

Design Parameters	Class A	Class B
Voids in total mix, percent	2.5 - 4.0	2.5 - 4.0%
Percent oil content	5.8 - 6.8	5.8 - 6.8%"

And replace it with:

"SECTION 02801 – ASPHALT CONCRETE PAVEMENT, PART 1 – GENERAL, Article 1.1, DESCRIPTION, *revise* TABLE 02801-1, ASPHALTIC CONCRETE MIX REQUIREMENTS, *as follows:*

Design Parameters	Class A	<u>Class B</u>
Voids in total mix, percent	2.5 - 4.0	2.5 - 4.0%
Percent oil content	5.8 - 6.8	5.8 - 6.8%*

^{*} Percent oil content for Type III Mix designs shall be 5.0 - 6.8"

Greg Smith, Contract Administrator

Total number of pages contained within this Addendum: 2