



ADDENDUM TO THE CONTRACT

for the

CREST STREET RECONSTRUCTION Contract No. BE21-219

ADDENDUM NO.: TWO

CURRENT DEADLINE FOR BIDS:
May 18, 2021

PREVIOUS ADDENDA: ONE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: May 14, 2021

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <https://juneau.org/engineering-public-works/current-bids-and-rfps>

DRAWINGS:

Item No. 1 SHEET C-202 Plan – Crest St STA “C” 12+00 to STA “C” 14+00

Delete the note that reads: “CTE W/LSS-1 non-shear coupling”

And **replace it with:** “CTE with 21”x18” PVC reducer, Romac 501 coupling with shop coat and 316 stainless steel hardware, or approved equal, and other fittings as required.”

Item No. 2 SHEET C-204 Plan – Crest St STA “C” 16+50 to STA “C” 19+00

Delete the note that reads: “CTE with 21x18 reducer and 18” LSS-1 non-shear coupling”

And **replace it with:** “CTE with 21”x18” PVC reducer, Romac 501 coupling with shop coat and 316 stainless steel hardware, or approved equal, and other fittings as required.”

By: 
Greg Smith,
Contract Administrator