



INFORMATION TO PROPOSERS
for

(C3) RFP No. E22-056
Design and Construction Administration
For the
BRH Emergency Department Addition and Renovation

ISSUED BY:

City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

Date Issued: July 23, 2021

The following information is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <https://juneau.org/engineering-public-works>. This is **not** an addendum.

Question 1: *“Is there a boiler capacity analysis available or will that be a part of the scope of services?”*

Response: A load and capacity analysis to handle the new load will need to be a part of the design scope.

Question 2: *“Will existing ductwork remain in place or will the consultant need to consider new design?”*

Response: Evaluating use of the existing duct work will be part of the design scope. Designated rooms will be used as negative pressure isolation patient rooms as well as non-isolation patient rooms. It is the responsibility of the design team to research the requirement for both types of rooms and design accordingly.