



**INFORMATION TO BIDDERS**

for the

**BARTLETT REGIONAL HOSPITAL  
CAMPUS DOOR UPGRADES 2021  
Contract No. BE22-171**

**ISSUED BY:** City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801

**DATE ISSUED:** December 10, 2021

The following information is posted online. Please refer to the CBJ Engineering Public Purchase webpage at: <https://www.publicpurchase.com/gems/juneau.ak/buyer/public/home>.

This is ***not*** an addendum.

- ❖ The conduits associated with the door magnets on sheet E200 Detail 3 shall be surface mounted. Conduits and cables associated with all other equipment shall be concealed except in electrical rooms.