



## INFORMATION TO BIDDERS

for the

### RIVERBEND ELEMENTARY SCHOOL WATER DAMAGE REPAIR Contract No. BE22-252

**ISSUED BY:**

City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801

**DATE ISSUED:**

**March 22, 2022**

The following information is posted online. Please refer to the CBJ Engineering Public Purchase webpage at: <https://www.publicpurchase.com/gems/juneau,ak/buyer/public/home>. This is **not** an addendum.

QUESTION: "068316 2.2 A. 3. Surface Finish says 'As selected by architect from manufacturer's full range,' and drawing sheet A001 says 'Color selected by Architect.'  
I'm being told a smooth finish gray sheet that has to come from the factory, can be 4-5x more expensive than say a pebbled finish white sheet that some suppliers still stock. Color would be great to know, but it's necessary to narrow down the panel finish to quote accurately."

RESPONSE: We are looking for the pebbled finish, nothing fancy like the smooth finish. Color would be white or gray pebbled.