



**ADDENDUM TO THE CONTRACT**  
**for the**  
**BRH FUEL SYSTEM UPGRADES**  
**Contract No. BE22-233**

**ADDENDUM NO.:** SIX

**CURRENT DEADLINE FOR BIDS:**  
June 28, 2022

**PREVIOUS ADDENDA:** FIVE

**ISSUED BY:** City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801

**DATE ADDENDUM ISSUED:** **June 23, 2022**

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Public Purchase webpage at: <https://www.publicpurchase.com/gems/juneau.ak/buyer/public/home>

**DRAWINGS:**

Item No. 1 Sheet M1.0D – FUEL SYSTEM PLAN DEMOLITION, 1 – MANHOLE DETAIL.

***Replace:*** MANHOLE COVERS AND FRAMES TO BE REMOVED AND REPLACED PER CBJ STANDARD 206A.

***With:*** MANHOLE 2 (FUEL LINE MANHOLE) COVERS AND FRAMES TO BE REMOVED AND REPLACED WITH OWNER-SUPPLIED MANHOLE COVER AND FRAME. EXISTING LETTER ON THE OWNER-SUPPLIED MANHOLE COVER SHALL BE REMOVED AND REPLACED WITH “FUEL” IN 2” LETTERING. MANHOLE 1 (FUEL FILL MANHOLE) WILL BE REMOVED AND REPLACED PER CBJ STANDARD 206A WITH MANHOLE COVER LABELED “FUEL” IN 2” CAST LETTERS.

Item No. 2 Sheet M1.0 – FUEL SYSTEM PLAN CONSTRUCTION, EXTERIOR VENT LOCATIONS, UNDERGROUND STORAGE TANK (UST)

***Replace:*** REPACE BOTH MANHOLE COVERS & FRAMES PER CBJ STANDARD 206A. MANHOLE COVERS TO BE LABELED “FUEL” IN 2” CAST LETTERS

***With:*** MANHOLE 2 (FUEL LINE MANHOLE) COVERS AND FRAMES TO BE REMOVED AND REPLACED WITH OWNER-SUPPLIED MANHOLE COVER AND FRAME. EXISTING LETTER ON THE OWNER-SUPPLIED MANHOLE COVER SHALL BE REMOVED AND REPLACED WITH “FUEL” IN 2” LETTERING. MANHOLE 1 (FUEL FILL MANHOLE) WILL BE REMOVED AND REPLACED PER CBJ STANDARD 206A WITH MANHOLE COVER LABELED “FUEL” IN 2” CAST LETTERS.

By:   
Caleb Comas,  
Contract Administrator