



ADDENDUM TO THE CONTRACT

for the

AUGUSTUS BROWN POOL MECHANICAL & ELECTRICAL UPGRADES Contract No. BE23-019

ADDENDUM NO.: FIVE

CURRENT DEADLINE FOR BIDS:
July 26, 2022

PREVIOUS ADDENDA: FOUR

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: **July 15, 2022**

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Public Purchase webpage at: <https://www.publicpurchase.com/gems/juneau,ak/buyer/public/home>

CLARIFICATIONS:

Question: “Sheet E7.03 indicates a new PNL-H, however E6.01 does not show it on the one line diagram and sheet E3.01 where the panel says its located is not shown either. Are we providing panel H or not?”

Response: Panel H is not required for this project, all equipment in pool systems room 128 shall be circuited to panel M or G as shown on E3.01.

DRAWINGS:

Item No. 1 Sheet E7.03 – PANEL SCHEDULES.
Delete PANELBOARD H.

By: Caleb Comas
Caleb Comas,
Contract Administrator

Total number of pages contained within this Addendum: 1