



ADDENDUM TO THE CONTRACT

for the

GLACIER FIRE STATION M/E UPGRADES & JUNEAU FIRE STATION GENERATOR REPLACEMENT

Contract No. BE22-108

ADDENDUM NO.: SIX

CURRENT DEADLINE FOR BIDS:
September 15, 2022

PREVIOUS ADDENDA: FIVE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: September 8, 2022

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Public Purchase webpage at: <https://www.publicpurchase.com/gems/juneau.ak/buyer/public/home>

CLARIFICATIONS:

Question: *"Sheet MD301 shows demolition of boiler housekeeping pads. Will the Generator and pumps housekeeping pad needs to be demolished as well?"*

Response: Demolish the generator housekeeping pad. Patch floor. The pump pad can remain.

By: 

Caleb Comas,
Contract Administrator

Total number of pages contained within this Addendum: 1