



ADDENDUM TO THE CONTRACT
for the
CBJ Water Reservoir 2010 Corrosion Repairs &
Valve Vault Painting
Contract No. E10-217

ADDENDUM NO.: TWO

CURRENT DEADLINE FOR BIDS:
July 14, 2010

PREVIOUS ADDENDA: ONE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

PREVIOUS DEADLINE FOR BIDS:
July 7, 2010

DATE ADDENDUM ISSUED: June 30, 2010

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at:
<http://www.juneau.org/engineeringftp/contracts/Contracts.php>

PROJECT MANUAL:

Item No. 1 SECTION 00030 - NOTICE INVITING BIDS. DEADLINE FOR BIDS.

Change the date of the Deadline for Bids **from** July 7, 2010 **to** July 14, 2010. The time remains the same. The bid opening location has **changed** to the City Hall Room 224 Conference Room, 2nd Floor of the Municipal Building, 155 S. Seward Street.

Item No. 2 SECTION 09971 – WELDED STEEL WATER TANK PREPARATION & PAINTING, PART 3 – EXECUTION, Article 3.3 SURFACE PREPARATION OF STEEL, Paragraph A, **Add** the following sentence to the end of the paragraph:

Water will be available at the reservoir sites, but system pressure is less than 10 psi. Owner will supply a booster tank and pump to provide adequate pressure and volume to standard pressure-washing equipment. Contractor shall provide any fittings necessary to connect to Owner-supplied equipment, and shall coordinate use with Owner. Contractor shall return Owner's equipment in good, working condition or shall replace such equipment with equal or better equipment at the end of the project.

Item No. 3 SECTION 09960 – VALVE VAULT PREPARATION AND PAINTING, PART 1 – GENERAL, Article 1.5 SUBMITTALS, Paragraph B.1.b. **Delete** in its entirety and **replace** with the following:

- b. Submit listing of not less than 3 each of General Contractor's and Painting Sub-Contractor's most recent applications representing similar scope and complexity to Project requirements. List shall include information as follows:
 - i. Project name and address
 - ii. Name of OWNER
 - iii. Name of CONTRACTOR
 - iv. Name of engineer
 - v. Date of completion

Item No. 4 SECTION 09971 – WELDED STEEL WATER TANK PREPARATION AND PAINTING, PART 1 – GENERAL, Article 1.5 SUBMITTALS, Paragraph B.1.b. **Delete** in its entirety and **replace** with the following:

- b. Submit listing of not less than 3 each of General Contractor's and Painting Sub-Contractor's most recent applications representing similar scope and complexity to Project requirements. List shall include information as follows:
- i. Project name and address
 - ii. Name of OWNER
 - iii. Name of CONTRACTOR
 - iv. Name of engineer
 - v. Date of completion

Item No. 5 SECTION 09971 – WELDED STEEL WATER TANK PREPARATION & PAINTING, PART 1 – GENERAL, Article 1.8 PROJECT CONDITIONS, **Add** the following Paragraph and sub-paragraphs:

- B. Valve vaults on this project are 14' x 15.5' x 8' deep concrete underground vaults with a single 20"x30" man-hatch and permanent ladder. An additional larger equipment hatch is located near the center of the vault lid, as shown in profile on the sheet labeled "Section A" from Addendum No. 1 of these contract documents. The concrete vault lid is concrete overlaid with approximately 6" of rigid foam insulation, which is continuous over the equipment hatch.
1. Contractor is responsible for following all federal, state, and local regulations for performing project work within the limited-access underground vaults, and for all costs associated with following such regulations.
 2. Contractor may open equipment hatches to allow additional access and ventilation to the vaults during prosecution of the Work. Equipment hatch shall be returned to its original sealed and insulated condition at the end of the project.

Item No. 6 SECTION 09971 WELDED STEEL WATER TANK PREPARATION & PAINTING, PART 3 – EXECUTION, Article 3.3, SURFACE PREPARATION OF STEEL, Paragraph B **delete** in its entirety and **replace** it with the following:

- B. All pitted and rusted areas on the tank walls and roof shall receive a Power Tool Cleaning in accordance with SSPC-SP-11 or Blast Cleaning in accordance with SSPC-SP-10. All "popped" or loose paint and rusted areas shall be DA sanded to remove all loose or flaking paint or Blast Cleaned in accordance with SSPC-SP-10. If Blast Cleaning is used, CONTRACTOR shall remove all blast medium from the site in excess of 1/4" depth over the original grade. All costs associated with the removal and disposal of blast medium from the site shall be the responsibility of the CONTRACTOR.

By: 
Jennifer Mannix,
Contract Administrator

Date: 6/20/10

Total number of pages contained within this Addendum: 2