



ENGINEERING DEPARTMENT

**ADDENDUM TO THE CONTRACT  
for  
OUTER DRIVE AND WEST JUNEAU PUMP STATION REPAIR**

**Contract No. E11-029**

**ADDENDUM NO.:** ONE

**CURRENT BID OPENING DATE:**

**September 17, 2010  
2:00 p.m. Local Time**

**PREVIOUS ADDENDA:** NONE

**ISSUED BY:** City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801

**PREVIOUS DEADLINE FOR BIDS:**  
September 15, 2010

**DATE ADDENDUM ISSUED:** **September 14, 2010**

The following items of the contract are modified as herein indicated. All other items remain the same. This is a faxed addendum. A confirming copy will not be mailed to you. If this fax is incomplete, please call (907) 586-0490, and we will re-send it. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at:

<http://www.juneau.org/engineering ftp/contracts/Contracts.php>

**PROJECT MANUAL:**

Item No. 1: SECTION 00030 - NOTICE INVITING BIDS. DEADLINE FOR BIDS.

***Change*** the date of the Deadline for Bids ***from*** September 15, 2010 ***to*** September 17, 2010. The time remains the same. The bid opening location has ***changed*** to the City Hall Room 224 Conference Room, 2<sup>nd</sup> Floor of the Municipal Building, 155 S. Seward Street.

Item No. 2: SPECIAL PROVISIONS, SECTION 11176 – WASTEWATER PUMP STATION REPAIRS, PART 2 – PRODUCTS, Article 2.6, PIPE AND FITTINGS. In Paragraph A, ***change*** the second sentence to read:

*HDPE pipe shall be either SDR 13.5 or SDR 11 with outside diameters equivalent to either ductile iron pipe sizes or iron pipe sizes, as necessary to connect to existing pipe.*

Item No. 3: SPECIAL PROVISIONS, SECTION 11176 – WASTEWATER PUMP STATION REPAIRS, PART 2 – PRODUCTS, Article 2.6, PIPE AND FITTINGS. In Paragraph D, change the words "Schedule 40 ABS" to read "HDPE"

**DRAWINGS:**

Item No. 1: Sheet No. C201, WEST JUNEAU PUMP STATION SITE PLAN SECTIONS AND DETAILS. ***Add*** the following notes to Quick Coupling Vault and Force Main Connection Plan 2:

*The drain pipe leaving the bottom of the vault shall be labeled "4" Ductile Iron Pipe".  
The pipe taps and elbows attached to the 8" elbows shall be labeled as "3" HDPE".  
The pipeline drain valves on the 3" taps shall be labeled as "3" plug valves".*

By: \_\_\_\_\_  
Jennifer Mannix,  
Contract Administrator